

Report Of Passed Appliances
For all Sites and Locations

lite alternative

Lite Alternative LTD
Unit 4
Duttons Way
Shadsworth Business Park
Blackburn
Lancashire
BB1 2QR
Phone: 01254 279 654

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
LA -											
100M MULTICORE (TYPE I)	LA22719	02/02/17	P	S	S	S	S	S	S	S	S
100M MULTICORE (TYPE I)	LA21298	02/02/17	P	S	S	S	S	S	S	S	S
100M MULTICORE (TYPE III)	LA37444	17/01/17	S	S	S	S	S	S	S	S	S
100M MULTICORE (TYPE III)	LA34106	17/01/17	S	S	S	S	S	S	S	S	S
120MM CAMLOCK - POWERLOCK 3M ADAPTOR	LA30903	18/01/17	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 10M	LA30896	18/01/17	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 10M	LA30897	18/01/17	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 3M	LA20334	18/01/17	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 3M	LA17069	18/01/17	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 3M	LA30898	27/01/17	P	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 3M	LA30899	27/01/17	P	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 5M	LA30900	18/01/17	S	S	S	S	S	S	S	S	S
120MM POWERLOCK LUG 3M	LA30902	18/01/17	S	S	S	S	S	S	S	S	S
120MM POWERLOCK TAILS 3M	LA30901	18/01/17	S	S	S	S	S	S	S	S	S
125A 1PH 10M MAINS EXTENSION	LA26118	31/01/17	P	S	S	S	S	S	S	S	S
125A 1PH 10M MAINS EXTENSION	LA26119	31/01/17	P	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA32364	18/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA00955	18/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA22278	18/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA33550	03/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA22101	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA21059	13/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA21508	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA21759	18/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA32470	05/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA17150	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA30725	10/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA35101	13/01/17	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA20304	03/01/17	S	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA32469	03/01/17	S	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA37824	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA22670	25/01/17	P	S	S	S	S	S	S	S	S
125A 3PH LUGGED TAILS	LA21061	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH LUGGED TAILS	LA22672	03/01/17	S	S	S	S	S	S	S	S	S
125A 3PH LUGGED TAILS	LA32468	03/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA30798	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA33646	04/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
125A 3PH MAINS CABLE 10M	LA26973	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA30748	18/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA22668	10/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA22669	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA31659	10/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA39008	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA32462	18/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA39024	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 3M	LA22667	03/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 3M	LA37771	03/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA32464	10/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA26972	04/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA22666	18/01/17	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA39064	18/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26226	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26761	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26221	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA35135	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32201	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32203	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32199	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32195	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26219	22/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26229	09/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36138	08/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36139	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA25158	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36135	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30291	09/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA35122	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA25458	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36140	24/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36134	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33622	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA24531	23/01/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33624	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36133	25/01/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36136	19/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36137	02/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA24548	10/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA24551	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32193	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33605	09/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA35090	19/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33607	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26966	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26707	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33608	23/01/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26704	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30298	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30288	23/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30297	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30292	19/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33606	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA17889	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30296	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26316	22/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33615	23/01/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33619	09/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30287	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32194	03/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33621	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33617	22/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33618	19/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33609	09/01/17	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33614	22/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33613	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26854	01/02/17	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33612	01/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
13A - 16A 1PH ADAPTER 0.5M	LA34556	19/01/17	S	S	S	S	S	S	S	S	S
13A - POWERCON ADAPTOR	LA35136	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37780	04/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37694	04/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA20501	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA20497	09/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA37620	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA37964	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA32090	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA40325	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA30808	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA32091	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA30805	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA17591	27/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA17286	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA04474	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA16434	27/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA17500	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA25997	27/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA16438	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA33335	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA33331	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA17662	17/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA16136	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA15517	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA16339	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA16193	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA15802	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA30132	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA17606	08/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA30130	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26749	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26740	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26750	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26746	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26742	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26743	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32739	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32735	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25804	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32741	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25803	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32738	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25802	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA26709	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25914	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32745	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32744	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32737	02/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - EDISON (US) FEMALE 0.5M	LA26708	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32746	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25177	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32743	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25175	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25171	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25172	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25174	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32742	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25913	13/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32740	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA35134	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M ADAPTOR	LA25805	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA30881	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17568	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17566	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17264	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24218	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24150	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17567	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17570	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17034	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17476	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA35100	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17667	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24798	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17292	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17665	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA26304	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26935	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26994	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA17200	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33927	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA17480	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA21668	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26919	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26992	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA35095	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA21670	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24022	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA35098	08/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24026	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26928	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26950	19/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - IEC ADAPTOR	LA31879	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24937	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24711	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26213	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26218	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26210	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25408	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32025	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA16872	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32011	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32026	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25430	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32024	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26211	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26519	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26413	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26506	08/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25979	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25624	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30875	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26513	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26508	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26509	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26510	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26514	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26517	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26512	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32012	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30880	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33932	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30884	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30877	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30870	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30874	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24356	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24352	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26996	08/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30882	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA34245	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24362	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32019	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32021	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32015	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32013	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32008	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25883	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32010	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32018	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39639	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39626	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39630	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39638	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39632	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39636	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39635	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39631	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39633	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39788	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39790	25/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA39623	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39624	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39786	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39773	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39814	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39813	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39258	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39273	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39270	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39809	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39808	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39811	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39817	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39816	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39812	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39207	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39236	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39231	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39256	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39248	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39209	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39282	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39274	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39269	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39281	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39276	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39283	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39810	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39775	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39780	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39778	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39784	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39781	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39777	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39798	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39791	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39787	24/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA39794	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39793	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39807	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39827	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39824	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39820	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39826	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39825	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39828	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39783	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39782	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39785	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39819	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39823	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39821	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30691	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30682	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30692	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30686	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30681	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30670	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30667	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30685	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30684	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30690	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30677	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30680	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32773	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30678	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30679	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30676	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30674	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30672	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30671	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30665	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32251	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32263	24/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA32250	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32253	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32262	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32256	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32255	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32264	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32260	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32334	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30663	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32258	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30669	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30668	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA31881	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32335	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32339	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32259	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32338	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32775	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39621	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39620	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39619	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39618	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32309	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39607	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39613	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39615	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39609	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39589	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39596	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39604	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39640	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39600	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39602	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39586	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39594	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39595	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39587	24/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA39611	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32781	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32778	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32786	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32784	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32777	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32790	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32787	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32780	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32779	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32319	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32320	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26951	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32311	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32317	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26932	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32783	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32782	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32322	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32318	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38897	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38900	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38899	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38898	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38905	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38904	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38901	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38887	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38884	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38883	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38930	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38927	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38929	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38928	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38893	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38896	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38895	24/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA38894	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38916	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38919	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38918	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38890	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38903	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38902	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38891	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38892	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38889	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38888	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35613	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35610	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35607	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35614	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35253	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35612	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35611	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40226	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30719	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30720	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40231	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35605	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35609	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35608	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA24062	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA24075	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA24082	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38881	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38886	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38885	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38882	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35203	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35252	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35256	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35242	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA24076	01/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA35215	17/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35208	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38917	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25614	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25615	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26352	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25612	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17745	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25610	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25611	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26251	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26107	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26102	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26324	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26351	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26342	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26253	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17744	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17582	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17580	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17972	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17968	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17966	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17969	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25808	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25806	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25807	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25867	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17574	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25873	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25870	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38911	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38907	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38906	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38914	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38913	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38912	24/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA38915	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38925	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38924	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38920	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38921	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38910	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38908	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38922	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26247	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26249	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26244	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26246	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26104	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26105	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26089	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA37623	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA37624	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA37178	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25151	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA24374	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25423	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25154	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39834	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39552	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39547	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39546	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39556	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39555	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39553	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39557	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39201	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39195	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39205	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39182	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39551	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39549	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39318	24/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA39577	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39539	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39538	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39579	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39581	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39575	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39573	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39527	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39534	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39533	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39532	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39545	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39542	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39536	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39309	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39308	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39302	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39303	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39287	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39286	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39307	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39252	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39249	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39257	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39299	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39296	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39295	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39301	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39191	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39190	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39206	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39184	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39203	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39194	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39186	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39288	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39285	30/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA39284	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39291	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39290	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39289	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39294	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39584	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40351	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40350	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40357	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40360	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40361	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40373	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40366	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39504	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39500	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39495	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39506	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40352	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39503	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39502	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39831	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26952	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30718	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39832	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39833	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39830	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39829	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40328	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40327	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40363	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40338	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40337	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40332	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40347	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39572	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39570	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39564	09/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA39565	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39490	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39525	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39568	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39583	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39582	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39585	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39562	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39561	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39559	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39563	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39514	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39524	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39523	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39516	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39492	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39499	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39497	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39509	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39470	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39491	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39512	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39513	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39508	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39507	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32314	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26684	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33816	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33817	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33810	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA34063	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA34064	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33838	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33812	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33790	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26648	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33830	24/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA33796	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33815	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26623	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33791	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33564	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33575	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33842	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33577	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33583	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33584	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33576	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33843	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26673	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26683	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26669	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26622	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33839	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33840	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30716	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33831	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33220	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33226	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33224	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33222	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33234	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33233	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33228	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33245	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33236	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33822	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33825	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33240	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33242	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33263	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33248	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33836	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26650	24/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA33833	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33835	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33828	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33829	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33832	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33834	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33818	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33819	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33230	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33821	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26651	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33820	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33232	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35029	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35027	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35030	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35028	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30713	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35047	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35050	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35040	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30714	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35089	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35025	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35078	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35042	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35077	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26616	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26794	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26619	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26620	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26793	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26752	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26722	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26795	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26621	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30704	25/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA30709	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA34559	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30696	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26618	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30693	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30694	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30711	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33668	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33590	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33547	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33667	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33599	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33670	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33675	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30715	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33582	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33585	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33588	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33579	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33580	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33581	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33578	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35011	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35012	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33604	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35013	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30712	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35016	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35024	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33593	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33602	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33603	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33598	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33597	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33596	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33591	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33592	24/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON ADAPTOR	LA33218	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32323	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33219	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33213	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32332	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33235	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32324	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32328	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33824	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32326	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32327	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30702	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33211	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33207	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30701	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33826	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33239	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33202	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33198	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33212	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32312	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32331	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33208	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33216	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33197	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33200	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33237	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33203	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32333	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32330	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33210	30/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33204	25/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33823	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33206	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35017	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35022	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35021	27/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON TRUE 0.5M	LA35019	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35018	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35015	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39740	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39743	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39737	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39733	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39734	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39767	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39764	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39766	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39738	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39739	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39736	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39746	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39749	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39744	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39747	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39748	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39752	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39735	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39750	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39753	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39754	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35014	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39704	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39705	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32607	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32608	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39703	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39710	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39707	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39706	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39709	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32610	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA33808	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32613	09/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON TRUE 0.5M	LA33806	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA33809	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32614	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32615	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32609	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32611	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32612	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39708	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39712	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39718	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39715	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39711	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39721	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39720	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39732	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39722	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39719	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39714	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39723	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39724	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39725	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39726	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39727	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39728	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39729	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39730	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39731	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40261	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40264	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40256	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40257	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40265	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40249	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40250	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40262	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40263	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40260	27/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON TRUE 0.5M	LA34789	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34786	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34791	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34793	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34783	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34710	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40259	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34788	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34787	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40247	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40246	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40242	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40241	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40244	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40243	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35621	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35623	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35620	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35624	03/03/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40238	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40254	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40255	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40248	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40251	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40252	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40240	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40237	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40253	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40239	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34792	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39763	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39760	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39759	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39762	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39761	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35071	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35070	24/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON TRUE 0.5M	LA35069	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35068	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39756	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39771	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39772	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39765	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39768	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39769	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39758	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39755	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39770	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA39757	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35067	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35055	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35054	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35062	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35061	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35053	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34782	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34781	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34780	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA34776	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35056	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35066	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35065	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35064	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35063	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35072	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35026	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35060	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35032	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35031	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32375	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32374	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32371	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32369	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA33805	16/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - POWERCON TRUE 0.5M	LA33802	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA33801	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA33800	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32383	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32382	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32377	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32378	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32372	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32370	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32376	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32373	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA33799	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA33807	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30206	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30204	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA17491	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30210	13/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30202	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA35110	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA17489	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30207	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30208	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26758	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26759	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26326	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25991	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26658	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25800	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26757	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25799	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25990	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26360	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26361	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26179	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25930	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26368	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26366	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26661	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26373	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25391	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25393	13/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26756	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26755	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA24741	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25924	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA24760	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26328	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26322	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26765	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26766	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA24755	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26767	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26768	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA24756	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA24757	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25823	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA24759	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA24758	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26659	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25938	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25940	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25306	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25311	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26162	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25314	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25312	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26160	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25944	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25155	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25946	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25942	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25303	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26161	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26420	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26163	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26181	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26660	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA25928	13/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26656	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26414	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26183	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26180	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26165	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH (M) - BB4 (INPUT) I-PIX BB4 ADAPTOR	LA26182	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA16920	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA35020	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA17285	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA17279	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA17138	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA16919	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA26986	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA38544	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA34953	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA25106	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA16921	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA25194	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA16959	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA38524	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA38477	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA38526	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA17276	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA17280	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA17278	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA17258	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA26739	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37056	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37064	18/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37061	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37067	18/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37065	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37055	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37057	18/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37063	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37062	18/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37068	01/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH 2 WAY SPLITTER Y-CORD	LA33555	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33561	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35960	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35961	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35157	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33556	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34955	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35964	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33557	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34957	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35159	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34960	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35962	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26288	27/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35957	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35952	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26912	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35956	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26289	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35955	03/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34958	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34959	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34963	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33306	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26285	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34961	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35949	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26910	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35160	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33549	09/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35163	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26900	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26898	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26902	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26897	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34954	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26896	01/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH 2 WAY SPLITTER Y-CORD	LA35947	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35946	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33554	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA17240	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA25108	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16877	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA00726	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA00588	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16876	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16875	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA25109	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA25110	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16973	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16974	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA37182	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA20582	24/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA39167	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30184	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA24676	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25843	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25845	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25839	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA26062	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30186	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30189	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25976	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30187	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30183	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30185	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30257	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24117	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30258	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40116	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24109	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40150	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40118	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40119	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30249	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30252	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40115	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30250	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30254	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39076	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38978	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38979	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39072	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38980	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38982	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39079	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39080	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39077	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38983	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26955	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38969	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39071	10/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA30591	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30594	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40126	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38965	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40120	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40125	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40122	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39073	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39075	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30255	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35838	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40121	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30251	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30597	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30595	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26636	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35836	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30008	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35840	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30014	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30010	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30012	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30585	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30626	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30590	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30600	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30604	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30605	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30003	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30004	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30013	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32162	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35438	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35837	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35437	17/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26583	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26582	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35447	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35449	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30592	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32166	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32165	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35446	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24114	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24116	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24111	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24211	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30007	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24112	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35443	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30627	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32169	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35444	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35445	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35442	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32167	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32164	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32163	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32168	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32172	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32171	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39078	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25903	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25080	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30593	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30587	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25065	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25081	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25922	10/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA33279	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35441	17/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25082	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25079	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40137	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40139	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30601	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33276	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30583	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39477	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40143	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40144	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40146	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40142	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40145	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33280	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33277	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40136	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40127	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40132	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33278	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40131	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33281	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40134	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40128	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33270	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30578	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA04329	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30580	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30606	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30608	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30584	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40130	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40133	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40129	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA04080	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33274	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15950	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39083	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35847	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39082	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38968	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39084	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35842	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA34219	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35845	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA34334	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA04701	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35841	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39069	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39070	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35849	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35835	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35834	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35848	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38967	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35850	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26956	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35853	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38970	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40114	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25083	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40113	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40110	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24118	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40111	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40140	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40141	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33273	11/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA40112	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15960	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38977	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38973	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38976	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38971	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35844	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30001	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35430	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40107	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30586	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38974	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30002	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32698	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24709	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32701	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32705	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32704	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35435	17/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35431	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35434	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35858	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30599	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30020	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32695	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17090	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32709	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24522	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32703	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32702	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26586	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30015	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30016	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26048	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17293	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35439	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39654	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26705	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30603	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39656	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39657	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39660	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39655	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39659	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35436	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30622	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35433	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32706	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26110	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32699	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30619	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39662	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32697	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32700	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32710	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24588	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24591	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24585	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24858	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24861	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35856	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35859	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35857	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35863	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35860	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24852	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24853	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24851	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17096	10/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA30620	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35861	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24857	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35862	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24849	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24855	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24592	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32714	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24598	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32712	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32456	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32457	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32707	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35855	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24506	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32711	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32708	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32450	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32453	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32713	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26576	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30614	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24594	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24596	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32454	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24599	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32449	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26299	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26578	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26577	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25197	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26579	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30611	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26580	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25195	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30610	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26574	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30618	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26572	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30615	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17837	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17835	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26573	09/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30624	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30609	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17843	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30612	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26571	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26567	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30613	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32157	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32156	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17848	23/01/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32161	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26569	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32153	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32154	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25196	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26570	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32155	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32160	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32150	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32151	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26585	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32145	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25210	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32696	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25208	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30623	16/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA32144	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32147	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35440	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30588	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32148	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32146	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25199	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26639	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26638	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26640	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30616	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26637	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26604	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30056	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26601	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35453	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30058	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15974	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35456	17/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24883	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30828	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35462	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24884	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26602	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15986	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35460	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35865	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30818	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35866	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26598	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35870	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35864	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35868	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35873	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30259	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33290	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30211	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33288	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33292	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35869	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33289	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32733	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30266	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30264	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32729	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32116	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35452	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30052	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32115	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26599	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32732	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26600	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30053	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30814	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30815	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30054	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35455	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35454	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30051	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26411	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24205	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35871	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26590	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35450	17/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24210	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24204	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24206	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30219	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26047	12/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA26049	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35872	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24099	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39983	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26043	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24102	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35465	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39977	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39978	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39979	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39990	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39992	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39994	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39995	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35468	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35467	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24208	18/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35469	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35463	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35466	17/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35451	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35464	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30811	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32716	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32720	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32721	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32718	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39987	02/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39986	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32719	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30817	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35457	17/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35458	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26985	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32715	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32728	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32726	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32725	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32724	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30816	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30217	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39982	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39980	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30213	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30812	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39984	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30810	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38997	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39989	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38986	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38985	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38987	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17870	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39988	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39985	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24881	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17867	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30261	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26597	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30267	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26589	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17864	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24564	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24565	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24561	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30268	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17862	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24562	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32138	22/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA30823	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30263	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32140	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32141	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30821	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24568	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA02845	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17854	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA02583	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17853	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04242	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26593	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30221	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25085	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17858	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25087	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39004	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25086	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25059	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04391	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25057	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA34218	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15446	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15431	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25824	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32117	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32139	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26592	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26595	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17863	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17494	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26301	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38999	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26594	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25212	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17689	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33286	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32119	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32118	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32121	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32125	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30826	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32122	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25912	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30820	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24872	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32120	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32135	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30822	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25180	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15441	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30829	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32123	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24873	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24875	13/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32114	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17474	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32126	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24876	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32124	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30825	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32134	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32133	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32129	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33285	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24572	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24575	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32132	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33287	12/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA32131	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32127	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33284	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24571	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24869	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24867	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32137	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32136	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24870	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17010	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24868	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24576	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30260	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25000	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24998	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35471	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30223	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30231	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30230	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35470	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25060	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25061	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25062	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35484	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24092	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35487	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35477	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24997	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24995	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25201	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30232	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35485	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35486	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35483	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35480	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35479	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35475	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35476	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25001	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30064	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA34715	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30833	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35488	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30081	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30830	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35489	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25064	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25063	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33906	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35880	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA01224	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35887	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30832	18/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33294	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33301	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33302	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35886	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24903	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35889	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35891	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30831	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30074	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30076	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30079	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33296	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33300	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30078	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33913	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA15466	11/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 30FT	LA35883	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30354	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA15460	20/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30838	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26041	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25091	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30225	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30226	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25004	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30837	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30353	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35875	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30834	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30229	09/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30356	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30355	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30228	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33907	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35881	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33912	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26039	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25090	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35878	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35876	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24900	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26037	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26035	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30360	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35497	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35494	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30358	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35495	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35498	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35496	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35493	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35492	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35499	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35490	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA39028	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30240	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA04423	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30241	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30243	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30239	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA26612	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA02615	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30246	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30070	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA26611	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30244	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA02858	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA17118	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33926	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33923	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33917	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33914	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33925	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33924	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33916	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30845	23/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30847	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30238	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33922	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33919	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24896	19/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30120	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30118	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30119	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30067	12/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 50FT	LA24263	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24265	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35414	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35411	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24453	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35413	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15383	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24600	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24844	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24842	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24601	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24511	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24510	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24602	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26565	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24610	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24611	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15381	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35410	16/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24603	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24605	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24613	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24608	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26562	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35415	17/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35412	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26564	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35416	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35417	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35418	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35419	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17105	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24128	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17107	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17291	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24826	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24125	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24124	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24816	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26558	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26559	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26560	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26557	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26109	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33266	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26566	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17869	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24831	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24832	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24839	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24835	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38956	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24840	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24833	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24780	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38952	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24828	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38953	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38950	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24837	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24838	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17104	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24830	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24607	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25074	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25073	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25072	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25075	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33272	09/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA02419	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16055	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25067	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25148	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35427	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35426	15/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25125	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25070	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25069	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25068	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16905	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16981	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16983	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16984	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15928	16/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15936	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15940	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15943	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33271	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16632	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16908	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16912	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33269	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16263	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33268	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33267	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25126	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17249	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38961	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17294	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15391	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35424	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35423	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17129	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24617	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38964	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24641	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24614	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38958	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24616	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24615	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24618	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38948	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24123	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA04736	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15399	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA04553	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35429	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24122	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24120	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35425	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38949	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26628	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17121	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24127	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38946	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35422	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35420	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32595	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40085	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40089	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40086	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32598	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32599	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40088	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32601	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40092	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32448	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32593	11/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA32432	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32433	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32594	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40093	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32596	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32597	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39652	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34543	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34697	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40100	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39646	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34221	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39472	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40099	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34588	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40087	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39649	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39643	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39650	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39651	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39648	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39645	27/01/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39644	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39647	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40090	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30035	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40103	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30030	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32444	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40061	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40060	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40059	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40058	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30029	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32446	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30041	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30037	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32443	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30031	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30032	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30040	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32447	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40057	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39970	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39969	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39975	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39973	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40064	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40091	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39972	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39971	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32435	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39968	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39967	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39966	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32445	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32431	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32434	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32429	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32430	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30347	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30343	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30034	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30043	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30333	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30336	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30344	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30332	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30033	10/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA30046	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30050	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30102	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30047	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40079	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40078	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30049	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40076	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26953	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30109	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30108	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30115	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30114	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30117	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30116	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30111	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30110	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30112	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30335	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30042	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30337	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30334	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30044	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30113	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30348	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30045	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40077	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40095	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40094	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40101	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40098	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40071	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40070	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40097	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40096	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40102	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30342	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30338	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39478	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30341	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30099	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30105	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30339	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30345	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40073	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40067	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40082	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40068	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30103	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40083	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40080	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40081	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40084	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30100	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40066	24/01/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30104	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40072	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40069	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40065	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30101	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30107	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30106	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30039	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35807	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35832	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33782	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32189	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35817	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35816	09/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA35831	01/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35833	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35797	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30351	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35794	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35799	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32180	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32182	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30350	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32186	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35820	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32680	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35811	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30563	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32192	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32681	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30556	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30567	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30566	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32187	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32188	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35819	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32190	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30565	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30562	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35815	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30564	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32184	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30570	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30573	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30546	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30571	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30568	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30575	16/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30572	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30569	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30545	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30544	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30548	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30547	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30551	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30550	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30555	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30549	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA31882	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35801	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32178	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30576	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32176	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35796	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32179	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32173	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32174	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30021	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30025	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30574	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30577	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35805	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35804	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35803	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35802	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30559	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35824	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40105	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35821	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35825	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30022	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30024	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40104	11/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA40106	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35823	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35826	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32663	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32662	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35829	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30538	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30537	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30543	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30542	18/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30540	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30038	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32510	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32512	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32509	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32436	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32437	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32441	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32442	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32511	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33781	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32516	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30539	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30028	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32507	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32508	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32513	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32514	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35813	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32677	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32671	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32668	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35828	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35827	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35810	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35812	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32683	12/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30560	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32670	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32684	22/02/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30557	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30558	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32682	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32678	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32655	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32656	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32657	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32658	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35830	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32665	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32659	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32664	10/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32675	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32676	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32669	06/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32672	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32667	09/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30541	31/01/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32673	11/01/17	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32674	09/01/17	S	S	S	S	S	S	S	S	S
16A 3PH (4 PIN) - 2 X 16A 3PH (4 PIN)	LA15620	02/02/17	P	S	S	S	S	S	S	S	S
16A 3PH (4 PIN) - 2 X 16A 3PH (4 PIN)	LA15622	27/01/17	P	S	S	S	S	S	S	S	S
16A 3PH (4 PIN) - 2 X 16A 3PH (4 PIN)	LA15621	02/02/17	P	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA17025	02/02/17	P	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA32365	31/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 3PH 4P TRS 25M	LA32367	31/01/17	P	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA32368	31/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA17217	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA25764	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA34704	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA34698	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA25765	04/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA25214	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA33513	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA25204	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA34706	02/02/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32077	07/03/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA00996	24/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA15522	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA15529	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA15521	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA34705	04/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32828	24/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32829	24/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32825	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32823	24/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32836	01/02/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32837	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32835	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32831	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32833	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32827	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32830	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32834	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32822	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32351	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA15531	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32348	13/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32350	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA24642	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA25215	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32352	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA15523	13/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 415V/110V MOTOR CABLE 15M	LA38931	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32349	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA38938	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA15524	13/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32347	02/02/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36055	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36047	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36046	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA33065	04/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA37772	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA34569	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA33066	20/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32802	26/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32795	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32794	26/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32799	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA24638	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32803	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32805	20/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36048	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32798	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32797	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36052	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36050	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36049	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36053	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA25771	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA25916	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA25921	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA33067	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA33070	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA33069	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA25773	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30919	02/02/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30918	24/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA00333	31/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA34707	13/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 415V/110V MOTOR CABLE 25M	LA26388	31/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA37221	31/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30917	24/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30915	24/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30920	02/02/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA17193	13/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA16163	31/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA15570	31/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32051	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32484	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32343	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32344	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32807	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32811	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32810	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32809	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32806	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32821	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32812	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32813	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA33495	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA25437	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32814	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32816	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32341	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32819	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32346	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32817	04/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA30912	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA30910	01/02/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA25993	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32490	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32488	06/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA25767	04/01/17	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32485	30/01/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32486	06/01/17	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA26941	13/01/17	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA30369	01/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A XLR5 COMBI CABLE 10FT	LA33995	23/01/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA38527	13/01/17	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA25402	16/01/17	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA25404	16/01/17	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA16109	13/01/17	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA38954	13/01/17	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA17521	23/02/17	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA16308	13/02/17	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA30137	31/01/17	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA25814	08/02/17	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA16312	23/02/17	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA30134	31/01/17	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA03445	31/01/17	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA33340	31/01/17	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA17520	17/01/17	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA16309	31/01/17	P	S	S	S	S	S	S	S	S
32A 1PH - 63A 1PH ADAPTOR	LA38043	31/01/17	P	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30138	23/02/17	P	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30140	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30141	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30139	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 2 WAY SPLITTER	LA25819	31/01/17	P	S	S	S	S	S	S	S	S
32A 1PH 2 WAY SPLITTER	LA25818	31/01/17	P	S	S	S	S	S	S	S	S
32A 1PH 2 WAY SPLITTER	LA25817	31/01/17	P	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA32423	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA30143	23/02/17	P	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA30144	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA32424	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA30145	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA30142	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA26963	23/02/17	P	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA15710	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA32425	23/02/17	P	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA16190	12/01/17	S	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA32428	23/02/17	P	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA32427	09/02/17	P	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32030	18/01/17	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36011	21/02/17	P	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA20179	18/01/17	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36008	02/02/17	P	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32288	02/02/17	P	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32029	23/02/17	P	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32028	02/02/17	P	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32287	02/02/17	P	S	S	S	S	S	S	S	S
32A 3PH - 16A 3PH (4 PIN) MOTOR ADAPTOR	LA26754	02/02/17	P	S	S	S	S	S	S	S	S
32A 3PH - 16A 3PH (5 PIN) ADAPTOR	LA17023	02/02/17	P	S	S	S	S	S	S	S	S
32A 3PH - 3 X 32A 1PH ADAPTOR	LA26989	02/02/17	P	S	S	S	S	S	S	S	S
32A 3PH - 32A 1PH ADAPTOR	LA37262	02/02/17	P	S	S	S	S	S	S	S	S
32A 3PH - 32A 1PH ADAPTOR	LA25985	02/02/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32908	31/01/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA22979	31/01/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA00242	18/01/17	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA21074	05/01/17	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA21558	31/01/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32910	05/01/17	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA26960	25/01/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32907	31/01/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA37774	10/01/17	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA36114	02/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA36115	02/02/17	P	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA36112	01/02/17	P	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA20309	18/01/17	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA26954	02/02/17	P	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA20174	02/02/17	P	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22050	24/01/17	P	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22049	24/01/17	P	S	S	S	S	S	S	S	S
32A 3PH LUGGED TAILS	LA15900	24/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30763	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30097	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA17433	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30506	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33645	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA26261	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33638	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30762	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30755	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA34941	09/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30754	25/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33367	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30510	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30509	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30094	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30504	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30507	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30508	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30505	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38837	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38838	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38839	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38846	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA30756	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38847	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA33063	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32911	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32912	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA30768	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32459	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA33064	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38836	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32460	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA33059	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA33528	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30771	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30516	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30769	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32281	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30517	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32284	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA20644	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30800	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32282	09/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30773	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30801	03/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30772	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30523	24/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30524	26/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33366	24/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30776	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38848	24/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA25328	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38850	24/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38849	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30525	19/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
32A 3PH MAINS CABLE 30M	LA30757	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30520	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA25327	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38851	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30522	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33364	24/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30774	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30802	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33365	24/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30775	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA25097	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30494	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA17459	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32394	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32482	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30490	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30491	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32483	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30487	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA33315	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32397	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32396	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA39160	25/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32395	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32398	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA17428	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA17431	19/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30753	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32393	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33655	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30247	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33654	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33647	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32392	03/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32916	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30502	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33494	09/01/17	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32915	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30498	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33496	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33503	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30501	23/02/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32914	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25350	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32391	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25335	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25336	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30495	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30496	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25340	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32917	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30248	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25351	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32390	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25338	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30497	23/01/17	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25333	19/01/17	S	S	S	S	S	S	S	S	S
35MM CAMS - POWERLOK ADAPTOR	LA20330	03/01/17	S	S	S	S	S	S	S	S	S
35MM CAMS - POWERLOK ADAPTOR	LA22279	25/01/17	P	S	S	S	S	S	S	S	S
35MM POWERLOCK LINK 1M	LA37673	18/01/17	S	S	S	S	S	S	S	S	S
50M FOH MULTICORE (16A 1PH, 5 PIN DMX)	LA04455	02/02/17	P	S	S	S	S	S	S	S	S
50M FOH MULTICORE (16A 1PH, 5 PIN DMX)	LA20314	02/02/17	P	S	S	S	S	S	S	S	S
50M TYPE III MULTICORE 16A	LA34414	02/02/17	P	S	S	S	S	S	S	S	S
50MM POWERLOCK CABLE 3M	LA20470	18/01/17	S	S	S	S	S	S	S	S	S
50MM POWERLOCK CABLE 3M	LA21290	18/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
5M FOH DESK LOOM ETHERNET & POWER	LA30784	03/01/17	S	S	S	S	S	S	S	S	S
63A 1PH - 125A 1PH ADAPTOR	LA30759	31/01/17	P	S	S	S	S	S	S	S	S
63A 1PH - 2 X 32A 1PH ADAPTOR	LA17018	31/01/17	P	S	S	S	S	S	S	S	S
63A 1PH - 2 X 63A 1PH SPLITTER	LA17017	31/01/17	P	S	S	S	S	S	S	S	S
63A 1PH - 32A 1PH ADAPTOR	LA38044	31/01/17	P	S	S	S	S	S	S	S	S
63A 1PH - 63A 3PH ADAPTER	LA37913	31/01/17	P	S	S	S	S	S	S	S	S
63A 1PH 10M MAINS	LA03436	31/01/17	P	S	S	S	S	S	S	S	S
63A 1PH 10M MAINS	LA02522	31/01/17	P	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA26971	25/01/17	P	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA21206	04/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA22248	10/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA35152	03/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA34391	18/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA22481	02/02/17	P	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA26961	25/01/17	P	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA22852	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA32385	18/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA22851	18/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - 63A 1PH ADAPTOR	LA15716	31/01/17	P	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA21446	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA22330	18/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA22326	25/01/17	P	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA21447	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA31371	25/01/17	P	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA37825	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA21432	10/01/17	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA22182	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA20315	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA21433	25/01/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA25626	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA32466	25/01/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA00751	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA21427	10/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA17167	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA21309	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA21424	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA25627	10/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA21308	25/01/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA32465	18/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA33627	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA25625	25/01/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA34533	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA16538	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA32467	05/01/17	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA21428	10/01/17	S	S	S	S	S	S	S	S	S
70MM CAMS - POWERLOCK ADAPTOR 3M	LA22135	04/01/17	S	S	S	S	S	S	S	S	S
70MM CAMS - POWERLOCK ADAPTOR 3M	LA21082	05/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK BARE END TAILS	LA33406	05/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK BARE END TAILS	LA21008	05/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK BARE END TAILS	LA17058	04/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 10M	LA21943	05/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 10M	LA33403	04/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 10M	LA31219	05/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE	LA21159	05/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
20M											
70MM POWERLOCK CABLE	LA21572	05/01/17	S	S	S	S	S	S	S	S	S
20M											
70MM POWERLOCK CABLE	LA33402	10/01/17	S	S	S	S	S	S	S	S	S
20M											
70MM POWERLOCK CABLE 3M	LA33405	04/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 3M	LA22718	04/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 3M	LA22307	04/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 3M	LA30895	03/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 3M	LA21573	04/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 5M	LA31289	05/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 5M	LA22368	04/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 5M	LA33404	04/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK LUGGED TAILS	LA21942	04/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK LUGGED TAILS	LA33407	05/01/17	S	S	S	S	S	S	S	S	S
70MM POWERLOCK LUGGED TAILS	LA20307	05/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK BARE END TAILS	LA21816	16/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK BARE END TAILS	LA31562	16/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA15136	10/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA31401	10/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA21741	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA31565	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 20M	LA21740	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 20M	LA22114	10/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 20M	LA31564	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 2M	LA31945	18/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA22972	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA31567	27/01/17	P	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA31669	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA22971	18/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA21815	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA21814	27/01/17	P	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA34466	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA21744	18/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA31610	18/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA20336	18/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA31566	27/01/17	P	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 5M	LA21155	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 5M	LA31568	13/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 5M	LA38572	10/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK LUGGED TAILS	LA31563	16/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK LUGGED TAILS	LA21817	16/01/17	S	S	S	S	S	S	S	S	S
95MM POWERLOCK LUGGED TAILS	LA21158	18/01/17	S	S	S	S	S	S	S	S	S
AVO ART 2000 POWER CUBE	LA31780	24/01/17	P	S	0.03 P	>300 P	S	S	S	S	S
AVO ART 2000 POWER CUBE	LA31779	24/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
AVO ART 2000 POWER CUBE	LA22985	24/01/17	P	S	0.02 P	>300 P	S	S	S	S	S
AVO ART 2000 POWER CUBE	LA31082	24/01/17	P	S	0.04 P	>300 P	S	S	S	S	S
AVOCENT DUAL DVI KVM EXTENDER (RECEIVER)	LA39454	31/01/17	P	S	S	>300 P	S	S	S	S	S
AVOCENT DUAL DVI KVM EXTENDER (RECEIVER)	LA39452	31/01/17	P	S	S	>300 P	S	S	S	S	S
AVOCENT DUAL DVI KVM EXTENDER (TRANSMITTER)	LA39453	31/01/17	P	S	S	>300 P	S	S	S	S	S
AVOCENT DUAL DVI KVM EXTENDER (TRANSMITTER)	LA39447	31/01/17	P	S	S	>300 P	S	S	S	S	S
AVOCENT DUAL DVI KVM EXTENDER (TRANSMITTER)	LA39451	31/01/17	P	S	S	>300 P	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25988	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25931	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25935	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA24812	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25929	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25945	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25939	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26187	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26185	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25927	02/02/17	P	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26662	01/02/17	P	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26663	01/02/17	P	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26666	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25941	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26325	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25801	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26166	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26169	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26168	01/02/17	P	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26170	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26362	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26374	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26367	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25937	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26189	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26167	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26184	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26364	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26949	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26773	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26771	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA37274	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25324	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26776	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25315	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25319	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26777	13/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA24747	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA24745	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25323	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25322	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26770	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA24742	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26774	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA24744	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26775	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26772	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25822	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA24767	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26778	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25326	01/02/17	P	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA24764	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25395	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25396	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA24765	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25325	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25318	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA25317	13/01/17	S	S	S	S	S	S	S	S	S
BB4 (OUTPUT) - 16A 1PH (F) IPIX BB4 ADAPTOR	LA26769	13/01/17	S	S	S	S	S	S	S	S	S
CAMLOK - 125A 3PH ADAPTOR	LA17068	03/01/17	S	S	S	S	S	S	S	S	S
CAMLOK - 125A 3PH ADAPTOR	LA34718	04/01/17	S	S	S	S	S	S	S	S	S
CAMLOK - 63A 3PH ADAPTOR	LA17166	25/01/17	P	S	S	S	S	S	S	S	S
CAMLOK - 63A 3PH ADAPTOR	LA34534	05/01/17	S	S	S	S	S	S	S	S	S
CAMLOK - 63A 3PH ADAPTOR	LA20300	10/01/17	S	S	S	S	S	S	S	S	S
CUE SERVER PRO C/W PSU	LA34065	31/01/17	P	S	S	>300 P	S	S	S	S	S
EDISON (US) MALE - 16A 1PH 0.5M	LA39473	13/02/17	P	S	S	S	S	S	S	S	S
FOLSOM IMAGE PRO HD/SDI SCAN CONVERTER	LA26029	26/01/17	P	S	0.09 P	>300 P	S	S	S	S	S
FOLSOM IMAGE PRO HD/SDI SCAN CONVERTER	LA31210	31/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
FOLSOM IMAGE PRO HD/SDI SCAN CONVERTER	LA31415	26/01/17	P	S	0.07 P	>300 P	S	S	S	S	S
FOLSOM IMAGE PRO HD/SDI SCAN CONVERTER	LA31414	31/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
GRANDMA 2 ONPC COMMAND WING	LA38570	31/01/17	P	S	0.06 P	S	<0.05 P	0.40 P	S	S	S
GRANDMA 2 ONPC FADER WING	LA38571	31/01/17	P	S	0.08 P	>300 P	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25515	27/01/17	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA24377	27/01/17	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25518	27/01/17	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA15749	27/01/17	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA26483	27/01/17	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA35073	27/01/17	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25514	27/01/17	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25519	27/01/17	P	S	S	S	S	S	S	S	S
IEC (F) - 16A 1PH (M)&(F)	LA35139	01/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32636	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35084	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30389	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32897	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32894	16/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32890	31/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30392	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA39476	01/02/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32895	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38315	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA26711	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35114	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32898	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33310	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32633	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35617	03/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33312	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33307	08/02/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32902	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33311	31/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30388	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33563	17/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30393	17/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38310	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32473	17/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32564	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32565	17/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32567	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32896	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32566	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32479	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32474	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32475	09/02/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32477	08/02/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA40321	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32476	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35638	27/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32478	17/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35637	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35642	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35639	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32893	31/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA34574	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38312	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38313	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32887	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38311	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35618	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32903	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32891	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32899	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38308	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32569	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32570	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32572	17/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32568	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32571	17/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35616	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35615	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38309	20/01/17	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA37917	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32563	27/01/17	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC EXTENSION 0.25M	LA32094	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32099	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32098	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32097	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32102	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32101	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32100	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25483	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25484	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA35117	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25485	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32093	31/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25487	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25488	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33422	17/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33419	03/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33420	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA15858	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA15856	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33424	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA15753	20/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
IEC EXTENSION 0.25M	LA33425	03/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA26734	22/02/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17785	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32104	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA25494	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32105	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33417	17/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33421	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33415	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA25493	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17786	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA15850	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA16188	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17787	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA25490	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32109	16/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33411	03/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17788	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17778	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA34060	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32112	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32111	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32107	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32110	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32108	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25498	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25496	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25501	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25500	31/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17797	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17796	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17794	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17790	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25164	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25162	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25224	17/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25165	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA26714	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17987	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17988	18/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA16551	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA16382	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24774	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24770	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25984	22/02/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24771	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24783	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24727	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25223	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25833	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17674	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA35116	22/02/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25507	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA35113	03/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA35112	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25504	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA35128	19/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25505	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA26732	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17799	20/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA26733	17/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA25510	19/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA24925	19/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA24927	16/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA26726	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA26730	03/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA24928	27/01/17	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA24926	16/01/17	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA17650	20/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
I-PIX BB4 10M LINK CABLE	LA25794	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 10M LINK CABLE	LA25795	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 10M LINK CABLE	LA25793	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 10M LINK CABLE	LA25791	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24790	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26682	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24792	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25776	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24789	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25787	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25959	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25784	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25788	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26400	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26332	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26157	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26155	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25777	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24785	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24788	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24787	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24786	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26159	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26177	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24795	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26158	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26173	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26333	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26329	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25952	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26399	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25956	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24793	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25958	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25955	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25785	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25775	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA24796	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA25957	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 1M LINK CABLE	LA26154	01/02/17	P	S	S	S	S	S	S	S	S
I-PIX BB4 5M LINK CABLE	LA25798	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 5M LINK CABLE	LA25797	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 5M LINK CABLE	LA25812	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 5M LINK CABLE	LA25796	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 5M LINK CABLE	LA25810	13/01/17	S	S	S	S	S	S	S	S	S
I-PIX BB4 5M LINK CABLE	LA25811	13/01/17	S	S	S	S	S	S	S	S	S
JANDS STAGE CL COMPACT LIGHTING PSU	LA34345	31/01/17	P	S	S	>300 P	S	S	S	S	S
JANDS STAGE CL COMPACT LIGHTING PSU	LA34347	31/01/17	P	S	S	>300 P	S	S	S	S	S
JANDS STAGE CL LED CONSOLE	LA34344	31/01/17	P	S	S	>300 P	S	S	S	S	S
JANDS STAGE CL LED CONSOLE	LA34346	31/01/17	P	S	S	>300 P	S	S	S	S	S
JANDS VISTA S1 CONSOLE	LA31985	31/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
KINESYS ARRAY 485 8 WAY DATA SPLITTER	LA37279	31/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
KINESYS ARRAY 485 8 WAY DATA SPLITTER	LA37276	31/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA39067	26/01/17	P	S	0.03 P	>300 P	S	S	S	S	S
LIGHTWARE MX 8X8 MATRIX DVI-D PRO SWITCHER	LA34590	31/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
LIGHTWARE MX 8X8 MATRIX DVI-D PRO SWITCHER	LA39178	26/01/17	P	S	0.07 P	>300 P	S	S	S	S	S
LIGHTWARE MX 8X8 MATRIX DVI-D PRO SWITCHER	LA39179	31/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
MARTIN P3 POWERPORT 1500	LA39439	31/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
MARTIN P3 POWERPORT 1500	LA39441	31/01/17	P	S	0.03 P	>300 P	S	S	S	S	S
MTP FIBRE MULTICORE 150M	LA39487	02/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MTP FIBRE MULTICORE 150M	LA39469	02/02/17	P	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA24734	23/01/17	P	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA17756	23/01/17	P	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA17752	23/01/17	P	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA17751	23/01/17	P	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA26934	23/01/17	P	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA25880	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30376	02/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30384	02/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35096	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30386	08/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30382	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30383	08/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35074	02/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30385	02/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA26092	08/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA26095	02/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30378	02/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35286	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35289	17/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35288	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35225	15/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35295	15/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35294	15/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30380	02/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30375	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA26341	08/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA26094	02/02/17	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35266	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA32904	20/01/17	S	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA35103	27/01/17	P	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA35132	25/01/17	P	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA35102	27/01/17	P	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA32900	27/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34857	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34936	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34935	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34858	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34940	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34939	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34856	23/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON 2 WAY SPLITTER	LA34937	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34859	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34855	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34938	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38263	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38261	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38265	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38266	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38262	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38268	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38270	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38267	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38264	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34770	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34769	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34763	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34762	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34765	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34766	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34764	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34767	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34774	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34773	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34771	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34775	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34772	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34760	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34768	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34761	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34759	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34758	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32623	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32624	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32630	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32631	27/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32625	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32628	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32621	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32622	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32632	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32417	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32418	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32419	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32420	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32415	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32416	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32421	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32422	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32629	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35588	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35591	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35584	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35585	12/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE TRS 10FT	LA35590	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35583	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35592	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35589	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35587	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32620	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32619	01/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32618	27/01/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32617	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32627	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32626	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35586	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA39087	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32404	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32399	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32402	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32401	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32400	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32407	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32406	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32403	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32412	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32409	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32414	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32413	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32410	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32405	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32408	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32411	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35629	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35628	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35625	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35627	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35626	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35630	12/01/17	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39692	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39931	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39689	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39687	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39919	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39688	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39694	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39691	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39690	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39693	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39937	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39940	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39941	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39934	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39935	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39936	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39933	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39923	16/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39924	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39928	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39927	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39938	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39939	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39925	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39942	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39945	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39944	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39943	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39949	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39946	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39953	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39957	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39952	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39951	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39954	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39955	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39956	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39959	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39958	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39696	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39695	03/03/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39916	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39917	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39918	03/03/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39921	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39920	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39915	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39929	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39950	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39930	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39932	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39922	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39948	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39947	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39681	16/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39678	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39684	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39682	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39685	03/03/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39677	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA35993	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA35981	03/03/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39686	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39680	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39679	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA39683	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA33149	03/03/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA30647	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA30644	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA33171	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA33172	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 5FT	LA33169	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 10FT	LA30657	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 15FT	LA25275	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 20FT	LA33060	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 20FT	LA33058	23/01/17	P	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA35992	03/03/17	P	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA35986	16/02/17	P	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA30424	16/02/17	P	S	S	S	S	S	S	S	S
POWERLOCK - 125A 3PH ADAPTOR 3M	LA30796	04/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK - 125A 3PH ADAPTOR 3M	LA32471	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK - 125A 3PH ADAPTOR 3M	LA22671	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK - 125A 3PH ADAPTOR 3M	LA26974	10/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA22245	05/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA31372	05/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA22246	10/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA21431	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA22247	03/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA22243	25/01/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33466	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA34139	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA34138	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33468	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33469	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33467	18/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERLOCK LINK E 1.5M	LA34140	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38831	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38830	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38834	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38835	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33465	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38833	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38832	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33447	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38809	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38808	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38807	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38810	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38806	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38811	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA34142	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA34143	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA34141	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33449	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33445	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33448	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33446	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA34145	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA34146	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33454	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33453	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA34144	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38812	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38817	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38816	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38815	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38813	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38814	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33450	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33452	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33451	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33457	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33458	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33459	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA34136	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38823	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38820	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38818	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38819	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA34135	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38822	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33455	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33456	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA34137	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38821	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38824	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33460	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38828	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38827	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33461	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38829	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38826	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38825	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33464	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA34134	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA34132	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33463	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33462	18/01/17	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA34133	18/01/17	S	S	S	S	S	S	S	S	S
QUAD FIBRE MULTICORE 150M	LA38942	02/02/17	P	S	S	S	S	S	S	S	S
QUAD FIBRE MULTICORE 150M	LA39486	03/01/17	S	S	S	S	S	S	S	S	S
QUAD FIBRE MULTICORE 150M	LA36056	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15625	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15630	19/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SHUKO - 16A 1PH ADAPTOR	LA15592	03/01/17	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15587	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15595	19/01/17	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15599	03/01/17	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17643	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17487	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17485	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA35127	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA35126	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17486	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17605	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17642	19/01/17	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17484	13/02/17	P	S	S	S	S	S	S	S	S
SHUKO - IEC EURO ADAPTOR	LA26059	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - IEC EURO ADAPTOR	LA26005	02/02/17	P	S	S	S	S	S	S	S	S
SHUKO - IEC EURO ADAPTOR	LA24491	02/02/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN IN	LA25917	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN IN	LA25640	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN IN	LA35144	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30782	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30634	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30777	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30779	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30633	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30162	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30160	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA22675	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30161	31/01/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20277	02/02/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20283	02/02/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20278	02/02/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20276	02/02/17	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20280	02/02/17	P	S	S	S	S	S	S	S	S
SOCA- 3 WAY 415V/110V MOTOR FAN OUT 60FT	LA20273	01/02/17	P	S	S	S	S	S	S	S	S
SOCA- 3 WAY 415V/110V MOTOR FAN OUT 60FT	LA20275	31/01/17	P	S	S	S	S	S	S	S	S
SOCA- 3 WAY 415V/110V MOTOR FAN OUT 60FT	LA20274	31/01/17	P	S	S	S	S	S	S	S	S
SOCAPLEX - 6 X 16A 1PH STAGE/TRUSS BOX	LA34899	02/02/17	P	S	S	S	S	S	S	S	S
SOCAPLEX - 6 X 16A 1PH STAGE/TRUSS BOX	LA34900	02/02/17	P	S	S	S	S	S	S	S	S
SOCAPLEX - 6 X 16A 1PH STAGE/TRUSS BOX	LA34897	02/02/17	P	S	S	S	S	S	S	S	S
SOCAPLEX - 6 X 16A 1PH STAGE/TRUSS BOX	LA34898	02/02/17	P	S	S	S	S	S	S	S	S
SOCAPLEX (F) - 3 WAY 415V/110V MOTOR FAN IN	LA32870	31/01/17	P	S	S	S	S	S	S	S	S
SOCAPLEX (F) - 3 WAY 415V/110V MOTOR FAN IN	LA32871	31/01/17	P	S	S	S	S	S	S	S	S
SOCAPLEX (F) - 3 WAY 415V/110V MOTOR FAN IN	LA32868	31/01/17	P	S	S	S	S	S	S	S	S
SOCAPLEX (F) - 3 WAY 415V/110V MOTOR FAN IN	LA32869	31/01/17	P	S	S	S	S	S	S	S	S
SOCAPLEX (F) - 6 X 16A 1PH	LA22323	01/02/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA21133	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA17462	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA22324	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA17466	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA17463	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA17467	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA20190	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA20187	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA32276	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA32279	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA21945	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA32277	06/01/17	S	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA32278	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA21128	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA21131	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA32275	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA32280	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA21944	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA22322	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (F) - 6 X 16A 1PH	LA22321	01/02/17	P	S	S	S	S	S	S	S	S
FAN IN											
SOCAPEX (M) - 3 WAY	LA32838	06/01/17	S	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32588	31/01/17	P	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32840	06/01/17	S	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32587	31/01/17	P	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32848	06/01/17	S	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32849	31/01/17	P	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32583	06/01/17	S	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32584	06/01/17	S	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32586	04/01/17	S	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32841	04/01/17	S	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32590	31/01/17	P	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32843	31/01/17	P	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32844	02/02/17	P	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32589	06/01/17	S	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32847	02/02/17	P	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 3 WAY	LA32846	31/01/17	P	S	S	S	S	S	S	S	S
415V/110V MOTOR FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA36232	06/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26869	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32573	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26873	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01843	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA36231	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26870	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01979	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26871	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26914	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26917	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26916	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26913	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40182	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26877	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26876	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32576	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32521	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26878	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26875	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26927	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32578	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32579	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40179	19/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32577	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32574	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32575	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40171	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22644	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40168	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40172	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40162	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40166	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22645	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40158	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40169	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40175	19/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40157	26/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40161	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40159	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40176	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40173	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40174	19/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40177	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA36042	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA37180	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40165	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40181	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01977	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26874	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA37179	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01844	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22648	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22651	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22652	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40167	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22650	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22647	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40163	19/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22649	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22646	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32272	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32270	19/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32265	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32269	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24955	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17811	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32274	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32273	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24963	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24959	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24956	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24966	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24961	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24965	26/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24964	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA04516	27/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24962	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17812	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17825	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17826	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17815	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17817	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17879	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17274	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA33313	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17124	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17813	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA34565	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17819	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35092	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA34568	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17895	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17818	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17821	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA17824	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24973	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA30533	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01661	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA30536	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA30531	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01660	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01416	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01748	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01841	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA30535	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26879	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26884	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32519	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA26886	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA30527	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA30528	26/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA30529	23/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA30530	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01612	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24969	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24968	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA01659	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA25116	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24975	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24974	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24967	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA24970	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32685	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32692	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32689	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32694	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32693	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32690	27/02/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32686	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32687	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA32691	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35913	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35108	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21777	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA20361	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21934	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35099	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA20359	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35553	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21778	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35556	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35911	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35554	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21783	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35131	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21947	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21932	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35545	26/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35903	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA20439	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22911	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22977	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21933	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35550	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA20356	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35551	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35908	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21774	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21776	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35902	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35542	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21772	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35910	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35540	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35549	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35897	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35539	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35552	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35896	27/02/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35546	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40185	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40186	27/02/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40180	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA40183	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35544	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21936	27/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA22643	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21782	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35894	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35538	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35901	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21779	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21780	25/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35904	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21935	27/01/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35146	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35895	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA35543	06/01/17	S	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX (M) - 6 X 16A 1PH	LA21781	26/01/17	P	S	S	S	S	S	S	S	S
FAN OUT											
SOCAPEX 1.5MM CABLE 10M	LA36216	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA34695	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36079	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36076	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36080	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36077	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36078	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32360	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36177	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA34557	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32361	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA31994	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA30195	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36151	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA30852	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32038	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA20110	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA17148	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32308	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA26076	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30946	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30854	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30853	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA21785	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30783	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA21788	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA32792	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA36084	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30308	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA21904	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA32042	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA32793	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30891	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30894	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA34547	04/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30890	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA17624	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21145	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21144	04/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36171	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21142	04/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21301	04/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30933	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30864	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30865	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30862	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21302	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30889	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30931	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30932	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30859	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36169	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36060	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA31351	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36155	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36063	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA31582	04/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36061	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36062	04/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20546	05/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 1.5MM CABLE 2.5M	LA20544	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20540	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA24291	04/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36111	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20545	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA31997	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA32033	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA32035	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA22759	04/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36170	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA40326	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA21150	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA31612	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA24712	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA22720	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA36185	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA31053	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA36025	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA37099	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA36086	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA21153	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA17283	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA22879	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 30M	LA36101	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 30M	LA34560	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 30M	LA17074	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 30M	LA32064	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 40M	LA36196	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 40M	LA01996	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30942	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30941	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20429	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA22063	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20556	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20555	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36145	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36173	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20112	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20562	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA17272	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36148	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA17282	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30765	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36131	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA34696	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36172	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA26605	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36141	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36142	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36070	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30851	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20427	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30850	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36073	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30190	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30305	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36207	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36067	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36069	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30888	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20054	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30192	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30193	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36143	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA01276	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30194	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA21540	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30855	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30197	19/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 1.5MM CABLE 5M	LA36072	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA22758	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30948	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA21900	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32497	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32359	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32040	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32753	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32757	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32645	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32646	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36215	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32643	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32648	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32754	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32493	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32492	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32496	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32498	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32495	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32791	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32758	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32494	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32491	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36198	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36182	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36181	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36180	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30465	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30469	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30470	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30466	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30462	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25585	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25584	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25592	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25586	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25583	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21675	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36179	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36034	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21644	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30467	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21709	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36132	01/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32875	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32874	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21714	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21716	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21717	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21711	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21710	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36083	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36082	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30468	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32925	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36153	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32876	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA22523	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36152	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA22522	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30857	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32304	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32227	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32226	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32533	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32228	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32232	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32233	19/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 10M	LA21802	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21919	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32225	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21921	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21922	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21923	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32231	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25589	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25590	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32537	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25591	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32538	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25588	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32542	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32536	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21920	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32535	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32540	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32239	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32857	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32856	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32858	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32241	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32862	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32859	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32861	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32242	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32247	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32007	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32006	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33025	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30485	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32860	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33018	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33016	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33017	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32301	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32074	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33023	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33024	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33021	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33019	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33022	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32249	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32055	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32877	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32878	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32248	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32924	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32041	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32923	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33015	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33026	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22433	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22429	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22436	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22437	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33013	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33009	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33008	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33012	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36021	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32603	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32764	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32759	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32762	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32756	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32761	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33010	06/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 15M	LA22440	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33011	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32760	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32763	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32549	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36001	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36022	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32547	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30486	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32543	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32544	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32548	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32550	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32552	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32545	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32604	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36184	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33027	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30484	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30947	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA30936	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA32886	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA30935	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36064	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA30930	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36200	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30456	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36193	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30978	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30975	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30457	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30454	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30455	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32558	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32555	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32559	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32561	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32554	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30972	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30973	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32557	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32556	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32560	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36220	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36221	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30453	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30452	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30959	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36219	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36222	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36023	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36024	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36191	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32880	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32881	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32884	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36099	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32883	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36098	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32879	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36097	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36100	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22635	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22640	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21728	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32863	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21724	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22642	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21722	16/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 20M	LA22636	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22639	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32865	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22641	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32864	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30955	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30977	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30976	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36090	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36091	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30459	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36189	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36187	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30460	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32932	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32931	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32992	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32990	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32991	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30969	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36094	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32922	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36093	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36092	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36026	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36088	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30956	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36032	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32340	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30958	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32357	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32075	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33004	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21891	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32766	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32219	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32222	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32220	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA31654	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA31984	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21912	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33000	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32768	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32057	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32767	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32769	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32993	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32996	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32995	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30960	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33002	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32043	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33003	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32998	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32994	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30966	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33006	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21890	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33061	30/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32765	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21915	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32224	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32223	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32213	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30967	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36031	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32553	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30965	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32208	16/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 20M	LA32209	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30961	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32205	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32207	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32212	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32206	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32215	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32214	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32217	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33007	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33001	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30971	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32221	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32216	16/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32218	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32960	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32958	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32959	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32962	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32654	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32963	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32966	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32956	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32953	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32950	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32957	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32983	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32955	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32954	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32965	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32964	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32967	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32951	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32949	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32952	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA31583	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21730	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22653	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21731	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36003	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21733	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36107	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21735	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA24312	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21739	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21734	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36005	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32885	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22658	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22659	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22656	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36105	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22660	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32653	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32062	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36004	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22526	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32650	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22527	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32984	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30447	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30448	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA24981	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA24978	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30450	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21796	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA24984	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30444	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30992	17/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 30M	LA30982	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30980	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30983	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA24983	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA24977	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36106	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30449	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30987	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30788	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21805	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21798	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30984	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30789	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30988	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30856	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36027	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36103	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30985	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36227	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30790	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30786	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30981	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32980	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32975	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32974	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32979	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32978	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32942	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32938	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32948	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32941	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32969	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32986	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32651	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32981	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32982	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32987	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32973	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32968	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32652	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32972	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32944	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32946	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32945	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32947	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32356	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32943	06/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32939	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36104	17/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32933	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32934	18/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 40M	LA36108	09/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 40M	LA38490	09/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32001	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA30993	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32005	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32004	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32003	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32002	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA30994	23/01/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30951	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30952	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30949	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30950	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30954	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32532	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30940	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36202	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32531	05/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 5M	LA30943	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36176	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30938	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30939	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32529	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32525	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32748	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32528	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32530	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36203	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32526	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36201	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36175	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36013	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36017	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36014	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36015	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36019	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21927	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36018	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA20203	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36144	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21640	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36074	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36037	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21706	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36036	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21700	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21701	09/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32747	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32850	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32853	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32854	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32852	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25473	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32851	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25472	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32873	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30472	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25479	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30479	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30476	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30481	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30480	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25476	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36205	20/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36206	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32639	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36204	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32750	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32749	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32752	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32638	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32071	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32072	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32362	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32052	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32642	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32641	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32037	05/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA37805	08/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA37804	08/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA37802	08/02/17	P	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA16633	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA37803	19/01/17	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX SPLITTER RUBBER BOX RB	LA16999	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA26977	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA26976	19/01/17	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA25181	19/01/17	S	S	S	S	S	S	S	S	S
STRAND 100 PLUS SERIES 12/24 CONSOLE	LA34353	31/01/17	P	S	S	>300 P	S	S	S	S	S
STRAND 100 PLUS SERIES 12/24 PSU	LA34354	31/01/17	P	S	S	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX S-1 TRANSMITTER	LA37332	25/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S

Total Appliances: 4,038

LITE ALT - BLACKBURN

1000W HALOGON FLOOD WORK LIGHT	LA20022	06/01/17	P	S	0.06 P	>300 P	1.01 P	<0.10 P	S	S	S
1000W HALOGON FLOOD WORK LIGHT	LA20023	06/01/17	P	S	0.07 P	>300 P	1.01 P	<0.10 P	S	S	S
1000W HALOGON FLOOD WORK LIGHT	LA20021	06/01/17	P	S	0.07 P	>300 P	1.00 P	<0.10 P	S	S	S
2K MOLE RICHARDSON MOLEBEAM PROJECTOR	LA24685	18/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
2K MOLE RICHARDSON MOLEBEAM PROJECTOR	LA24686	18/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
2K MOLE RICHARDSON MOLEBEAM PROJECTOR	LA24682	18/01/17	P	S	0.06 P	>300 P	2.10 P	<0.10 P	S	S	S
2K MOLE RICHARDSON MOLEBEAM PROJECTOR	LA24684	18/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
2K MOLE RICHARDSON MOLEBEAM PROJECTOR	LA24681	18/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
2K MOLE RICHARDSON MOLEBEAM PROJECTOR	LA24680	18/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31757	18/01/17	P	S	0.04 P	>300 P	1.01 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31758	18/01/17	P	S	0.09 P	>300 P	1.05 P	0.44 P	S	S	S
3KW MOLE PAR	LA31748	18/01/17	P	S	0.07 P	>300 P	1.01 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31754	18/01/17	P	S	0.07 P	>300 P	1.04 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31753	18/01/17	P	S	0.07 P	>300 P	1.03 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31752	18/01/17	P	S	0.04 P	>300 P	1.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31751	18/01/17	P	S	0.04 P	>300 P	1.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31750	18/01/17	P	S	0.06 P	>300 P	1.04 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31749	18/01/17	P	S	0.05 P	>300 P	1.03 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31742	18/01/17	P	S	0.06 P	>300 P	1.04 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31756	18/01/17	P	S	0.04 P	>300 P	1.02 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31741	18/01/17	P	S	0.05 P	>300 P	1.15 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31762	18/01/17	P	S	0.04 P	>300 P	1.02 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31764	18/01/17	P	S	0.05 P	>300 P	1.06 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31759	18/01/17	P	S	0.04 P	>300 P	1.02 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31761	18/01/17	P	S	0.04 P	>300 P	1.02 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31760	18/01/17	P	S	0.04 P	>300 P	1.06 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31763	18/01/17	P	S	0.06 P	>300 P	1.04 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31743	18/01/17	P	S	0.04 P	>300 P	1.07 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31744	18/01/17	P	S	0.06 P	>300 P	1.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31745	18/01/17	P	S	0.04 P	>300 P	1.07 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31755	18/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31746	18/01/17	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31747	18/01/17	P	S	0.05 P	>300 P	1.05 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26738	06/01/17	P	S	0.05 P	>300 P	0.51 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26701	06/01/17	P	S	0.05 P	>300 P	0.42 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26737	06/01/17	P	S	0.04 P	>300 P	0.40 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26888	06/01/17	P	S	0.06 P	>300 P	0.43 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26887	06/01/17	P	S	0.07 P	>300 P	0.44 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26882	06/01/17	P	S	0.05 P	>300 P	0.43 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26881	06/01/17	P	S	0.05 P	>300 P	0.43 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
500W HALOGEN FLOOD WORK LIGHT	LA26880	06/01/17	P	S	0.05 P	>300 P	0.54 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26702	06/01/17	P	S	0.05 P	>300 P	0.39 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26699	06/01/17	P	S	0.06 P	>300 P	0.40 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26883	06/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26838	06/01/17	P	S	0.05 P	>300 P	0.44 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26837	06/01/17	P	S	0.05 P	>300 P	0.49 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02197	10/01/17	P	S	0.06 P	>300 P	2.16 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02198	09/01/17	P	S	0.06 P	>300 P	2.66 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02193	09/01/17	P	S	0.05 P	>300 P	2.43 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02190	10/01/17	P	S	0.05 P	>300 P	2.38 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02196	10/01/17	P	S	0.05 P	>300 P	2.37 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02195	09/01/17	P	S	0.06 P	>300 P	2.40 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02199	10/01/17	P	S	0.05 P	>300 P	2.36 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02194	09/01/17	P	S	0.07 P	>300 P	2.51 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02191	10/01/17	P	S	0.05 P	>300 P	2.36 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02192	09/01/17	P	S	0.07 P	>300 P	2.43 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24137	06/01/17	P	S	0.04 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24134	06/01/17	P	S	0.02 P	>300 P	0.85 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24130	06/01/17	P	S	0.03 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24139	06/01/17	P	S	0.03 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24131	06/01/17	P	S	0.03 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24136	06/01/17	P	S	0.03 P	>300 P	0.77 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24135	06/01/17	P	S	0.03 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25628	06/01/17	P	S	0.06 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25629	06/01/17	P	S	0.05 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25633	06/01/17	P	S	0.05 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25630	06/01/17	P	S	0.05 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25631	06/01/17	P	S	0.05 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24140	06/01/17	P	S	0.04 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25632	06/01/17	P	S	0.06 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24138	06/01/17	P	S	0.04 P	>300 P	0.78 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24129	06/01/17	P	S	0.05 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24133	06/01/17	P	S	0.03 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24132	06/01/17	P	S	0.03 P	>300 P	0.84 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PHOTOFLOOD C/W BARNDOOR											
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOOR	LA25973	06/01/17	P	S	0.04 P	>300 P	0.55 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOOR	LA25974	06/01/17	P	S	0.05 P	>300 P	0.83 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34692	06/01/17	P	S	0.04 P	>300 P	0.75 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34239	06/01/17	P	S	0.06 P	>300 P	0.48 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34895	06/01/17	P	S	0.05 P	>300 P	0.77 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34237	06/01/17	P	S	0.04 P	>300 P	0.85 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34238	06/01/17	P	S	0.05 P	>300 P	0.81 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34894	06/01/17	P	S	0.05 P	>300 P	0.83 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34892	06/01/17	P	S	0.03 P	>300 P	0.75 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34893	06/01/17	P	S	0.04 P	>300 P	0.75 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34890	06/01/17	P	S	0.05 P	>300 P	0.76 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34889	06/01/17	P	S	0.05 P	>300 P	0.83 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34891	06/01/17	P	S	0.04 P	>300 P	0.81 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34690	06/01/17	P	S	0.05 P	>300 P	0.83 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34896	06/01/17	P	S	0.03 P	>300 P	0.78 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34691	06/01/17	P	S	0.04 P	>300 P	0.53 P	<0.10 P	S	S	S
ANYTRONICS D1225 12 CHANNEL DIMMER	LA24070	12/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS D1225 12 CHANNEL DIMMER	LA25661	12/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS INLINE 5KW DIMMER DMX 32A 1PH	LA20810	12/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K090 S192 10A 6 WAY SWITCH PACK	LA24071	12/01/17	P	S	0.03 P	>300 P	0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA25036	12/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA25035	12/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA26087	12/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA26088	12/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37627	12/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37625	12/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37626	12/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37628	12/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
ARTISTIC LICENCE ETHER-LYNX ART NET NODE	LA25345	11/01/17	P	S	0.08 P	S	<0.05 P	0.24 P	S	S	S
ASL BS181 TALKBACK PSU	LA17303	12/01/17	P	S	0.10 P	>300 P	<0.05 P	0.37 P	S	S	S
ASL BS181 TALKBACK PSU	LA34240	12/01/17	P	S	0.16 P	>300 P	<0.05 P	0.38 P	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA34751	11/01/17	P	S	0.12 P	>300 P	<0.05 P	0.43 P	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA25416	17/01/17	P	S	0.11 P	>300 P	<0.05 P	0.48 P	S	S	S
ASL PS285 TALKBACK AUX PSU	LA25359	11/01/17	P	S	0.16 P	>300 P	<0.05 P	0.42 P	S	S	S
AVO ART 2000 POWER CUBE	LA34417	24/01/17	P	S	0.02 P	>300 P	S	S	S	S	S
AVO ART 2000 POWER CUBE	LA34348	24/01/17	P	S	0.03 P	>300 P	S	S	S	S	S
AVO ART2000 T2 FRAME C/W POWERLOCK	LA38228	24/01/17	S	S	0.04 P	>300 P	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
AVO ART2000 T2 FRAME C/W POWERLOCK	LA26988	24/01/17	S	S	0.05 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA21259	23/01/17	P	S	0.04 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA21260	23/01/17	P	S	0.04 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA22987	24/01/17	P	S	0.04 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA31873	23/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA21703	23/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA21857	17/01/17	P	S	0.04 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA34699	24/01/17	P	S	0.04 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA31089	23/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA22761	24/01/17	P	S	0.04 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA31088	23/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA20318	23/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA34809	23/01/17	P	S	0.04 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA34810	23/01/17	P	S	0.04 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA34912	23/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA31570	23/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA31569	24/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31845	11/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA22487	11/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA24718	11/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31846	03/01/17	P	S	0.06 P	>300 P	<0.05 P	0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31844	11/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA24751	11/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA24753	11/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA24675	11/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA24752	11/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31847	03/01/17	P	S	0.06 P	>300 P	<0.05 P	0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA22486	11/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA22458	11/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31965	11/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA22459	11/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA26889	11/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA21520	11/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA21519	03/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31215	11/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA22489	11/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA22488	11/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31992	11/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVOLITES TIGER TOUCH PRO CONSOLE	LA26978	12/01/17	P	S	0.07 P	S	<0.05 P	0.44 P	S	S	S
AYRTON MAGIC PANEL 602	LA37113	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34654	17/01/17	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
AYRTON MAGIC PANEL 602	LA34655	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
AYRTON MAGIC PANEL 602	LA34650	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34651	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34653	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
AYRTON MAGIC PANEL 602	LA34657	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34656	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34652	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34659	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
AYRTON MAGIC PANEL 602	LA34658	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34660	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34661	17/01/17	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGICBLADE-R	LA37708	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.18 P	S	S	S
AYRTON MAGICBLADE-R	LA37368	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICBLADE-R	LA37370	04/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
AYRTON MAGICBLADE-R	LA37371	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICBLADE-R	LA37367	04/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
AYRTON MAGICBLADE-R	LA37369	04/01/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICBLADE-R	LA37366	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICBLADE-R	LA37955	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICBLADE-R	LA37959	04/01/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICBLADE-R	LA37956	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICBLADE-R	LA37954	05/01/17	P	S	0.04 P	>300 P	<0.05 P	0.12 P	S	S	S
AYRTON MAGICBLADE-R	LA37958	05/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICBLADE-R	LA37957	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.19 P	S	S	S
AYRTON MAGICDOT-R	LA37881	13/01/17	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37884	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37886	13/01/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37887	13/01/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37860	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37852	13/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37853	13/01/17	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37858	13/01/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37869	13/01/17	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37896	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37878	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37865	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37863	13/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38776	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38777	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38760	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38773	13/01/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38761	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38757	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38758	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38778	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38769	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38775	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38759	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38770	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38774	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R LUMINAIRE	LA38762	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CCT 500W CYC UNIT	LA04641	09/01/17	P	S	0.05 P	>300 P	0.41 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17561	09/01/17	P	S	0.04 P	>300 P	0.49 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17559	09/01/17	P	S	0.06 P	>300 P	0.50 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17558	09/01/17	P	S	0.06 P	>300 P	0.42 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17554	09/01/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17555	09/01/17	P	S	0.05 P	>300 P	0.40 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17556	09/01/17	P	S	0.04 P	160.70 P	0.50 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17560	09/01/17	P	S	0.07 P	>300 P	0.42 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17557	09/01/17	P	S	0.06 P	>300 P	0.51 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31660	09/01/17	P	S	0.03 P	>300 P	0.68 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31852	09/01/17	P	S	0.02 P	>300 P	0.67 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA24068	09/01/17	P	S	0.03 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31853	09/01/17	P	S	0.03 P	>300 P	0.67 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31661	09/01/17	P	S	0.04 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA24460	09/01/17	P	S	0.05 P	>300 P	0.68 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA26915	09/01/17	P	S	0.03 P	>300 P	0.68 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31662	09/01/17	P	S	0.01 P	>300 P	0.68 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA26030	09/01/17	P	S	0.03 P	>300 P	0.68 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22830	09/01/17	P	S	0.05 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22832	09/01/17	P	S	0.05 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22831	09/01/17	P	S	0.08 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22828	09/01/17	P	S	0.03 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22829	09/01/17	P	S	0.04 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22823	09/01/17	P	S	0.07 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22824	09/01/17	P	S	0.04 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22827	09/01/17	P	S	0.04 P	>300 P	0.67 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22821	09/01/17	P	S	0.05 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22822	09/01/17	P	S	0.05 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22826	09/01/17	P	S	0.05 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22825	09/01/17	P	S	0.04 P	>300 P	0.67 P	<0.10 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26133	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26134	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26132	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26129	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26128	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26131	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26126	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA32354	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA32353	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26127	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26130	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26125	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26124	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA34928	10/01/17	P	S	0.02 P	>300 P	<0.05 P	0.49 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA26123	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA24715	12/01/17	P	S	0.06 P	>300 P	<0.05 P	1.39 P	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26856	12/01/17	P	S	0.06 P	>300 P	<0.05 P	1.46 P	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA24146	12/01/17	P	S	0.06 P	>300 P	<0.05 P	1.51 P	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26046	12/01/17	P	S	0.09 P	>300 P	<0.05 P	1.38 P	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26398	12/01/17	P	S	0.07 P	>300 P	<0.05 P	1.44 P	S	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA34920	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17585	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17589	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA25016	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA25014	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17899	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA34918	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA25015	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA34921	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA34919	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA25013	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17588	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17586	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17587	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA25012	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17590	16/01/17	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34314	25/01/17	P	S	0.04 P	>300 P	0.12 P	2.16 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34721	25/01/17	P	S	0.05 P	>300 P	0.12 P	1.98 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34182	25/01/17	P	S	0.05 P	>300 P	0.11 P	2.06 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34196	25/01/17	P	S	0.04 P	>300 P	0.11 P	2.03 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34183	25/01/17	P	S	0.05 P	>300 P	0.11 P	2.05 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34184	25/01/17	P	S	0.05 P	>300 P	0.11 P	2.07 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34187	25/01/17	P	S	0.05 P	>300 P	0.11 P	2.01 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34185	25/01/17	P	S	0.05 P	>300 P	0.11 P	1.99 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34186	25/01/17	P	S	0.05 P	>300 P	0.10 P	2.05 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34195	25/01/17	P	S	0.05 P	>300 P	0.11 P	2.00 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34188	25/01/17	P	S	0.05 P	>300 P	0.11 P	1.95 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34192	26/01/17	P	S	0.04 P	>300 P	0.12 P	2.04 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34197	25/01/17	P	S	0.05 P	>300 P	0.12 P	2.02 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34194	25/01/17	P	S	0.05 P	>300 P	0.11 P	2.03 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34193	25/01/17	P	S	0.05 P	>300 P	0.12 P	2.06 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34189	25/01/17	P	S	0.05 P	>300 P	0.11 P	2.07 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34308	25/01/17	P	S	0.05 P	>300 P	0.11 P	2.13 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34306	25/01/17	P	S	0.04 P	>300 P	0.09 P	2.23 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34312	25/01/17	P	S	0.04 P	>300 P	0.12 P	2.17 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34313	25/01/17	P	S	0.04 P	>300 P	0.12 P	2.16 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34307	25/01/17	P	S	0.04 P	>300 P	0.12 P	2.15 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34310	25/01/17	P	S	0.04 P	>300 P	0.07 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CHROMLECH ELIDY BIG PSU PSX9	LA34309	26/01/17	P	S	0.05 P	>300 P	0.11 P	2.20 P	S	S	S
CITY THEATRICAL SPDS 375TR 6-WAY IW BLAST SUPPLY	LA31112	20/01/17	P	S	0.08 P	60.46 P	<0.05 P	0.46 P	S	S	S
CITY THEATRICAL SPDS 375TR 6-WAY IW BLAST SUPPLY	LA31116	20/01/17	P	S	0.08 P	126.50 P	<0.05 P	0.46 P	S	S	S
CITY THEATRICAL SPDS 375TR 6-WAY IW BLAST SUPPLY	LA31131	20/01/17	P	S	0.07 P	50.37 P	<0.05 P	0.45 P	S	S	S
CLAY PAKY GLOW UP 6 WAY FLIGHT CASE	LA34498	10/01/17	P	S	0.05 P	>300 P	0.05 P	0.73 P	S	S	S
CLAY PAKY GLOW UP 6 WAY FLIGHT CASE	LA34497	10/01/17	P	S	0.08 P	>300 P	0.05 P	0.74 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34459	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.34 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34455	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.34 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34457	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.32 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34460	10/01/17	P	S	0.08 P	294.00 P	<0.05 P	0.35 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34465	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.34 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34464	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.33 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34461	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.34 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34454	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.33 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34463	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.33 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34456	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.32 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34462	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.33 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34945	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34576	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34575	12/01/17	P	S	0.04 P	>300 P	0.10 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34947	12/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37682	16/01/17	P	S	0.04 P	>300 P	0.11 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37677	12/01/17	P	S	0.03 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37687	03/01/17	P	S	0.02 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31605	12/01/17	P	S	0.05 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31602	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31601	11/01/17	P	S	0.06 P	>300 P	0.10 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31560	16/01/17	P	S	0.04 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31561	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37684	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37685	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31603	11/01/17	P	S	0.05 P	>300 P	0.10 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31600	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.54 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31599	23/12/16	P	S	0.02 P	>300 P	0.10 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31597	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31596	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31607	12/01/17	P	S	0.04 P	>300 P	0.09 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31606	12/01/17	P	S	0.04 P	>300 P	0.09 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31598	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37686	11/01/17	P	S	0.05 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31604	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34724	12/01/17	P	S	0.03 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34946	11/01/17	P	S	0.05 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37678	23/12/16	P	S	0.04 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37679	23/12/16	P	S	0.03 P	>300 P	0.11 P	0.51 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CLAY PAKY SHARPY SPOT	LA37676	23/12/16	P	S	0.04 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38227	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34577	03/01/17	P	S	0.02 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34578	11/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31555	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37691	11/01/17	P	S	0.06 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37688	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31558	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37690	13/01/17	P	S	0.04 P	>300 P	0.10 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31557	16/01/17	P	S	0.04 P	>300 P	0.10 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31554	16/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37689	23/12/16	P	S	0.02 P	>300 P	0.11 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31556	23/12/16	P	S	0.02 P	>300 P	0.11 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37308	12/01/17	P	S	0.04 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37303	12/01/17	P	S	0.04 P	>300 P	0.11 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38164	16/01/17	P	S	0.04 P	>300 P	0.11 P	0.32 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37306	12/01/17	P	S	0.04 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38163	12/01/17	P	S	0.03 P	>300 P	0.10 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37309	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38170	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38162	12/01/17	P	S	0.03 P	>300 P	0.10 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37305	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37302	23/12/16	P	S	0.03 P	>300 P	0.11 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38165	11/01/17	P	S	0.05 P	>300 P	0.11 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38169	12/01/17	P	S	0.05 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37307	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37297	12/01/17	P	S	0.03 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37300	13/01/17	P	S	0.04 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37299	12/01/17	P	S	0.04 P	>300 P	0.11 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37439	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37465	16/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37298	12/01/17	P	S	0.04 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38168	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37296	12/01/17	P	S	0.03 P	>300 P	0.11 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37295	12/01/17	P	S	0.03 P	>300 P	0.11 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37294	13/01/17	P	S	0.05 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37293	11/01/17	P	S	0.04 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38167	16/01/17	P	S	0.03 P	>300 P	0.11 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37304	03/01/17	P	S	0.02 P	>300 P	0.11 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37683	12/01/17	P	S	0.05 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34579	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38158	11/01/17	P	S	0.06 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38151	11/01/17	P	S	0.05 P	>300 P	0.10 P	0.56 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34942	11/01/17	P	S	0.05 P	>300 P	0.10 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34580	12/01/17	P	S	0.04 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38161	12/01/17	P	S	0.04 P	>300 P	0.10 P	0.55 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38160	03/01/17	P	S	0.02 P	>300 P	0.10 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38159	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38157	11/01/17	P	S	0.06 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38155	11/01/17	P	S	0.03 P	>300 P	0.11 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38156	12/01/17	P	S	0.05 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37311	12/01/17	P	S	0.04 P	>300 P	0.10 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37292	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37291	11/01/17	P	S	0.05 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38153	12/01/17	P	S	0.03 P	>300 P	0.10 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37290	13/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38152	11/01/17	P	S	0.05 P	>300 P	0.10 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37289	11/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38150	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37286	12/01/17	P	S	0.04 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37310	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38154	11/01/17	P	S	0.03 P	>300 P	0.11 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37287	11/01/17	P	S	0.05 P	>300 P	0.11 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38149	12/01/17	P	S	0.03 P	>300 P	0.11 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38140	16/01/17	P	S	0.05 P	>300 P	0.11 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37681	23/12/16	P	S	0.02 P	>300 P	0.11 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34943	23/12/16	P	S	0.03 P	>300 P	0.09 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34944	12/01/17	P	S	0.03 P	>300 P	0.11 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37430	11/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CLAY PAKY SHARPY SPOT	LA37433	16/01/17	P	S	0.03 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37432	03/01/17	P	S	0.02 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37409	11/01/17	P	S	0.05 P	>300 P	0.11 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37412	12/01/17	P	S	0.03 P	>300 P	0.11 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37411	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37680	23/12/16	P	S	0.03 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34581	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37410	11/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37431	23/12/16	P	S	0.02 P	>300 P	0.10 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37428	23/12/16	P	S	0.02 P	>300 P	0.10 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37423	12/01/17	P	S	0.04 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37421	11/01/17	P	S	0.02 P	>300 P	0.11 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37427	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37426	12/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37429	23/12/16	P	S	0.02 P	>300 P	0.11 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37434	12/01/17	P	S	0.04 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37437	12/01/17	P	S	0.03 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37436	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37425	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37424	11/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37435	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37418	12/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38144	12/01/17	P	S	0.04 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38143	11/01/17	P	S	0.03 P	>300 P	0.11 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38148	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38133	16/01/17	P	S	0.05 P	>300 P	0.10 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38136	12/01/17	P	S	0.03 P	>300 P	0.10 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38145	12/01/17	P	S	0.04 P	>300 P	0.11 P	0.54 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38147	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38138	11/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38137	12/01/17	P	S	0.04 P	>300 P	0.10 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38141	11/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38146	12/01/17	P	S	0.05 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38142	23/12/16	P	S	0.02 P	>300 P	0.06 P	0.54 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38139	13/01/17	P	S	0.03 P	>300 P	0.10 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37414	12/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37413	16/01/17	P	S	0.03 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37416	11/01/17	P	S	0.03 P	>300 P	0.10 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37417	12/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37420	03/01/17	P	S	0.02 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37419	12/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37415	11/01/17	P	S	0.03 P	>300 P	0.11 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38132	11/01/17	P	S	0.04 P	>300 P	0.10 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38135	11/01/17	P	S	0.05 P	>300 P	0.10 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38134	23/12/16	P	S	0.05 P	>300 P	0.10 P	0.54 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38166	12/01/17	P	S	0.06 P	>300 P	0.10 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37438	11/01/17	P	S	0.04 P	>300 P	0.11 P	0.50 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA35408	10/01/17	P	S	0.10 P	>300 P	<0.05 P	0.62 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA37966	10/01/17	P	S	0.08 P	>300 P	<0.05 P	0.61 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA35409	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.64 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA37967	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.61 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA39996	11/01/17	P	S	0.10 P	>300 P	<0.05 P	0.61 P	S	S	S
CM4 4 WAY MOTOR CONTROLLER	LA20288	19/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
CM4 4 WAY MOTOR CONTROLLER	LA20289	19/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26402	06/01/17	P	S	0.07 P	>300 P	0.07 P	0.28 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26405	06/01/17	P	S	0.05 P	>300 P	0.05 P	0.28 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26403	06/01/17	P	S	0.08 P	>300 P	0.07 P	0.28 P	S	S	S
COLOUR KINETIC	LA37164	06/01/17	P	S	0.08 P	>300 P	0.08 P	0.27 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COLOURBLAZE 48LED BATTEN V3 (1.2M)											
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26406	06/01/17	P	S	0.07 P	>300 P	0.06 P	0.27 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26409	06/01/17	P	S	0.07 P	>300 P	0.06 P	0.28 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26408	06/01/17	P	S	0.09 P	>300 P	0.06 P	0.27 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26407	06/01/17	P	S	0.05 P	>300 P	0.06 P	0.27 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26404	06/01/17	P	S	0.06 P	>300 P	0.07 P	0.28 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA37165	06/01/17	P	S	0.09 P	>300 P	0.07 P	0.28 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26410	06/01/17	P	S	0.09 P	>300 P	0.07 P	0.27 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31363	06/01/17	P	S	0.09 P	>300 P	0.09 P	0.42 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31360	06/01/17	P	S	0.08 P	>300 P	0.09 P	0.40 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31361	06/01/17	P	S	0.08 P	>300 P	0.10 P	0.41 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31369	06/01/17	P	S	0.08 P	>300 P	0.09 P	0.41 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31365	06/01/17	P	S	0.07 P	>300 P	0.09 P	0.41 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31364	06/01/17	P	S	0.07 P	>300 P	0.09 P	0.41 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31359	06/01/17	P	S	0.06 P	>300 P	0.09 P	0.40 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31366	06/01/17	P	S	0.08 P	>300 P	0.09 P	0.41 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31373	06/01/17	P	S	0.08 P	>300 P	0.09 P	0.41 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31362	06/01/17	P	S	0.07 P	>300 P	0.09 P	0.41 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31368	06/01/17	P	S	0.07 P	>300 P	0.09 P	0.41 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31367	06/01/17	P	S	0.09 P	>300 P	0.09 P	0.42 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA34548	06/01/17	P	S	0.08 P	>300 P	0.10 P	0.41 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34725	13/01/17	P	S	0.03 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34729	13/01/17	P	S	0.03 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34728	13/01/17	P	S	0.02 P	>300 P	1.03 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34730	13/01/17	P	S	0.02 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34452	13/01/17	P	S	0.02 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34727	13/01/17	P	S	0.02 P	>300 P	1.02 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34731	13/01/17	P	S	0.02 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34418	13/01/17	P	S	0.06 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34726	13/01/17	P	S	0.03 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34451	13/01/17	P	S	0.03 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34732	13/01/17	P	S	0.03 P	>300 P	0.99 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34453	13/01/17	P	S	0.04 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34423	13/01/17	P	S	0.04 P	>300 P	1.00 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FILMGEAR 1000W FRESNEL	LA34420	13/01/17	P	S	0.04 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34421	13/01/17	P	S	0.04 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34424	13/01/17	P	S	0.02 P	>300 P	0.99 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34419	13/01/17	P	S	0.04 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34450	13/01/17	P	S	0.05 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34425	13/01/17	P	S	0.02 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34422	13/01/17	P	S	0.03 P	>300 P	0.99 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34733	13/01/17	P	S	0.03 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34734	13/01/17	P	S	0.02 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34736	13/01/17	P	S	0.03 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34735	13/01/17	P	S	0.03 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA37660	17/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38565	17/01/17	P	S	0.03 P	>300 P	2.03 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA37659	17/01/17	P	S	0.05 P	>300 P	2.02 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38566	17/01/17	P	S	0.04 P	>300 P	2.01 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38567	17/01/17	P	S	0.04 P	>300 P	2.03 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA37664	17/01/17	P	S	0.03 P	>300 P	2.02 P	<0.10 P	S	S	S
FURMAN 10A POWER CONDITIONER	LA17383	16/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
FURMAN 10A POWER CONDITIONER	LA17382	17/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
FURMAN 10A POWER CONDITIONER	LA34493	16/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FURMAN 10A POWER CONDITIONER	LA25593	31/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 FULL SIZE CONTROL DESK	LA34614	11/01/17	P	S	0.03 P	S	<0.05 P	0.48 P	S	S	S
GRANDMA 2 FULL SIZE CONTROL DESK	LA34325	11/01/17	S	S	0.03 P	S	<0.05 P	0.41 P	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA34113	11/01/17	P	S	0.03 P	S	<0.05 P	0.48 P	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA38514	11/01/17	P	S	0.04 P	S	<0.05 P	0.43 P	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA38363	10/01/17	P	S	0.04 P	S	<0.05 P	0.33 P	S	S	S
GRANDMA 2 ONPC COMMAND WING	LA31706	16/01/17	P	S	0.07 P	S	<0.05 P	0.40 P	S	S	S
GRANDMA MA 8PORT NODE	LA34755	16/01/17	P	S	0.03 P	S	<0.05 P	0.38 P	S	S	S
GRANDMA MA 8PORT NODE	LA38367	12/01/17	P	S	0.02 P	S	<0.05 P	0.39 P	S	S	S
GRANDMA MA 8PORT NODE	LA34756	16/01/17	P	S	0.04 P	S	<0.05 P	0.39 P	S	S	S
GRANDMA MA 8PORT NODE	LA34583	11/01/17	P	S	0.04 P	S	<0.05 P	0.39 P	S	S	S
GRANDMA MA 8PORT NODE	LA34582	11/01/17	P	S	0.04 P	S	<0.05 P	0.39 P	S	S	S
GRANDMA MA 8PORT NODE	LA38366	12/01/17	P	S	0.02 P	S	<0.05 P	0.38 P	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA31187	11/01/17	P	S	0.04 P	S	<0.05 P	0.96 P	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA31186	11/01/17	P	S	0.04 P	S	<0.05 P	0.97 P	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA31050	11/01/17	P	S	0.03 P	S	<0.05 P	0.99 P	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA31342	11/01/17	P	S	0.05 P	S	<0.05 P	0.89 P	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA31083	11/01/17	P	S	0.04 P	S	<0.05 P	0.89 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA37445	16/01/17	P	S	0.08 P	S	<0.05 P	<0.10 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA34931	16/01/17	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA38362	11/01/17	P	S	0.09 P	S	0.10 P	0.47 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA38361	11/01/17	P	S	0.07 P	S	0.09 P	0.44 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA34739	11/01/17	P	S	0.07 P	S	0.09 P	0.41 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA34930	04/01/17	S	S	0.08 P	S	0.09 P	0.41 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA34738	12/01/17	P	S	0.08 P	S	0.08 P	0.40 P	S	S	S
HES HOG 4 CONSOLE	LA34129	10/01/17	P	S	0.09 P	S	0.10 P	0.21 P	S	S	S
HES HOG 4 CONSOLE	LA34128	10/01/17	P	S	0.09 P	S	0.10 P	0.18 P	S	S	S
HES NANO HOG 4 CONSOLE	LA37111	03/01/17	P	S	S	>300 P	S	S	S	S	S
HES PLAYBACK WING 4	LA34932	12/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
HES PLAYBACK WING 4	LA34933	12/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
HES RACK HOG 4 CONSOLE	LA37112	03/01/17	P	S	0.07 P	S	<0.05 P	0.75 P	S	S	S
IEC EXTENSION 0.25M	LA33426	03/01/17	S	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
IEC EXTENSION 0.25M	LA33423	03/01/17	S	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
IEC EXTENSION 0.5M	LA33408	03/01/17	S	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
IEC EXTENSION 0.5M	LA33409	03/01/17	S	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
IEC EXTENSION 0.5M	LA33410	03/01/17	S	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
IEC EXTENSION 2M	LA25512	03/01/17	S	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
I-PIX BB4 LED WASH	LA22908	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.87 P	S	S	S
I-PIX BB4 LED WASH	LA21618	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.65 P	S	S	S
I-PIX BB4 LED WASH	LA22390	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.89 P	S	S	S
I-PIX BB4 LED WASH	LA22389	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.87 P	S	S	S
I-PIX BB4 LED WASH	LA22391	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.84 P	S	S	S
I-PIX BB4 LED WASH	LA22909	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.81 P	S	S	S
I-PIX BB4 LED WASH	LA31695	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.94 P	S	S	S
I-PIX BB4 LED WASH	LA31698	17/01/17	P	S	0.07 P	>300 P	<0.05 P	0.92 P	S	S	S
I-PIX BB4 LED WASH	LA31697	17/01/17	P	S	0.09 P	>300 P	<0.05 P	0.90 P	S	S	S
I-PIX BB4 LED WASH	LA22910	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.83 P	S	S	S
I-PIX BB4 LED WASH	LA21616	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.39 P	S	S	S
I-PIX BB4 LED WASH	LA21617	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.86 P	S	S	S
I-PIX BB4 LED WASH	LA21615	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.87 P	S	S	S
I-PIX BB4 LED WASH	LA31696	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.95 P	S	S	S
I-PIX BB4 LED WASH	LA22392	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.80 P	S	S	S
I-PIX BB4 LED WASH	LA22393	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.83 P	S	S	S
I-PIX BB4 LED WASH	LA21613	17/01/17	P	S	0.05 P	>300 P	<0.05 P	1.34 P	S	S	S
I-PIX BB4 LED WASH	LA22386	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.80 P	S	S	S
I-PIX BB4 LED WASH	LA21612	17/01/17	P	S	0.03 P	>300 P	<0.05 P	0.40 P	S	S	S
I-PIX BB4 LED WASH	LA22388	17/01/17	P	S	0.09 P	>300 P	<0.05 P	0.87 P	S	S	S
I-PIX BB4 LED WASH	LA22379	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.83 P	S	S	S
I-PIX BB4 LED WASH	LA31691	17/01/17	P	S	0.08 P	>300 P	<0.05 P	0.95 P	S	S	S
I-PIX BB4 LED WASH	LA31693	17/01/17	P	S	0.07 P	>300 P	<0.05 P	0.90 P	S	S	S
I-PIX BB4 LED WASH	LA22394	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.81 P	S	S	S
I-PIX BB4 LED WASH	LA21614	17/01/17	P	S	0.03 P	>300 P	<0.05 P	0.86 P	S	S	S
I-PIX BB4 LED WASH	LA22395	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.83 P	S	S	S
I-PIX BB4 LED WASH	LA22906	17/01/17	P	S	0.07 P	>300 P	<0.05 P	0.87 P	S	S	S
I-PIX BB4 LED WASH	LA31031	17/01/17	P	S	0.08 P	>300 P	<0.05 P	0.66 P	S	S	S
I-PIX BB4 LED WASH	LA31690	17/01/17	P	S	0.04 P	>300 P	<0.05 P	1.02 P	S	S	S
I-PIX BB4 LED WASH	LA31032	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.89 P	S	S	S
I-PIX BB4 LED WASH	LA31034	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.91 P	S	S	S
I-PIX BB4 LED WASH	LA31033	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.59 P	S	S	S
I-PIX BB4 LED WASH	LA31098	17/01/17	P	S	0.08 P	>300 P	<0.05 P	0.89 P	S	S	S
I-PIX BB4 LED WASH	LA31097	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.90 P	S	S	S
I-PIX BB4 LED WASH	LA31095	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.87 P	S	S	S
I-PIX BB4 LED WASH	LA31030	17/01/17	P	S	0.08 P	>300 P	<0.05 P	0.58 P	S	S	S
I-PIX BB4 LED WASH	LA31096	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.95 P	S	S	S
I-PIX BB4 LED WASH	LA31407	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.83 P	S	S	S
I-PIX BB4 LED WASH	LA31688	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.58 P	S	S	S
I-PIX BB4 LED WASH	LA31406	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.55 P	S	S	S
I-PIX BB4 LED WASH	LA21611	17/01/17	P	S	0.08 P	>300 P	<0.05 P	0.65 P	S	S	S
I-PIX BB4 LED WASH	LA21610	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.55 P	S	S	S
I-PIX BB4 LED WASH	LA31099	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.87 P	S	S	S
I-PIX BB4 LED WASH	LA31689	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.85 P	S	S	S
I-PIX BB4 LED WASH	LA31687	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.87 P	S	S	S
I-PIX BB4 LED WASH	LA31408	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.59 P	S	S	S
I-PIX BB4 LED WASH	LA31409	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.85 P	S	S	S
I-PIX BB4 LED WASH	LA31093	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.79 P	S	S	S
I-PIX BB4 LED WASH	LA22903	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.56 P	S	S	S
I-PIX BB4 LED WASH	LA22904	17/01/17	P	S	0.06 P	>300 P	<0.05 P	0.84 P	S	S	S
I-PIX BB4 LED WASH	LA31091	17/01/17	P	S	0.05 P	>300 P	<0.05 P	0.81 P	S	S	S
I-PIX BB4 LED WASH	LA22901	17/01/17	P	S	0.07 P	>300 P	<0.05 P	0.85 P	S	S	S
I-PIX BB4 LED WASH	LA31092	17/01/17	P	S	0.08 P	>300 P	<0.05 P	0.86 P	S	S	S
I-PIX BB4 LED WASH	LA31090	17/01/17	P	S	0.07 P	>300 P	<0.05 P	0.95 P	S	S	S
I-PIX BB4 LED WASH	LA22907	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.92 P	S	S	S
I-PIX BB4 LED WASH	LA31094	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.72 P	S	S	S
I-PIX BB4 LED WASH	LA22900	17/01/17	P	S	0.04 P	>300 P	<0.05 P	0.54 P	S	S	S
JEM AF-1 DMX FAN	LA24813	04/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34243	04/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA37938	04/01/17	P	S	0.11 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34241	04/01/17	P	S	0.12 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA16316	04/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA17507	04/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA31522	04/01/17	P	S	0.10 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34119	04/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
JEM AF-1 DMX FAN	LA37942	04/01/17	P	S	0.11 P	159.40 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA22818	04/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA37936	04/01/17	P	S	0.12 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA22817	04/01/17	P	S	0.08 P	>300 P	0.11 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA37940	04/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34118	04/01/17	P	S	0.10 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA38419	04/01/17	P	S	0.03 P	>300 P	2.08 P	0.39 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA34440	04/01/17	P	S	0.04 P	25.32 P	2.11 P	0.39 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA31520	04/01/17	P	S	0.04 P	11.13 P	1.99 P	0.37 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA34012	04/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA38418	04/01/17	P	S	0.04 P	>300 P	2.09 P	0.39 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA37552	04/01/17	P	S	0.04 P	>300 P	2.09 P	0.39 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA34752	04/01/17	P	S	0.03 P	>300 P	1.95 P	0.38 P	S	S	S
KINESYS ARRAY 485 8 WAY DATA SPLITTER	LA37277	12/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
KINESYS ARRAY PDES-T POWERLOCK DISTRO	LA34175	19/01/17	P	S	0.04 P	>300 P	<0.05 P	2.70 P	S	S	S
KINESYS ARRAY PDES-T POWERLOCK DISTRO	LA31214	19/01/17	P	S	0.04 P	>300 P	<0.05 P	2.69 P	S	S	S
KINESYS SMART 8 MOTOR CONTROLLER	LA21638	19/01/17	P	S	0.05 P	>300 P	<0.05 P	0.21 P	S	S	S
KINESYS SMART 8 MOTOR CONTROLLER	LA21968	19/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
KRAMER 1:4 DISTRIBUTION AMP - DVI	LA22414	10/01/17	P	S	0.08 P	S	<0.05 P	0.33 P	S	S	S
KRAMER 6X6 MATRIX - DVI	LA31303	12/01/17	P	S	0.07 P	S	<0.05 P	0.40 P	S	S	S
KRAMER 6X6 MATRIX - DVI	LA31304	11/01/17	P	S	0.07 P	S	<0.05 P	0.36 P	S	S	S
KRAMER 6X6 MATRIX - DVI	LA31766	11/01/17	P	S	0.09 P	S	<0.05 P	0.38 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA37118	12/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33396	11/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA39068	31/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33391	11/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33390	11/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33399	16/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA35632	11/01/17	P	S	0.07 P	>300 P	<0.05 P	0.12 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33395	12/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA26981	11/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA39089	12/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA26980	11/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33400	11/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA35634	11/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33398	11/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA26982	11/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA26983	11/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA35636	11/01/17	P	S	0.08 P	>300 P	<0.05 P	0.11 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA35631	11/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA35633	11/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33397	11/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA39066	11/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
LIGHTWARE MX 16X16 DVI PLUS MATRIX	LA34749	12/01/17	P	S	0.06 P	S	<0.05 P	<0.10 P	S	S	S
LIGHTWARE MX 8X8 MATRIX DVI-D PRO SWITCHER	LA37658	31/01/17	P	S	0.07 P	>300 P	S	S	S	S	S
LITE ALTERNATIVE SUNBED (4 X QUICK FIRE TUBE)	LA00854	18/01/17	P	S	0.06 P	85.76 P	0.10 P	1.09 P	S	S	S
LITE ALTERNATIVE SUNBED (4 X QUICK FIRE TUBE)	LA00855	18/01/17	P	S	0.06 P	78.68 P	0.10 P	1.10 P	S	S	S
LITE ALTERNATIVE SUNBED (4 X QUICK FIRE TUBE)	LA00857	18/01/17	P	S	0.05 P	81.00 P	0.10 P	1.09 P	S	S	S
LITE ALTERNATIVE SUNBED (4 X QUICK FIRE TUBE)	LA00856	18/01/17	P	S	0.06 P	114.10 P	0.09 P	1.03 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA34468	04/01/17	P	S	0.07 P	10.60 P	0.32 P	0.27 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA34467	04/01/17	P	S	0.09 P	14.68 P	0.33 P	0.26 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA37745	04/01/17	P	S	0.07 P	11.39 P	1.19 P	0.39 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA37746	04/01/17	P	S	0.06 P	12.30 P	0.24 P	0.28 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA38569	04/01/17	P	S	0.05 P	5.75 P	1.14 P	0.40 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17312	06/01/17	P	S	0.05 P	>300 P	0.64 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17809	06/01/17	P	S	0.05 P	>300 P	0.64 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17427	06/01/17	P	S	0.06 P	>300 P	0.65 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17426	06/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA24063	06/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA24064	06/01/17	P	S	0.06 P	>300 P	0.66 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA04639	06/01/17	P	S	0.05 P	>300 P	0.68 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38271	10/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA37155	10/01/17	P	S	0.08 P	>300 P	<0.05 P	0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38273	10/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38432	10/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38431	10/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38272	10/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA37090	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38657	11/01/17	S	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38658	11/01/17	S	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38659	11/01/17	S	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA37091	12/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38051	10/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38660	11/01/17	S	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38052	10/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
LUMINEX GIGASWITCH 8 PORT ETHERCON	LA31416	12/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA22497	04/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA22463	04/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA22781	04/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA37167	19/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA38568	04/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA22780	04/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CONTROLLER											
LV6 6 WAY MOTOR CONTROLLER	LA34513	19/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LV6 6 WAY MOTOR CONTROLLER	LA22782	19/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
LV6 6 WAY MOTOR CONTROLLER	LA34512	19/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MA DMX MERGER	LA31225	31/01/17	P	S	0.13 P	>300 P	<0.05 P	0.21 P	S	S	S
MA DMX MERGER	LA31226	31/01/17	P	S	0.12 P	>300 P	<0.05 P	0.21 P	S	S	S
MA DMX MERGER	LA31224	31/01/17	P	S	0.11 P	>300 P	<0.05 P	0.21 P	S	S	S
MA DMX MERGER	LA31223	31/01/17	P	S	0.08 P	>300 P	<0.05 P	0.21 P	S	S	S
MAC 101CT WHITE LED	LA26692	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.33 P	S	S	S
MAC 101CT WHITE LED	LA26691	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.34 P	S	S	S
MAC 101CT WHITE LED	LA26686	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.35 P	S	S	S
MAC 101CT WHITE LED	LA26697	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.34 P	S	S	S
MAC 101CT WHITE LED	LA26696	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.32 P	S	S	S
MAC 101CT WHITE LED	LA26690	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.32 P	S	S	S
MAC 101CT WHITE LED	LA26693	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.35 P	S	S	S
MAC 101CT WHITE LED	LA26689	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.34 P	S	S	S
MAC 101CT WHITE LED	LA26695	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.35 P	S	S	S
MAC 101CT WHITE LED	LA26687	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.34 P	S	S	S
MAC 101CT WHITE LED	LA26688	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC 101CT WHITE LED	LA26694	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.35 P	S	S	S
MAC AURA LED WASH	LA34640	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34639	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34641	03/01/17	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34642	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34643	04/01/17	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34638	03/01/17	P	S	0.05 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34644	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34645	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34647	04/01/17	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34626	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34636	03/01/17	P	S	0.05 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34637	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34634	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34631	04/01/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34632	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34633	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34630	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34623	03/01/17	P	S	0.04 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34628	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34629	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34622	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34635	03/01/17	P	S	0.01 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34624	03/01/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34625	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34363	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34103	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34096	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34067	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.55 P	S	S	S
MAC AURA LED WASH	LA34097	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34098	03/01/17	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34101	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34099	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34102	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34105	04/01/17	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34831	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34748	03/01/17	P	S	0.05 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34832	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.43 P	S	S	S
MAC AURA LED WASH	LA34830	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34829	03/01/17	P	S	0.04 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34073	03/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34069	04/01/17	P	S	0.05 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34074	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.32 P	S	S	S
MAC AURA LED WASH	LA34072	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34070	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA37346	03/01/17	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA37344	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC AURA LED WASH	LA37351	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA37349	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA37352	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34909	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA37110	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34910	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA37348	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA37347	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA37340	03/01/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA37343	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA37341	03/01/17	P	S	0.01 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34100	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA37353	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA37338	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA37350	03/01/17	P	S	0.01 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA37339	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA37342	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA37337	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34479	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34477	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34475	04/01/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34469	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34476	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34473	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34818	04/01/17	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34474	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34472	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34471	03/01/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34486	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34481	04/01/17	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34490	04/01/17	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34485	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34484	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34492	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34491	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34482	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34480	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34483	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34820	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34824	03/01/17	P	S	0.05 P	>300 P	<0.05 P	0.42 P	S	S	S
MAC AURA LED WASH	LA34822	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34828	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.43 P	S	S	S
MAC AURA LED WASH	LA34827	04/01/17	P	S	0.07 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34836	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34835	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34833	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34823	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA34834	03/01/17	P	S	0.01 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34843	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34838	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34841	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34819	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34842	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA34826	04/01/17	P	S	0.06 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34825	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34839	03/01/17	P	S	0.01 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34837	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34840	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA31950	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA38040	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA31676	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.19 P	S	S	S
MAC AURA LED WASH	LA31954	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA31922	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.54 P	S	S	S
MAC AURA LED WASH	LA31674	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA38039	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC AURA LED WASH	LA34627	03/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA31953	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA38041	06/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AXIOM HYBRID	LA38551	20/01/17	P	S	0.05 P	>300 P	0.13 P	0.22 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC AXIOM HYBRID	LA38550	20/01/17	P	S	0.06 P	>300 P	0.13 P	0.22 P	S	S	S
MAC AXIOM HYBRID	LA38549	20/01/17	P	S	0.06 P	>300 P	0.13 P	0.22 P	S	S	S
MAC AXIOM HYBRID	LA38548	20/01/17	P	S	0.05 P	>300 P	0.13 P	0.22 P	S	S	S
MAC AXIOM HYBRID	LA38547	20/01/17	P	S	0.06 P	>300 P	0.13 P	0.22 P	S	S	S
MAC QUANTUM LED PROFILE	LA37141	04/01/17	P	S	0.03 P	>300 P	0.10 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37145	04/01/17	P	S	0.05 P	>300 P	0.10 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37142	04/01/17	P	S	0.03 P	>300 P	0.10 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37143	04/01/17	P	S	0.06 P	>300 P	0.11 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37144	04/01/17	P	S	0.03 P	>300 P	0.10 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37148	04/01/17	P	S	0.02 P	>300 P	0.11 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37146	04/01/17	P	S	0.03 P	>300 P	0.10 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37147	04/01/17	P	S	0.06 P	>300 P	0.10 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37149	04/01/17	P	S	0.04 P	>300 P	0.10 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37540	04/01/17	P	S	0.03 P	>300 P	0.07 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34881	04/01/17	P	S	0.03 P	>300 P	0.06 P	0.38 P	S	S	S
MAC QUANTUM LED WASH	LA34877	04/01/17	P	S	0.02 P	>300 P	0.06 P	0.38 P	S	S	S
MAC QUANTUM LED WASH	LA34874	03/01/17	P	S	0.03 P	>300 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37535	04/01/17	P	S	0.03 P	>300 P	0.06 P	0.38 P	S	S	S
MAC QUANTUM LED WASH	LA34876	04/01/17	P	S	0.03 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34875	03/01/17	P	S	0.04 P	121.40 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37123	03/01/17	P	S	0.02 P	>300 P	0.07 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37122	04/01/17	P	S	0.05 P	>300 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37121	03/01/17	P	S	0.03 P	101.40 P	0.07 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37537	03/01/17	P	S	0.03 P	>300 P	0.07 P	0.36 P	S	S	S
MAC QUANTUM LED WASH	LA37536	03/01/17	P	S	0.03 P	>300 P	0.07 P	0.36 P	S	S	S
MAC QUANTUM LED WASH	LA34878	03/01/17	P	S	0.02 P	>300 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34879	03/01/17	P	S	0.03 P	91.59 P	0.06 P	0.39 P	S	S	S
MAC QUANTUM LED WASH	LA37538	03/01/17	P	S	0.03 P	>300 P	0.07 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34873	03/01/17	P	S	0.02 P	>300 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37539	03/01/17	P	S	0.03 P	>300 P	0.07 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34882	03/01/17	P	S	0.02 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34880	03/01/17	P	S	0.03 P	>300 P	0.06 P	0.37 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21491	19/01/17	P	S	0.06 P	>300 P	0.12 P	0.68 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21807	19/01/17	P	S	0.06 P	>300 P	0.13 P	0.62 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21906	19/01/17	P	S	0.04 P	>300 P	0.12 P	0.65 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21490	19/01/17	P	S	0.04 P	>300 P	0.13 P	0.73 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21488	19/01/17	P	S	0.05 P	>300 P	0.12 P	0.63 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21907	19/01/17	P	S	0.03 P	>300 P	0.13 P	0.67 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21489	19/01/17	P	S	0.05 P	>300 P	0.12 P	0.67 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21492	19/01/17	P	S	0.05 P	>300 P	0.13 P	0.67 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21493	19/01/17	P	S	0.05 P	>300 P	0.12 P	0.71 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21937	19/01/17	P	S	0.06 P	>300 P	0.12 P	0.68 P	S	S	S
MAC VIPER AIRFX	LA34902	18/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER AIRFX	LA37753	18/01/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37357	18/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER AIRFX	LA37193	18/01/17	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37199	21/12/16	P	S	0.02 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA34907	21/12/16	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37194	18/01/17	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37750	18/01/17	P	S	0.07 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37196	20/12/16	P	S	0.04 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER AIRFX	LA34441	18/01/17	P	S	0.06 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC VIPER AIRFX	LA34442	18/01/17	P	S	0.04 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER AIRFX	LA37751	18/01/17	P	S	0.06 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA34901	18/01/17	P	S	0.09 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37355	18/01/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA34903	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.42 P	S	S	S
MAC VIPER AIRFX	LA37198	16/01/17	P	S	0.08 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37356	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA38387	21/12/16	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC VIPER AIRFX	LA37197	20/12/16	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37363	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.25 P	S	S	S
MAC VIPER AIRFX	LA37362	20/12/16	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37202	20/12/16	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37365	22/12/16	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37748	21/12/16	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37902	18/01/17	P	S	0.07 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37903	18/01/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37364	16/01/17	P	S	0.07 P	>300 P	<0.05 P	0.42 P	S	S	S
MAC VIPER AIRFX	LA38388	21/12/16	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA38386	22/12/16	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37749	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37752	18/01/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37747	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA34908	20/12/16	P	S	0.02 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37359	21/12/16	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37195	18/01/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37360	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37900	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37191	18/01/17	P	S	0.06 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA34447	18/01/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37901	16/01/17	P	S	0.08 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA34448	18/01/17	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37799	18/01/17	P	S	0.09 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER AIRFX	LA37906	20/12/16	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA38390	20/12/16	P	S	0.06 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA38389	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA38391	20/12/16	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA34905	21/12/16	P	S	0.08 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37361	18/01/17	P	S	0.07 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA38392	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37904	18/01/17	P	S	0.04 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER AIRFX	LA37358	18/01/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37905	21/12/16	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER AIRFX	LA34906	16/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER AIRFX	LA37200	18/01/17	P	S	0.07 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA34449	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER AIRFX	LA37192	20/12/16	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37910	21/12/16	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37201	20/12/16	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37203	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37909	21/12/16	P	S	0.03 P	>300 P	<0.05 P	0.39 P	S	S	S
MAC VIPER AIRFX	LA37907	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37911	18/01/17	P	S	0.08 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37908	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA34445	20/12/16	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA34443	18/01/17	P	S	0.04 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER AIRFX	LA34444	21/12/16	P	S	0.12 P	>300 P	<0.05 P	0.34 P	S	S	S
MAC VIPER AIRFX	LA34446	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC VIPER PROFILE	LA31941	19/01/17	P	S	0.09 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA31943	19/01/17	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA31936	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA34045	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA37720	18/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER PROFILE	LA31942	11/01/17	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA34041	19/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER PROFILE	LA31931	19/01/17	P	S	0.11 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA31930	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37136	19/12/16	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA31932	19/12/16	P	S	0.11 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34042	19/12/16	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA31938	05/01/17	P	S	0.02 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34046	11/01/17	P	S	0.02 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA31927	12/01/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA34048	18/01/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37138	20/12/16	P	S	0.02 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA31929	18/01/17	P	S	0.11 P	>300 P	<0.05 P	0.42 P	S	S	S
MAC VIPER PROFILE	LA37172	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER PROFILE	LA31928	18/01/17	P	S	0.10 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC VIPER PROFILE	LA34040	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA34049	05/01/17	P	S	0.02 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34044	05/01/17	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA34043	18/01/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA31924	21/12/16	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC VIPER PROFILE	LA34047	19/01/17	P	S	0.07 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37135	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA31935	19/12/16	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37730	19/12/16	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37729	19/01/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37735	13/01/17	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA37734	19/01/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37733	05/01/17	P	S	0.02 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37732	12/01/17	P	S	0.02 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37134	11/01/17	P	S	0.02 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA31940	12/01/17	P	S	0.02 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37130	19/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37731	19/12/16	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37131	11/01/17	P	S	0.02 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA34234	19/12/16	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34235	19/12/16	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA34229	19/12/16	P	S	0.02 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA34230	05/01/17	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA34231	05/01/17	P	S	0.02 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA34232	19/01/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA34108	19/12/16	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA34109	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34110	19/01/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA34233	19/01/17	P	S	0.05 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER PROFILE	LA34236	19/12/16	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37724	05/01/17	P	S	0.02 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37723	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37721	19/12/16	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37727	19/12/16	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA37722	19/12/16	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37716	19/01/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA31933	19/01/17	P	S	0.07 P	>300 P	<0.05 P	0.24 P	S	S	S
MAC VIPER PROFILE	LA31934	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37137	19/01/17	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37714	13/01/17	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA37719	18/01/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37717	19/12/16	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA31939	13/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37129	19/12/16	P	S	0.08 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37133	19/01/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37718	19/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER PROFILE	LA37726	19/01/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37725	19/01/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37728	19/12/16	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37715	19/12/16	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA31926	18/01/17	P	S	0.09 P	>300 P	<0.05 P	0.36 P	S	S	S
MAC VIPER PROFILE	LA31925	05/01/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA31666	10/01/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA31665	10/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA20255	10/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37107	10/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37106	10/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37108	10/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA20254	10/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37104	10/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37101	10/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAINTAINED EMERGENCY EXIT SIGN	LA20306	10/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37103	10/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37102	10/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37105	10/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26866	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.25 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26533	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26534	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26847	09/01/17	P	S	0.03 P	11.95 P	<0.05 P	0.26 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26848	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26849	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.25 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26846	09/01/17	P	S	0.02 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26865	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.25 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26923	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26387	09/01/17	P	S	0.07 P	>300 P	<0.05 P	0.26 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA37551	10/01/17	P	S	0.02 P	>300 P	<0.05 P	0.22 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26550	09/01/17	P	S	0.04 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26551	09/01/17	P	S	0.03 P	14.16 P	<0.05 P	0.25 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26552	09/01/17	P	S	0.05 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26537	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26553	09/01/17	P	S	0.05 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26554	09/01/17	P	S	0.05 P	>300 P	<0.05 P	0.25 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA24166	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.25 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26555	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26536	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26924	09/01/17	P	S	0.04 P	>300 P	<0.05 P	0.25 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA24810	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26535	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.24 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38237	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38243	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38238	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38240	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38241	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38236	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38239	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38242	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38233	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38234	16/01/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MARTIN ATOMIC 3000 LED STROBE	LA38245	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38235	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38244	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
MARTIN P3 POWERPORT 1500	LA39440	16/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
MARTIN P3 POWERPORT 1500	LA39438	16/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
MARTIN P3-100 SYSTEM CONTROLLER	LA39442	16/01/17	P	S	0.09 P	>300 P	S	S	S	S	S
MARTIN P3-100 SYSTEM CONTROLLER	LA39443	16/01/17	P	S	0.08 P	>300 P	S	S	S	S	S
MOLEFAY 2 LITE THOMAS	LA34035	05/01/17	P	S	0.04 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34038	05/01/17	P	S	0.04 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34034	05/01/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34019	05/01/17	P	S	0.04 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34020	05/01/17	P	S	0.05 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34017	05/01/17	P	S	0.04 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34033	05/01/17	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34039	05/01/17	P	S	0.05 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34030	05/01/17	P	S	0.09 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34015	05/01/17	P	S	0.07 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34028	05/01/17	P	S	0.05 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34032	05/01/17	P	S	0.07 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34025	05/01/17	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34026	05/01/17	P	S	0.06 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34031	05/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34037	05/01/17	P	S	0.08 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34016	05/01/17	P	S	0.07 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34014	05/01/17	P	S	0.04 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34027	05/01/17	P	S	0.09 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34029	05/01/17	P	S	0.03 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34018	05/01/17	P	S	0.05 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31891	05/01/17	P	S	0.05 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31890	05/01/17	P	S	0.05 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31887	05/01/17	P	S	0.03 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31889	05/01/17	P	S	0.02 P	>300 P	1.25 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31888	05/01/17	P	S	0.03 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17918	06/01/17	P	S	0.09 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17921	05/01/17	P	S	0.05 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17919	05/01/17	P	S	0.04 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA26892	05/01/17	P	S	0.05 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17920	05/01/17	P	S	0.09 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31893	05/01/17	P	S	0.06 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31886	05/01/17	P	S	0.07 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31885	05/01/17	P	S	0.06 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31849	06/01/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31851	05/01/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31850	05/01/17	P	S	0.02 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA26891	05/01/17	P	S	0.04 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31894	05/01/17	P	S	0.03 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA26890	05/01/17	P	S	0.03 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31884	05/01/17	P	S	0.05 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31895	05/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34024	05/01/17	P	S	0.04 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31656	05/01/17	P	S	0.06 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17923	05/01/17	P	S	0.04 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17922	05/01/17	P	S	0.05 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34022	05/01/17	P	S	0.05 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31657	05/01/17	P	S	0.04 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34023	05/01/17	P	S	0.04 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34021	05/01/17	P	S	0.05 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24661	05/01/17	P	S	0.06 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26828	05/01/17	P	S	0.02 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26829	05/01/17	P	S	0.05 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26827	05/01/17	P	S	0.03 P	>300 P	2.46 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MOLEFAY 4 LITE LINEAR THOMAS	LA24655	05/01/17	P	S	0.07 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26826	05/01/17	P	S	0.02 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26823	05/01/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26835	05/01/17	P	S	0.08 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26834	05/01/17	P	S	0.04 P	>300 P	2.47 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24662	05/01/17	P	S	0.06 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26824	05/01/17	P	S	0.08 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26822	05/01/17	P	S	0.04 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26825	05/01/17	P	S	0.03 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA34339	05/01/17	P	S	0.05 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24672	05/01/17	P	S	0.03 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24647	05/01/17	P	S	0.05 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24667	05/01/17	P	S	0.05 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24646	05/01/17	P	S	0.07 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24670	05/01/17	P	S	0.02 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24669	05/01/17	P	S	0.07 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26818	05/01/17	P	S	0.06 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26817	05/01/17	P	S	0.02 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24668	05/01/17	P	S	0.02 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26816	05/01/17	P	S	0.02 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24673	05/01/17	P	S	0.03 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24671	05/01/17	P	S	0.02 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24648	05/01/17	P	S	0.05 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26820	05/01/17	P	S	0.08 P	>300 P	2.46 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26819	05/01/17	P	S	0.02 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24649	05/01/17	P	S	0.04 P	>300 P	2.46 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24659	05/01/17	P	S	0.02 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24665	05/01/17	P	S	0.07 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26809	05/01/17	P	S	0.02 P	>300 P	2.47 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26815	05/01/17	P	S	0.02 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26811	05/01/17	P	S	0.02 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24658	05/01/17	P	S	0.09 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24666	05/01/17	P	S	0.04 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26807	05/01/17	P	S	0.02 P	>300 P	2.41 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26821	05/01/17	P	S	0.05 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26810	05/01/17	P	S	0.09 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24663	05/01/17	P	S	0.02 P	>300 P	2.45 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MOLEFAY 4 LITE LINEAR THOMAS	LA24664	05/01/17	P	S	0.03 P	>300 P	2.47 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26806	05/01/17	P	S	0.07 P	>300 P	1.25 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24652	05/01/17	P	S	0.06 P	>300 P	2.48 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26808	05/01/17	P	S	0.04 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26832	05/01/17	P	S	0.02 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24657	05/01/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26833	05/01/17	P	S	0.03 P	>300 P	2.46 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24654	05/01/17	P	S	0.02 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26831	05/01/17	P	S	0.05 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26830	05/01/17	P	S	0.04 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24656	05/01/17	P	S	0.02 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26813	05/01/17	P	S	0.05 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24653	05/01/17	P	S	0.02 P	>300 P	2.48 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26812	05/01/17	P	S	0.05 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24651	05/01/17	P	S	0.04 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24650	05/01/17	P	S	0.03 P	>300 P	2.42 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22766	05/01/17	P	S	0.02 P	>300 P	2.48 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21888	05/01/17	P	S	0.06 P	>300 P	2.41 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22864	05/01/17	P	S	0.09 P	>300 P	2.40 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22865	05/01/17	P	S	0.02 P	>300 P	2.49 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22767	05/01/17	P	S	0.08 P	>300 P	2.42 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21886	05/01/17	P	S	0.02 P	>300 P	2.49 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21885	05/01/17	P	S	0.03 P	>300 P	2.49 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21099	05/01/17	P	S	0.07 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34865	05/01/17	P	S	0.09 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22224	05/01/17	P	S	0.02 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34341	05/01/17	P	S	0.08 P	>300 P	2.41 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34340	05/01/17	P	S	0.02 P	>300 P	2.49 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34864	05/01/17	P	S	0.06 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22765	05/01/17	P	S	0.02 P	>300 P	2.46 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34868	05/01/17	P	S	0.06 P	>300 P	2.53 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21883	05/01/17	P	S	0.02 P	>300 P	2.49 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34867	05/01/17	P	S	0.08 P	>300 P	2.42 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21348	05/01/17	P	S	0.05 P	>300 P	2.49 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34861	05/01/17	P	S	0.07 P	>300 P	2.42 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21349	05/01/17	P	S	0.05 P	>300 P	2.52 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22769	05/01/17	P	S	0.02 P	>300 P	2.49 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MOLEFAY 4 LITE SQUARE THOMAS	LA22770	05/01/17	P	S	0.02 P	290.20 P	2.51 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34866	05/01/17	P	S	0.05 P	>300 P	2.41 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34862	05/01/17	P	S	0.08 P	>300 P	2.46 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34863	05/01/17	P	S	0.02 P	290.20 P	2.50 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21347	05/01/17	P	S	0.04 P	>300 P	2.50 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21345	05/01/17	P	S	0.05 P	>300 P	2.48 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22768	05/01/17	P	S	0.02 P	>300 P	2.49 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21884	05/01/17	P	S	0.02 P	>300 P	2.52 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21887	05/01/17	P	S	0.05 P	>300 P	2.49 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22771	05/01/17	P	S	0.07 P	>300 P	2.41 P	<0.10 P	S	S	S
MOLEFAY 8 LITE THOMAS	LA24364	09/01/17	P	S	0.07 P	>300 P	1.25 P	<0.10 P	S	S	S
OUTBOARD 12 WAY GAUZE CONTROLLER	LA15212	19/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
OUTBOARD 12 WAY GAUZE CONTROLLER	LA20495	19/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25146	06/01/17	P	S	0.08 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA20635	18/01/17	S	S	0.02 P	>300 P	1.01 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA15293	18/01/17	S	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA20636	18/01/17	S	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA24300	18/01/17	S	S	0.02 P	>300 P	1.01 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA20637	18/01/17	S	S	0.03 P	>300 P	1.15 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA24303	18/01/17	S	S	0.02 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA24302	18/01/17	S	S	0.02 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA24301	18/01/17	S	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA17532	18/01/17	S	S	0.02 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA17531	18/01/17	S	S	0.03 P	>300 P	1.14 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA20638	18/01/17	S	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA15188	18/01/17	S	S	0.02 P	>300 P	1.07 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA17301	18/01/17	S	S	0.02 P	>300 P	1.16 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16731	18/01/17	S	S	0.03 P	>300 P	1.06 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16730	18/01/17	S	S	0.02 P	>300 P	1.25 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16729	17/01/17	S	S	0.03 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16728	17/01/17	S	S	0.04 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16727	18/01/17	S	S	0.03 P	>300 P	0.85 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA15295	17/01/17	S	S	0.03 P	>300 P	1.32 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16005	18/01/17	S	S	0.03 P	>300 P	1.05 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16596	18/01/17	S	S	0.03 P	>300 P	0.66 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA15296	18/01/17	S	S	0.02 P	>300 P	1.27 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16599	18/01/17	S	S	0.02 P	>300 P	0.69 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16008	18/01/17	S	S	0.02 P	>300 P	1.29 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16598	17/01/17	S	S	0.05 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16007	18/01/17	S	S	0.03 P	>300 P	1.27 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16006	18/01/17	S	S	0.02 P	>300 P	1.06 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16597	18/01/17	S	S	0.02 P	>300 P	1.27 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26485	06/01/17	P	S	0.05 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26494	06/01/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26489	06/01/17	P	S	0.06 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26486	06/01/17	P	S	0.05 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26484	06/01/17	P	S	0.08 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26487	06/01/17	P	S	0.05 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26492	06/01/17	P	S	0.05 P	>300 P	1.07 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26495	06/01/17	P	S	0.04 P	>300 P	1.06 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26493	06/01/17	P	S	0.04 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26488	06/01/17	P	S	0.08 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26491	06/01/17	P	S	0.06 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26490	06/01/17	P	S	0.05 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31645	17/01/17	P	S	0.03 P	>300 P	1.22 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31642	17/01/17	P	S	0.04 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31641	17/01/17	P	S	0.03 P	>300 P	1.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PARCAN											
PAR 64 INDIVIDUAL BLACK PARCAN	LA21097	17/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA21090	17/01/17	P	S	0.04 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31647	17/01/17	P	S	0.04 P	>300 P	1.05 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA21530	17/01/17	P	S	0.06 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31643	17/01/17	P	S	0.04 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31650	17/01/17	P	S	0.03 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21174	09/01/17	P	S	0.02 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21170	09/01/17	P	S	0.02 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22861	09/01/17	P	S	0.02 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21175	06/01/17	P	S	0.04 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22859	09/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22856	09/01/17	P	S	0.02 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21164	09/01/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22858	06/01/17	P	S	0.03 P	>300 P	0.53 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22857	09/01/17	P	S	0.03 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22261	09/01/17	P	S	0.02 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21177	09/01/17	P	S	0.03 P	>300 P	0.53 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21176	09/01/17	P	S	0.03 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21169	10/01/17	P	S	0.02 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21178	09/01/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21166	09/01/17	P	S	0.03 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22860	06/01/17	P	S	0.05 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA16792	09/01/17	P	S	0.03 P	>300 P	0.54 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21168	06/01/17	P	S	0.05 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22262	09/01/17	P	S	0.02 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21165	09/01/17	P	S	0.03 P	>300 P	0.53 P	<0.10 P	S	S	S
PINSPOT 4 WAY BAR C/W 16A IN AND OUT.	LA22855	18/01/17	P	S	0.06 P	>300 P	0.09 P	<0.10 P	S	S	S
PINSPOT 4 WAY BAR C/W 16A IN AND OUT.	LA22854	18/01/17	P	S	0.06 P	>300 P	0.09 P	<0.10 P	S	S	S
PINSPOT 5 WAY BAR C/W 16A IN AND OUT.	LA02991	18/01/17	P	S	0.06 P	>300 P	0.09 P	<0.10 P	S	S	S
PINSPOT 5 WAY BAR C/W 16A IN AND OUT.	LA02993	18/01/17	P	S	0.06 P	>300 P	0.09 P	<0.10 P	S	S	S
PINSPOT 5 WAY BAR C/W 16A IN AND OUT.	LA01787	18/01/17	P	S	0.05 P	>300 P	0.09 P	<0.10 P	S	S	S
PINSPOT 5 WAY BAR C/W 16A IN AND OUT.	LA01396	18/01/17	P	S	0.05 P	>300 P	0.09 P	<0.10 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38177	20/01/17	P	S	0.02 P	>300 P	0.07 P	0.81 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38176	20/01/17	P	S	0.02 P	>300 P	0.07 P	0.82 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38181	20/01/17	P	S	0.02 P	>300 P	0.07 P	0.82 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38178	20/01/17	P	S	0.02 P	>300 P	0.07 P	0.80 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38180	20/01/17	P	S	0.02 P	>300 P	0.07 P	0.82 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38173	20/01/17	P	S	0.02 P	>300 P	0.07 P	0.80 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38175	20/01/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38182	20/01/17	P	S	0.02 P	>300 P	0.07 P	0.83 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38174	20/01/17	P	S	0.03 P	>300 P	0.07 P	0.82 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38059	20/01/17	P	S	0.02 P	>300 P	0.07 P	0.79 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38183	20/01/17	P	S	0.03 P	>300 P	0.18 P	0.79 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38336	20/01/17	P	S	0.03 P	>300 P	0.07 P	0.85 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37754	10/01/17	P	S	0.04 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38498	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38495	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38501	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38493	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37764	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38502	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38494	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38497	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38499	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38500	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38496	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38503	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37765	10/01/17	P	S	0.05 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37644	10/01/17	P	S	0.04 P	>300 P	0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37639	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37638	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37643	10/01/17	P	S	0.04 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37642	10/01/17	P	S	0.04 P	>300 P	0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37645	10/01/17	P	S	0.04 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37647	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37646	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37648	10/01/17	P	S	0.04 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37641	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37640	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37671	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37761	10/01/17	P	S	0.05 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37756	10/01/17	P	S	0.04 P	>300 P	0.06 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37763	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37762	10/01/17	P	S	0.04 P	>300 P	0.06 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37755	10/01/17	P	S	0.05 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37759	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37757	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37758	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38749	16/01/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38751	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38750	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38754	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38690	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38691	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38753	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38727	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38726	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38670	16/01/17	P	S	0.08 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38692	16/01/17	P	S	0.07 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38672	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38671	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38674	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38673	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38675	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38745	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38667	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38689	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38722	16/01/17	P	S	0.08 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38724	16/01/17	P	S	0.08 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38669	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38752	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38723	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38668	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38681	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38698	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38693	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38697	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38701	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38729	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38713	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38700	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38734	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38736	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38714	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38715	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38732	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38755	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38733	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38747	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38746	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38699	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38694	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38695	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38683	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38688	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38680	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38730	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38696	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38679	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38742	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38739	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38738	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38735	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38741	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38685	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38684	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38731	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38704	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38707	16/01/17	P	S	0.08 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38705	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38720	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38709	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38721	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38710	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38678	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38706	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38682	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38687	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38686	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38743	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38717	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38744	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38725	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38718	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38703	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38711	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38712	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.12 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38716	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38708	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38737	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38748	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38719	16/01/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38728	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38702	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38677	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38676	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38199	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38211	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38198	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38218	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38019	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38224	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38020	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38217	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38222	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38201	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38200	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38210	16/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38202	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38196	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38214	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38223	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38216	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38024	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38030	16/01/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38029	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38027	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38206	16/01/17	P	S	0.02 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38193	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38028	16/01/17	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38021	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38221	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38205	16/01/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38195	16/01/17	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS STUDIOCOBUV LED UV	LA38220	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38225	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38204	16/01/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34887	31/01/17	P	S	0.04 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34888	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34806	11/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34328	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34329	11/01/17	P	S	0.05 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34934	11/01/17	P	S	0.05 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34885	11/01/17	P	S	0.03 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34302	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34304	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34303	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34305	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34326	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34327	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34886	11/01/17	P	S	0.03 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34805	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34808	11/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34804	11/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA26968	11/01/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34807	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA37468	10/01/17	P	S	0.02 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34884	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34300	11/01/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34803	11/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34301	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
PROPLEX IQ ONE 8 ETHERNET TO DMX	LA37166	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38300	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38303	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38297	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38296	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38299	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38298	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38304	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38517	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.25 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38516	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.24 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROPLEX RDM DMX OPTO ISOLATOR	LA38305	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38302	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38301	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38306	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX SCENE SWITCH 8	LA38368	11/01/17	S	S	0.02 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX SCENE SWITCH 8	LA38371	11/01/17	S	S	0.02 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX SCENE SWITCH 8	LA38370	11/01/17	S	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
PROPLEX SCENE SWITCH 8	LA38369	11/01/17	S	S	0.02 P	>300 P	<0.05 P	0.18 P	S	S	S
PULSAR UNI PAK 10A DIMMER	LA22933	12/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PULSAR UNI PAK 10A DIMMER	LA22937	12/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA21835	04/01/17	P	S	0.07 P	239.10 P	0.43 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA21836	04/01/17	P	S	0.07 P	91.09 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA34248	04/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA24941	05/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA22772	04/01/17	P	S	0.07 P	>300 P	0.43 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA21837	04/01/17	P	S	0.07 P	3.90 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA31432	04/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA34869	04/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA25006	04/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA31431	04/01/17	P	S	0.06 P	9.18 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA25755	04/01/17	P	S	0.08 P	250.70 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA25756	04/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA17198	04/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA17199	04/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA37934	10/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA37973	10/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA34741	10/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA37395	10/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA37962	10/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA34742	10/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA34743	10/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA37960	10/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA37457	10/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA37396	10/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA34744	10/01/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA37162	10/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA34747	10/01/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA34746	10/01/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA37961	10/01/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
SGM X5 WHITE LED STROBE	LA37915	06/01/17	P	S	0.07 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34255	09/01/17	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34258	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34257	09/01/17	P	S	0.08 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34256	09/01/17	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34259	06/01/17	P	S	0.08 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34262	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34261	09/01/17	P	S	0.08 P	>300 P	<0.05 P	0.22 P	S	S	S
SGM X5 WHITE LED STROBE	LA34268	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34263	09/01/17	P	S	0.09 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34266	09/01/17	P	S	0.08 P	>300 P	<0.05 P	0.30 P	S	S	S
SGM X5 WHITE LED STROBE	LA34265	06/01/17	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34264	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.26 P	S	S	S
SGM X5 WHITE LED STROBE	LA34267	06/01/17	P	S	0.06 P	>300 P	<0.05 P	0.27 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SGM X5 WHITE LED STROBE	LA34270	09/01/17	P	S	0.08 P	>300 P	<0.05 P	0.23 P	S	S	S
SGM X5 WHITE LED STROBE	LA34269	06/01/17	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34272	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34271	09/01/17	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34274	09/01/17	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34277	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34276	09/01/17	P	S	0.08 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34275	06/01/17	P	S	0.06 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34278	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.23 P	S	S	S
SGM X5 WHITE LED STROBE	LA34273	09/01/17	P	S	0.06 P	>300 P	<0.05 P	0.30 P	S	S	S
SGM X5 WHITE LED STROBE	LA34282	09/01/17	P	S	0.09 P	>300 P	<0.05 P	0.28 P	S	S	S
SGM X5 WHITE LED STROBE	LA34281	09/01/17	P	S	0.07 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34260	06/01/17	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34279	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34284	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34283	09/01/17	P	S	0.09 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34280	09/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34223	09/01/17	P	S	0.04 P	>300 P	<0.05 P	0.21 P	S	S	S
SGM X5 WHITE LED STROBE	LA34228	06/01/17	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34225	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34250	09/01/17	P	S	0.08 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34253	09/01/17	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34252	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34224	09/01/17	P	S	0.09 P	>300 P	<0.05 P	0.22 P	S	S	S
SGM X5 WHITE LED STROBE	LA34665	09/01/17	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34662	09/01/17	P	S	0.04 P	>300 P	<0.05 P	0.25 P	S	S	S
SGM X5 WHITE LED STROBE	LA34663	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34227	06/01/17	P	S	0.06 P	>300 P	<0.05 P	0.27 P	S	S	S
SGM X5 WHITE LED STROBE	LA34226	09/01/17	P	S	0.09 P	>300 P	<0.05 P	0.28 P	S	S	S
SGM X5 WHITE LED STROBE	LA34664	09/01/17	P	S	0.06 P	>300 P	<0.05 P	0.21 P	S	S	S
SGM X5 WHITE LED STROBE	LA34251	09/01/17	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34392	09/01/17	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34254	06/01/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34674	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34677	10/01/17	P	S	0.02 P	>300 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34676	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34681	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.34 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34678	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34675	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34680	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34682	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34683	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34684	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34685	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34686	10/01/17	P	S	0.05 P	256.40 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34687	10/01/17	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34688	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34689	10/01/17	P	S	0.05 P	102.40 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34666	10/01/17	P	S	0.04 P	188.00 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34669	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34668	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.33 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34667	10/01/17	P	S	0.06 P	152.40 P	<0.05 P	0.32 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SHOWTEC SUNSTRIP ACTIVE DMX	LA34670	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34673	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34672	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34546	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA24319	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA24323	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.27 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA24316	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.28 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34679	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34671	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA31345	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.29 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA31346	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26191	10/01/17	P	S	0.06 P	>300 P	0.23 P	0.33 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26199	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26198	10/01/17	P	S	0.05 P	267.70 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26202	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA31515	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.28 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26297	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26295	10/01/17	P	S	0.08 P	281.60 P	<0.05 P	0.28 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26203	10/01/17	P	S	0.07 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26200	10/01/17	P	S	0.04 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26192	10/01/17	P	S	0.08 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26195	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.35 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26194	10/01/17	P	S	0.03 P	7.55 P	<0.05 P	0.33 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26197	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26294	10/01/17	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26193	10/01/17	P	S	0.06 P	>300 P	<0.05 P	0.31 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34371	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34366	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31628	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34368	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34377	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34372	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34367	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34374	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31636	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31621	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31631	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SILVER EXHIBITION CLAMP ON LAMP	LA31634	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31629	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31627	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31623	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31638	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34380	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31006	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31007	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31014	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31012	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31625	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31017	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31011	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31015	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31626	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31624	06/01/17	P	S	S	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34382	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34373	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34364	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34379	06/01/17	P	S	S	>300 P	<0.05 P	<0.10 P	S	S	S
SNOW / CONFETTI SUPERSTAR MACHINE (FAN STYLE)	LA17425	10/01/17	P	S	0.06 P	>300 P	0.05 P	<0.10 P	S	S	S
SNOW / CONFETTI SUPERSTAR MACHINE (FAN STYLE)	LA15149	10/01/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34853	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.78 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34854	05/01/17	P	S	0.05 P	>300 P	0.05 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37978	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37443	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37440	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37442	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37977	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37548	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37541	05/01/17	P	S	0.08 P	>300 P	0.05 P	0.81 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37546	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37543	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.78 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37549	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37542	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.79 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37982	05/01/17	P	S	0.03 P	>300 P	0.06 P	0.80 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOLARIS FLARE RGBW LED STROBE	LA37975	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37985	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.78 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37983	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.78 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37984	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37979	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.79 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37467	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.79 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37441	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37976	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37980	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.86 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37981	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37547	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34844	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34848	05/01/17	P	S	0.06 P	>300 P	0.05 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34847	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38428	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38429	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34845	05/01/17	P	S	0.07 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34852	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.75 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34849	05/01/17	P	S	0.08 P	>300 P	0.05 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34850	05/01/17	P	S	0.08 P	55.96 P	0.06 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34846	05/01/17	P	S	0.04 P	>300 P	0.05 P	0.78 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34851	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38424	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.78 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38425	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.79 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38420	05/01/17	P	S	0.04 P	>300 P	0.05 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37544	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.71 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37545	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.78 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38426	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38430	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38427	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.75 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38423	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.78 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38421	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38422	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.76 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37946	05/01/17	P	S	0.04 P	>300 P	0.06 P	0.81 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37944	05/01/17	P	S	0.06 P	>300 P	0.06 P	0.81 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37947	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37945	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.78 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOLARIS FLARE RGBW LED STROBE	LA37986	05/01/17	P	S	0.05 P	>300 P	0.06 P	0.80 P	S	S	S
SOURCE 4 PARNEL	LA04204	09/01/17	P	S	0.05 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA04203	09/01/17	P	S	0.05 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA34062	09/01/17	P	S	0.03 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA04206	09/01/17	P	S	0.03 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01974	09/01/17	P	S	0.02 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01973	09/01/17	P	S	0.02 P	>300 P	0.81 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01625	09/01/17	P	S	0.02 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01971	09/01/17	P	S	0.02 P	>300 P	0.81 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01972	09/01/17	P	S	0.03 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16790	09/01/17	P	S	0.03 P	92.71 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16786	09/01/17	P	S	0.03 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16787	09/01/17	P	S	0.03 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16791	09/01/17	P	S	0.03 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01613	09/01/17	P	S	0.03 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16789	09/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16788	09/01/17	P	S	0.03 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA31488	09/01/17	P	S	0.05 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA31489	09/01/17	P	S	0.03 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01626	09/01/17	P	S	0.03 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01628	09/01/17	P	S	0.04 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01624	09/01/17	P	S	0.05 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01623	09/01/17	P	S	0.03 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01618	09/01/17	P	S	0.02 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01617	09/01/17	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01616	09/01/17	P	S	0.04 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01621	09/01/17	P	S	0.04 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01614	09/01/17	P	S	0.05 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01615	09/01/17	P	S	0.04 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01627	09/01/17	P	S	0.05 P	>300 P	0.76 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01622	09/01/17	P	S	0.02 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01620	09/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01619	09/01/17	P	S	0.02 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA31487	09/01/17	P	S	0.06 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16142	09/01/17	P	S	0.04 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24034	06/01/17	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA04524	06/01/17	P	S	0.03 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16146	06/01/17	P	S	0.04 P	>300 P	0.81 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16140	06/01/17	P	S	0.04 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24030	06/01/17	P	S	0.06 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24029	06/01/17	P	S	0.04 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16566	09/01/17	P	S	0.05 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24464	06/01/17	P	S	0.06 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24465	09/01/17	P	S	0.07 P	>300 P	0.62 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA15104	06/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24032	09/01/17	P	S	0.04 P	>300 P	0.76 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA31483	09/01/17	P	S	0.06 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA31484	09/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA31485	06/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24031	06/01/17	P	S	0.05 P	113.00 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA04770	06/01/17	P	S	0.04 P	119.70 P	0.83 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24033	09/01/17	P	S	0.06 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16567	09/01/17	P	S	0.06 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16010	06/01/17	P	S	0.03 P	>300 P	0.75 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16009	09/01/17	P	S	0.04 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16011	09/01/17	P	S	0.06 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA25051	06/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16580	09/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA25618	09/01/17	P	S	0.06 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24027	09/01/17	P	S	0.06 P	>300 P	0.75 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16582	06/01/17	P	S	0.05 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA25619	06/01/17	P	S	0.04 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA01961	06/01/17	P	S	0.05 P	54.83 P	0.89 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16014	09/01/17	P	S	0.06 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA01963	06/01/17	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16013	09/01/17	P	S	0.06 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16139	09/01/17	P	S	0.04 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA01935	06/01/17	P	S	0.03 P	>300 P	0.79 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOURCE 4 PROFILE BACK END	LA25114	06/01/17	P	S	0.03 P	164.70 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16579	09/01/17	P	S	0.04 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA20847	09/01/17	P	S	0.07 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16568	06/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA20267	06/01/17	P	S	0.05 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA20268	06/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA20841	09/01/17	P	S	0.04 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA01365	06/01/17	P	S	0.04 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24028	06/01/17	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA20840	09/01/17	P	S	0.09 P	>300 P	0.79 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21624	17/01/17	P	S	0.03 P	>300 P	2.00 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21631	17/01/17	P	S	0.03 P	>300 P	2.02 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21626	17/01/17	P	S	0.05 P	>300 P	2.03 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21192	17/01/17	P	S	0.04 P	>300 P	1.99 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21628	17/01/17	P	S	0.04 P	>300 P	2.00 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21629	17/01/17	P	S	0.03 P	>300 P	2.01 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21627	17/01/17	P	S	0.03 P	>300 P	2.00 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21625	17/01/17	P	S	0.04 P	>300 P	2.02 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21198	17/01/17	P	S	0.03 P	>300 P	2.00 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21630	17/01/17	P	S	0.09 P	>300 P	2.01 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21632	17/01/17	P	S	0.09 P	>300 P	2.00 P	<0.10 P	S	S	S
SUPER-NOVA 2K MOVING	LA37156	23/01/17	P	S	0.06 P	>300 P	0.05 P	0.47 P	S	S	S
SUPER-NOVA 2K MOVING	LA34750	23/01/17	P	S	0.03 P	>300 P	0.05 P	0.46 P	S	S	S
SUPER-NOVA 2K MOVING	LA34078	23/01/17	P	S	0.04 P	>300 P	0.05 P	0.45 P	S	S	S
SUPER-NOVA 2K MOVING	LA34081	23/01/17	P	S	0.04 P	>300 P	0.05 P	0.45 P	S	S	S
SUPER-NOVA 2K MOVING	LA34077	20/01/17	P	S	0.06 P	>300 P	0.05 P	0.42 P	S	S	S
SUPER-NOVA 2K MOVING	LA34079	20/01/17	P	S	0.08 P	>300 P	0.05 P	0.44 P	S	S	S
SUPER-NOVA 2K MOVING	LA34080	20/01/17	P	S	0.07 P	>300 P	0.05 P	0.44 P	S	S	S
SUPER-NOVA 2K MOVING	LA34082	20/01/17	P	S	0.09 P	>300 P	0.05 P	0.46 P	S	S	S
TFT MONITOR 17``	LA26027	16/01/17	P	S	0.07 P	>300 P	S	S	S	S	S
TFT MONITOR 17``	LA24823	12/01/17	P	S	0.08 P	>300 P	S	S	S	S	S
TFT MONITOR 17``	LA26028	03/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA31157	12/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA25365	12/01/17	P	S	0.06 P	>300 P	S	S	S	S	S
THOMAS 1000W CYC UNIT	LA24047	09/01/17	P	S	0.02 P	>300 P	1.03 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24045	09/01/17	P	S	0.08 P	>300 P	1.02 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24044	09/01/17	P	S	0.02 P	>300 P	1.04 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24043	09/01/17	P	S	0.02 P	>300 P	1.02 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24048	09/01/17	P	S	0.02 P	>300 P	1.03 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24046	09/01/17	P	S	0.02 P	>300 P	1.03 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24035	09/01/17	P	S	0.02 P	>300 P	1.01 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24040	09/01/17	P	S	0.02 P	>300 P	1.02 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24036	09/01/17	P	S	0.02 P	>300 P	1.01 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24037	09/01/17	P	S	0.02 P	>300 P	1.01 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24039	09/01/17	P	S	0.02 P	>300 P	1.04 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24042	09/01/17	P	S	0.02 P	>300 P	1.03 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24041	09/01/17	P	S	0.02 P	>300 P	1.03 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24038	09/01/17	P	S	0.02 P	>300 P	1.02 P	<0.10 P	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA25962	10/01/17	P	S	0.08 P	>300 P	<0.05 P	0.20 P	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA24529	11/01/17	P	S	0.09 P	>300 P	<0.05 P	0.19 P	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA25961	31/01/17	P	S	0.08 P	>300 P	<0.05 P	0.20 P	S	S	S
TV ONE 4 WINDOW MULTI VIEWER	LA40269	12/01/17	P	S	0.05 P	>300 P	S	S	S	S	S
VARI*LITE VL3500 WASH FX	LA31905	19/01/17	P	S	0.04 P	>300 P	0.13 P	0.94 P	S	S	S
VARI*LITE VL3500 WASH FX	LA34949	19/01/17	P	S	0.05 P	>300 P	0.06 P	0.95 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31464	19/01/17	P	S	0.05 P	294.50 P	0.06 P	0.94 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31863	19/01/17	P	S	0.05 P	>300 P	0.13 P	0.89 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
VARI*LITE VL3500 WASH FX	LA31867	19/01/17	P	S	0.04 P	>300 P	0.06 P	0.89 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31461	19/01/17	P	S	0.05 P	>300 P	0.06 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31904	19/01/17	P	S	0.05 P	>300 P	0.13 P	0.93 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31460	19/01/17	P	S	0.04 P	>300 P	0.06 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31864	19/01/17	P	S	0.05 P	>300 P	0.13 P	0.94 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31865	19/01/17	P	S	0.06 P	>300 P	0.06 P	0.89 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31906	19/01/17	P	S	0.04 P	>300 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31907	19/01/17	P	S	0.04 P	>300 P	0.13 P	0.93 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31871	19/01/17	P	S	0.05 P	>300 P	<0.05 P	0.28 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31872	19/01/17	P	S	0.04 P	>300 P	0.06 P	0.94 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31866	19/01/17	P	S	0.04 P	>300 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31870	19/01/17	P	S	0.05 P	>300 P	0.06 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31463	19/01/17	P	S	0.06 P	>300 P	0.06 P	0.94 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31462	19/01/17	P	S	0.05 P	>300 P	0.06 P	0.91 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31901	19/01/17	P	S	0.04 P	>300 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31908	19/01/17	P	S	0.06 P	207.50 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31869	19/01/17	P	S	0.04 P	43.92 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31909	19/01/17	P	S	0.05 P	>300 P	0.07 P	0.94 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31903	19/01/17	P	S	0.08 P	>300 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31868	19/01/17	P	S	0.04 P	>300 P	0.13 P	0.92 P	S	S	S
WHOLE HOG DP 8000	LA37374	10/01/17	P	S	0.08 P	S	<0.05 P	0.27 P	S	S	S
WHOLE HOG DP 8000	LA37912	23/01/17	P	S	0.07 P	S	<0.05 P	0.26 P	S	S	S
WHOLE HOG DP 8000	LA38055	10/01/17	P	S	0.06 P	S	<0.05 P	0.29 P	S	S	S
WHOLE HOG DP 8000	LA38056	03/01/17	P	S	0.09 P	S	<0.05 P	0.30 P	S	S	S
WHOLE HOG DP 8000	LA31394	11/01/17	P	S	0.08 P	S	<0.05 P	0.27 P	S	S	S
WHOLE HOG DP 8000	LA31001	11/01/17	P	S	0.09 P	S	<0.05 P	0.26 P	S	S	S
WHOLE HOG DP 8000	LA31336	11/01/17	P	S	0.06 P	S	<0.05 P	0.27 P	S	S	S
WHOLE HOG DP 8000	LA38290	23/01/17	P	S	0.07 P	S	<0.05 P	0.26 P	S	S	S
WHOLE HOG DP 8000	LA38289	10/01/17	P	S	0.07 P	S	<0.05 P	0.28 P	S	S	S
WHOLE HOG DP 8000	LA31396	11/01/17	P	S	0.07 P	S	<0.05 P	0.27 P	S	S	S
WHOLE HOG DP 8000	LA37158	10/01/17	P	S	0.07 P	S	<0.05 P	0.30 P	S	S	S
WHOLE HOG DP 8000	LA38520	10/01/17	P	S	0.07 P	S	<0.05 P	0.29 P	S	S	S
WHOLE HOG DP 8000	LA38365	11/01/17	P	S	0.08 P	S	<0.05 P	0.27 P	S	S	S
WHOLE HOG DP 8000	LA38364	11/01/17	P	S	0.07 P	S	<0.05 P	0.27 P	S	S	S
WHOLE HOG DP 8000	LA38288	10/01/17	P	S	0.07 P	S	<0.05 P	0.28 P	S	S	S
WHOLE HOG DP 8000	LA37157	10/01/17	P	S	0.08 P	S	<0.05 P	0.29 P	S	S	S
WHOLE HOG DP 8000	LA38287	10/01/17	P	S	0.06 P	S	<0.05 P	0.28 P	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA31664	25/01/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA31663	25/01/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22940	25/01/17	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22942	25/01/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22941	25/01/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22945	25/01/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22944	25/01/17	P	S	0.09 P	>300 P	<0.05 P	0.13 P	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22943	25/01/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
WIRELESS SOLUTIONS W-DMX S-1 TRANSMITTER	LA22938	25/01/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
WIRELESS SOLUTIONS W-DMX S-1 TRANSMITTER	LA22939	25/01/17	P	S	0.07 P	>300 P	<0.05 P	0.12 P	S	S	S

Total Appliances: 1,870
Total Appliances For Report: 5,908