

**Report Of Passed Appliances  
For all Sites and Locations**

Lite Alternative LTD  
Unit 4  
Duttons Way  
Shadsworth Business Park  
Blackburn  
Lancashire  
BB1 2QR  
Phone: 01254 279 654

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
<b>LA -</b>											
1000W HALOGON FLOOD WORK LIGHT	LA20023	19/12/19	P	S	0.07 P	>300 P	1.00 P	<0.10 P	S	S	S
1000W HALOGON FLOOD WORK LIGHT	LA20021	19/12/19	P	S	0.08 P	>300 P	1.02 P	<0.10 P	S	S	S
100W LED FLOOD WORK LIGHT	LA38332	23/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
100W LED FLOOD WORK LIGHT	LA38017	23/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
100W LED FLOOD WORK LIGHT	LA38016	23/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
100W LED FLOOD WORK LIGHT	LA41589	23/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
100W LED FLOOD WORK LIGHT	LA38334	23/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
100W LED FLOOD WORK LIGHT	LA38333	23/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
120MM CAMLOCK - POWERLOCK 3M ADAPTOR	LA30903	20/12/19	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 10M	LA30896	07/01/20	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 3M	LA30898	21/01/20	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 3M	LA17069	20/12/19	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 3M	LA30899	21/01/20	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 5M	LA30900	07/01/20	S	S	S	S	S	S	S	S	S
120MM POWERLOCK LUG - EARTH	LA33552	24/01/20	S	S	S	S	S	S	S	S	S
120MM POWERLOCK LUG 3M	LA30902	20/12/19	S	S	S	S	S	S	S	S	S
120MM POWERLOCK TAILS 3M	LA30901	20/12/19	S	S	S	S	S	S	S	S	S
125A 1PH - 63A 1PH ADAPTOR	LA30758	21/01/20	S	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA32364	22/01/20	S	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA42567	22/01/20	S	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA22278	22/01/20	S	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA42566	21/01/20	S	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA00955	22/01/20	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA20304	19/12/19	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA33550	09/01/20	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA42864	17/12/19	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA22101	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA21508	17/12/19	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA39165	18/12/19	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA17150	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA32470	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA35101	13/12/19	S	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA22670	13/12/19	S	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA26975	17/12/19	S	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA37824	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA32469	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA30797	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH LUGGED TAILS	LA22672	13/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
125A 3PH LUGGED TAILS	LA21061	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH LUGGED TAILS	LA35174	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH LUGGED TAILS	LA32468	17/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA33637	13/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA42769	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA22668	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA33646	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA32463	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA30798	13/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA39008	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA39024	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA32462	13/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA22669	13/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA30799	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 3M	LA22667	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 3M	LA42741	10/01/20	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA42751	10/01/20	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA22666	17/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA32464	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA42715	12/12/19	S	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA39064	13/12/19	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32195	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32194	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32193	10/02/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32199	17/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33607	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33605	12/02/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32201	22/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36138	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36140	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30297	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36137	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30298	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36135	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36136	22/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33608	28/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36133	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33622	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33621	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA35122	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33624	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA34556	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA35090	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33612	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33611	30/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33609	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33613	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33619	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33615	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33614	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26219	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA25458	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26221	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26316	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26229	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA42211	10/02/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA42826	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA17889	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA25158	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA24548	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26704	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30292	12/02/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30291	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30295	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA42822	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30296	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26707	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26761	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26854	14/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
13A - 16A 1PH ADAPTER 0.5M	LA30288	14/01/20	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26966	17/01/20	S	S	S	S	S	S	S	S	S
13A - IEC ADAPTOR	LA24503	17/01/20	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26502	11/02/20	S	S	S	S	S	S	S	S	S
16A - POWERCON ADAPTOR	LA35136	14/01/20	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA15347	20/01/20	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA15909	20/01/20	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA15911	20/01/20	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA02704	20/01/20	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA15343	20/01/20	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA02699	17/01/20	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA02703	20/01/20	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA15356	17/01/20	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA15355	17/01/20	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA15348	17/01/20	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA16241	17/01/20	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA17890	17/01/20	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA24552	17/01/20	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA16242	17/01/20	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA16245	17/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA34522	10/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA34396	10/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA33559	07/02/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA38553	10/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA35138	10/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA35104	10/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA44380	10/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA44379	22/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA44381	22/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA44388	10/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA44386	10/01/20	S	S	S	S	S	S	S	S	S
16A 110V MOTOR PICKLE	LA46031	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37702	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37777	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37778	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37698	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37697	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37700	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37699	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37780	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37779	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37784	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37782	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37787	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37788	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37785	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37786	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37654	17/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - 4 X 13A RUBBER BOX	LA37652	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37650	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37655	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37696	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37695	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37694	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 2 WAY PLUGBOARD	LA16947	12/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA32091	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA42214	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA32081	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA20496	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA20501	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA17500	12/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA25901	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA38131	23/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA16424	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA17262	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 15A 1PH ADAPTOR	LA17219	11/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA15802	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA17029	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA40312	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA15517	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA33334	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA33335	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA17662	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - 6 X 13A / 1 X 16A 1PH RUBBER BOX	LA37109	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26748	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26745	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26749	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26750	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26743	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26744	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26740	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26742	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32738	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA26708	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25913	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25804	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA26709	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32737	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32736	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32735	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32745	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32744	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA35134	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32746	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32741	17/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - EDISON (US) FEMALE 0.5M	LA32739	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32743	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32742	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25173	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25174	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25171	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25172	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25802	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25803	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25175	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25177	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M ADAPTOR	LA25805	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24150	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24216	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24218	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17666	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17570	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24149	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17829	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA26304	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24798	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24526	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA30881	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA33936	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA35100	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA34086	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17567	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17264	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17183	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17034	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17292	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17566	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17476	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17357	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC 2 WAY SPLITTER	LA33934	18/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC 2 WAY SPLITTER	LA46648	30/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC 2 WAY SPLITTER	LA40277	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC 2 WAY SPLITTER	LA46659	30/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC 2 WAY SPLITTER	LA37621	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC 2 WAY SPLITTER	LA37622	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - IEC 4 WAY SPLITTER	LA37280	18/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32010	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32018	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32008	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32015	11/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32017	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32011	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32012	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30872	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30876	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26995	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30870	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30884	17/02/20	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
16A 1PH - IEC ADAPTOR	LA31614	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30877	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30882	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32020	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26303	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30880	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA42903	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26218	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA31880	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA35098	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33928	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33932	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32027	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33927	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32024	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32026	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA35095	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24362	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA34245	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA34558	17/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24557	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24821	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24215	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24299	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25408	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25410	11/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24937	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25390	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA16545	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA16872	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA21593	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24025	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24026	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24022	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA17480	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA21634	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24356	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26857	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26920	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26517	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26526	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26991	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26994	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26935	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26990	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25892	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25899	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25624	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25891	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26512	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26514	18/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26506	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26509	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33935	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26413	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA42096	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - IEC ADAPTOR	LA33933	03/03/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38917	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38916	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38923	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38918	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38915	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38911	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38910	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38914	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38913	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38925	24/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39258	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39257	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39283	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39281	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39256	11/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38928	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38927	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38930	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38929	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38900	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38899	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38901	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38891	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38898	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38894	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38893	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38897	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38896	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38902	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38888	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38906	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38909	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38908	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38905	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38904	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38903	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON	LA38889	14/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA38890	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39499	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39498	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39504	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39501	17/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39497	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39494	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39493	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39496	03/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39495	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39505	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39515	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39514	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39518	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39516	18/12/19	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39512	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39508	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39507	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39511	03/03/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40334	09/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39299	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39296	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39302	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39301	13/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39295	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39286	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39285	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39289	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39288	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39303	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39320	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39319	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39491	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39470	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39311	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39307	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39304	15/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39309	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39308	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38887	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33810	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33675	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33815	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33812	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33670	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33603	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33602	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33668	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33667	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33816	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33825	13/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33824	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33827	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33826	03/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33823	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33818	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33817	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33820	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33819	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33581	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33580	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33583	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33582	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33579	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33564	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33547	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33577	12/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33575	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33584	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33598	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33597	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33601	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40362	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33593	15/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39878	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33585	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33592	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33591	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35609	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35608	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35611	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35610	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35607	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35078	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35077	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35605	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35089	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35612	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38884	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38883	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38886	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38885	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38882	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35614	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35613	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38881	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA42161	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33835	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33834	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33838	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33836	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33833	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33829	03/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33828	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33832	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33831	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33839	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35028	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35027	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35049	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35030	15/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA35016	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33842	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33840	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35013	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35012	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39519	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40234	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40231	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40236	23/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40235	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40230	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40226	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40218	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40228	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40227	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40327	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA42167	03/03/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46676	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46684	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46677	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40355	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40330	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40329	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40340	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40335	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39631	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39630	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39633	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39632	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39629	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39625	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39624	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39628	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39626	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39635	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39817	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39802	12/02/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39828	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39822	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39779	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39637	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39636	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39777	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39638	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40341	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40354	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39313	03/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40348	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40358	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36293	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36294	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40374	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40331	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26753	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40364	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39877	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30674	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33223	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39847	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40359	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40345	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40349	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40343	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39312	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39314	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30707	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39316	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39610	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46678	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46685	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38926	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46679	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39642	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36297	03/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA36298	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36295	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36296	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36299	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36304	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39590	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36300	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36303	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39622	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39553	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39552	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39555	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39554	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39551	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39546	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39545	11/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39550	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39549	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39556	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39564	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39563	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39566	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39565	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39561	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39558	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39557	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39560	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39559	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39532	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39530	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39534	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39533	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39529	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39525	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39524	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39528	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39527	15/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39535	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39542	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39541	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39544	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39543	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39540	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39537	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39536	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39539	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39538	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39607	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39606	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39609	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39608	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39605	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39598	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39597	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39603	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39599	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39611	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39619	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39617	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39621	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39620	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39616	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39613	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39612	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39615	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39614	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39581	09/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39579	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39583	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39582	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39578	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39571	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39569	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39577	15/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39575	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39585	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39594	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39593	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39596	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39595	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39592	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39587	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39586	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39591	24/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39589	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33240	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26247	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26249	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26244	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26246	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26251	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26352	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26618	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26253	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26324	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26107	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25806	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25807	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40333	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25612	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25808	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26104	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26105	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25867	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26102	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26932	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26951	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26728	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26793	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30667	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30672	05/02/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA30676	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30668	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30669	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26722	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26621	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26622	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26619	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26620	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26623	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26683	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26712	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26673	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26677	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA24082	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40353	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40346	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46674	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39851	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39774	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46675	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39848	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46672	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39849	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33814	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39845	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39867	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39490	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39846	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46652	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39601	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33548	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39835	31/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA41429	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17574	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17580	03/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46681	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46683	27/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA17745	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17972	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA24076	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40344	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17969	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46682	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39844	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46673	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39868	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39866	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39862	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46686	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA46687	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39869	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39865	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30678	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32784	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32786	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32781	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32783	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32787	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33199	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33202	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32790	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33197	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32778	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32335	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32338	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32333	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32334	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32339	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32776	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32777	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32771	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32774	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33239	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33235	15/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA33222	03/03/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33224	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33234	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33230	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33226	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33233	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33231	17/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33220	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33210	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33211	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33204	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33206	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33212	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33218	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33219	17/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33213	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33216	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32332	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30720	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA31881	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30718	13/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30719	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32250	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32255	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32257	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32251	05/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32253	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30691	18/02/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30686	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30713	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30681	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30711	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30715	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30704	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30696	15/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30687	03/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30710	05/02/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON	LA32323	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32324	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32320	14/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32322	14/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32331	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32330	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32328	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32326	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32327	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32319	14/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32311	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32262	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32263	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32309	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32314	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32317	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32318	15/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32260	05/02/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON	LA32315	14/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR											
16A 1PH - POWERCON TRUE	LA42219	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35623	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40372	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40281	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40282	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42115	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46663	29/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40279	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40280	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42181	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46019	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46040	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46025	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46037	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46044	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46048	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46046	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42173	05/02/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA42172	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42133	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42197	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42174	12/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42178	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42177	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42182	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46649	10/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35033	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35053	12/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35054	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35032	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35017	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35018	12/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35026	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46005	16/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35059	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35060	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35056	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39297	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA46018	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35055	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33802	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33806	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33807	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42110	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33799	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42113	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33800	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42114	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34792	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35014	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34780	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33808	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34778	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34779	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42191	15/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA32382	22/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32381	07/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32380	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32383	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32608	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40256	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32607	20/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32379	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32372	20/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32371	07/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32370	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32374	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32377	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32376	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32375	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44240	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44222	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44233	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44238	22/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44203	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44214	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44248	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39741	03/03/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32612	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32611	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32609	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32613	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32616	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32615	22/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32614	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32369	21/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44242	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44244	20/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44229	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44246	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44217	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44202	22/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA44205	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44213	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44221	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44207	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44218	21/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44247	17/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44201	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44241	21/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44219	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44235	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44208	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44204	22/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44225	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44228	22/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44226	07/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44227	20/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44215	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44224	20/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44236	21/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44216	18/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44223	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44239	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44237	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA44230	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39764	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39766	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39763	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39761	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39762	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39767	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39771	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39772	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39770	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39768	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39769	11/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39760	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39745	05/02/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA39746	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39743	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39737	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39738	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39750	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39757	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39758	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39756	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39753	16/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39755	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40237	11/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40260	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40261	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40257	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40254	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40255	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40262	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40266	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42159	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40265	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40263	03/03/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40264	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40252	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40241	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40242	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40240	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40238	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40239	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40243	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40250	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40251	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40249	21/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40246	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40247	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39705	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39706	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39707	14/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA35624	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39703	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39704	17/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39711	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39712	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39713	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39709	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39710	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39819	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35622	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35066	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35067	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35068	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35062	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35063	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35064	12/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35072	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35620	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35621	29/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35069	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35070	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35071	07/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39728	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39730	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39727	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39725	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39726	14/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35061	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39736	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39735	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39731	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39733	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39719	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39720	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39717	05/02/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39718	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39714	15/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA39723	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39722	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39721	15/01/20	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - SHUKO ADAPTOR	LA30208	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30207	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA35110	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30210	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30202	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA17489	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA17491	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30206	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30204	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30203	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER	LA25184	13/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA25187	13/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA16959	12/02/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA17138	13/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA16920	13/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA25194	13/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA26986	13/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA16919	13/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA25192	13/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA38524	13/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA42199	27/01/20	S	S	S	S	S	S	S	S	S
GEWISS											
16A 1PH 2 WAY SPLITTER	LA17278	13/01/20	S	S	S	S	S	S	S	S	S
RUBBER BOX											
16A 1PH 2 WAY SPLITTER	LA17276	13/01/20	S	S	S	S	S	S	S	S	S
RUBBER BOX											
16A 1PH 2 WAY SPLITTER	LA17279	13/01/20	S	S	S	S	S	S	S	S	S
RUBBER BOX											
16A 1PH 2 WAY SPLITTER	LA17258	13/01/20	S	S	S	S	S	S	S	S	S
RUBBER BOX											
16A 1PH 2 WAY SPLITTER	LA26739	13/01/20	S	S	S	S	S	S	S	S	S
RUBBER BOX											
16A 1PH 2 WAY SPLITTER	LA17280	12/02/20	S	S	S	S	S	S	S	S	S
RUBBER BOX											
16A 1PH 2 WAY SPLITTER	LA37061	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA42194	13/02/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA40294	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA37055	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA37057	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA35139	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA42189	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA42187	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA42185	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA42127	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											
16A 1PH 2 WAY SPLITTER	LA35086	13/01/20	S	S	S	S	S	S	S	S	S
T-LINE											

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH 2 WAY SPLITTER T-LINE	LA42192	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA32050	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37065	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37067	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37064	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37062	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37063	13/02/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35958	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26911	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26904	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26898	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26902	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33555	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35957	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33554	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33306	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33549	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35959	19/02/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35960	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33561	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33556	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33557	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35961	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26289	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26896	07/02/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26285	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35963	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35965	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34959	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34958	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34960	13/02/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34963	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34962	12/02/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA42205	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA42190	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35020	12/02/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34955	13/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH 2 WAY SPLITTER Y-CORD	LA34954	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34964	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35951	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35948	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35952	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA40291	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35955	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35160	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35159	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35163	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35947	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35946	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA42154	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA42175	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA37174	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA25110	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA25108	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16974	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA17240	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA37182	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA00588	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16882	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16973	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16967	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16876	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16875	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16877	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25976	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25845	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25839	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25843	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA26062	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30187	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA38591	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30189	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA39167	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30183	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30184	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30186	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30185	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32703	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39078	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39077	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32452	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39079	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39086	07/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA39084	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39080	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32453	04/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32698	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32700	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32702	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32697	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32455	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32456	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32696	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25083	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25082	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25081	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25196	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25208	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25199	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25197	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25080	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24861	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24858	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24857	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24942	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25079	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25065	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25050	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32709	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39076	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39075	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32708	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32704	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32705	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32706	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39074	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26110	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26048	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25903	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26299	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39073	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39072	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39071	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39477	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40131	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40130	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40129	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40132	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40135	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40134	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40133	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40128	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40123	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40122	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40121	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40124	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40127	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40126	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40125	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40136	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40147	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40146	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40145	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40148	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40151	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40150	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40149	19/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40144	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40139	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40138	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40137	04/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40140	08/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA40143	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40142	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40141	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32172	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32449	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32451	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32171	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40107	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39662	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39661	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39660	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39655	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39654	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39653	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39656	12/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39659	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39658	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39657	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40108	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40116	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26573	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26572	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40117	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40120	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40119	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40118	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26570	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40111	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40110	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40109	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40112	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40115	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40114	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40113	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24855	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35842	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35844	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35845	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35839	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35840	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35841	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35846	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35850	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35853	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35855	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35847	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35848	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35849	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35838	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35441	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35442	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35443	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35436	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35438	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35440	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35444	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35448	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35835	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35837	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35445	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35446	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35447	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38970	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35858	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35860	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38973	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38972	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38971	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38969	07/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA35863	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38965	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38966	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38968	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35861	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35862	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38974	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39069	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38984	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38983	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35856	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35857	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39070	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38982	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38978	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38977	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38976	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38981	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38980	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38979	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35435	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17835	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17293	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17131	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17848	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17843	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17837	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17098	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA16895	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15960	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15950	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17096	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42631	13/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42620	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24109	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24599	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24598	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24596	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24853	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24852	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24709	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24592	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24114	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24112	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24111	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24589	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24522	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24506	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33277	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33278	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33279	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42625	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33273	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33274	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33281	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35431	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35432	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35434	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33282	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA34219	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35430	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42626	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32714	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32710	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33276	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA04701	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA04329	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA04080	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39082	23/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA32713	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42629	10/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42630	10/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39083	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32711	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32712	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30612	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30613	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30614	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30611	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30609	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32167	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30610	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30615	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30616	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30617	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30618	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32163	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32166	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32165	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32164	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17094	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42628	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17089	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30607	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26703	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26640	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26585	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA16931	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15417	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30608	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26637	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26586	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17687	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA16929	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15419	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30619	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32154	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32155	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32156	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39085	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26639	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32152	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA16933	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32157	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32161	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32160	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32159	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32162	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26638	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32458	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32158	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30624	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30625	10/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30626	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30623	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30620	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30621	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30622	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30627	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32148	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32150	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32151	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32147	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32144	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32145	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32146	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42294	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30583	07/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA30584	23/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30591	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30258	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30578	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30586	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30590	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30012	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30592	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30587	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30588	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30589	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30252	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30251	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30250	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30257	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30255	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30254	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30249	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30015	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30014	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30013	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30020	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30019	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30016	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30593	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26578	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42617	11/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26574	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30008	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26705	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32168	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26575	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26956	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32170	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32169	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39088	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30007	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30002	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30010	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30597	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30599	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30600	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30594	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26583	23/12/19	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30595	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26582	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30605	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30604	13/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30601	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30603	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32131	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32134	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32133	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32132	11/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32142	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24884	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32138	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32141	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32140	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24885	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32136	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32135	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25059	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25057	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32137	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32114	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32113	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30212	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30211	07/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA30056	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30057	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30058	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30828	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30829	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30215	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30218	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30213	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30214	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30219	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32115	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32126	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32125	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32123	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32127	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32130	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32129	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32128	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA16509	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32117	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32116	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32119	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32122	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32121	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32120	31/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39993	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39994	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39995	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39990	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39991	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39992	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30053	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30052	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38995	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30054	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38989	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA46729	13/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39989	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39980	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39981	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39982	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39977	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39978	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39979	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39986	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39987	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39988	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39983	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39984	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39985	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30051	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26047	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26043	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25912	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26411	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26301	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26049	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25087	04/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25086	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25085	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25824	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25212	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25180	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26589	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26602	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26601	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26600	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26985	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26718	07/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA46722	10/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26594	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26593	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26590	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26598	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26597	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26595	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39976	07/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33292	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA34218	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35451	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33288	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33289	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33290	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35455	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35456	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35457	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35452	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35453	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35454	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33287	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32726	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32727	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32729	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32721	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32724	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32725	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33284	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33285	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33286	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32730	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32731	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32732	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35458	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35871	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35872	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35873	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35868	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35869	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35870	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38997	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38999	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39004	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38985	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38986	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38987	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35867	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35463	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35464	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35465	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35459	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35460	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35461	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35864	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35865	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35866	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35466	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35468	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35469	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17864	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17863	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17860	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17867	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24204	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24102	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24099	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17858	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA16058	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15999	21/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA15986	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17080	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17854	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17494	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17474	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24205	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30263	11/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30264	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30265	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30261	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30222	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30259	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30260	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30266	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24561	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24210	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24208	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24564	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30268	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24567	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24565	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04242	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA02583	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24869	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04254	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30818	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30820	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30821	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24870	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24875	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38994	27/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24881	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24872	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26641	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24871	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04390	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30816	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15430	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30810	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30811	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15431	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15974	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15446	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15445	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30812	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38992	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30814	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30815	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04255	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38998	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04391	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30813	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30221	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24576	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30825	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA16503	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30822	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30823	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24868	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24883	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24867	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30826	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA42201	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24568	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24571	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24569	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30062	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25091	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30061	07/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 30FT	LA26609	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25090	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26035	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26607	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26041	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26039	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26036	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26608	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26037	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35883	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24998	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25000	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25001	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24997	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24092	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42193	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24995	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25063	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30357	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25064	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25062	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25004	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42589	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42160	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30064	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35489	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30225	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30228	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35488	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35881	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42597	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35487	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30833	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30838	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30837	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30836	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30839	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30834	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35880	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35879	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30076	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30078	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35485	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30075	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30065	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30066	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30074	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30079	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30353	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30081	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30223	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35884	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30230	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30229	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35486	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35470	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA34715	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33913	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35876	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35475	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35473	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33912	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35886	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33908	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30830	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33911	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33910	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33909	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35477	21/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 30FT	LA35892	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35891	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35889	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30226	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30832	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42596	28/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30831	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35481	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35480	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35479	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35484	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35483	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35482	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42595	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30232	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42590	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33297	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35875	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30354	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35878	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35885	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30233	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA15463	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA15466	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24089	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33298	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42592	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42591	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA01224	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35888	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33300	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33299	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33907	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35874	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33302	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33294	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33293	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30355	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33301	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33296	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33295	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA15480	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA17496	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA15493	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30843	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30844	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30845	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30842	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30360	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30363	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30841	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33915	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33916	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33917	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33914	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30847	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30848	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30849	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA02858	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30120	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30119	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA02615	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30128	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30239	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30237	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30242	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30243	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30246	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30241	07/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 50FT	LA30070	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30068	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30240	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35497	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35498	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35499	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24265	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA25905	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35496	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24896	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30125	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30123	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24263	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30126	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA39027	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA39028	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA16122	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33925	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33926	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35491	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33922	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33918	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33919	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33921	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30067	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA26612	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA26611	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35495	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35492	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35493	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35494	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30043	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30026	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30025	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30024	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30029	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30028	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30027	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30022	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26565	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26564	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26636	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30021	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26953	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26566	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33270	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30042	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30041	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA42333	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA42330	10/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA42318	10/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30039	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30034	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30033	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30031	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30038	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30037	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30035	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40058	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40059	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40060	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39974	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39975	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40057	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40064	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40065	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40066	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40061	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40062	06/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA40063	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39973	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39649	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39650	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39651	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39646	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39647	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39648	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39969	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39970	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39972	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39652	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39967	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39968	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40083	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40085	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40086	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40080	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40081	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40082	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40091	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40092	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40093	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40087	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40088	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40090	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40079	14/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40070	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40071	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40072	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40067	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40068	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40069	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40076	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40077	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40078	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40073	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40074	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40075	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35817	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35819	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35820	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35814	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35815	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35816	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35824	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35825	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35826	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35821	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35822	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35823	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35813	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35803	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35804	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35805	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35797	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35799	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35802	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35809	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35810	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35812	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35806	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35807	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35808	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38956	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38958	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38961	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38952	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38953	06/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA38955	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39643	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39644	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39645	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38964	29/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39472	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39478	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38951	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35831	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35832	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35833	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35827	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35828	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35829	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38948	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38949	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38950	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38945	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38946	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38947	07/02/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40094	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24614	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24615	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24617	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24610	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24611	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA42322	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24816	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24826	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24827	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24618	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24641	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24780	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24608	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24125	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24127	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24453	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17294	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24120	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24123	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24602	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24605	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24607	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24510	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24511	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24601	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25069	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25070	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25072	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24844	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25067	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25068	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26561	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA42291	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26614	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25073	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25074	16/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25075	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24842	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24832	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24833	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24834	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24828	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24830	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24831	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24837	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24839	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24840	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26563	07/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA26562	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24835	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26480	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26109	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25206	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA04553	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA04736	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26558	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33784	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38962	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25126	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25149	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25148	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA04740	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA02419	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40098	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40099	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40100	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40095	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40096	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40097	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40104	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40105	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40106	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40101	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40102	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40103	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16981	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16983	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16984	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16905	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16908	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16912	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17121	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17129	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17249	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17104	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17105	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17107	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16632	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15387	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15391	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15399	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25125	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15381	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15383	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16055	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16263	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16586	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15934	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15936	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15940	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30560	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30561	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30562	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30557	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30558	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30559	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30566	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30567	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30568	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30563	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30564	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30565	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30546	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30547	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30548	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30543	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30544	02/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA30545	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30553	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30555	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30556	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30549	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30550	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30551	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30569	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32182	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32184	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32185	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32178	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32179	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32180	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32189	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32190	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32191	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32186	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32187	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32188	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30573	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30574	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30575	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30570	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30571	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30572	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32174	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32176	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32177	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30577	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA31882	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32173	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30103	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30104	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30105	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30100	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30101	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30102	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30110	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30111	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30113	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30106	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30107	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30109	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26560	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40213	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26559	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30044	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30046	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30047	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30050	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30098	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30099	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA42305	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30048	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30049	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30114	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30345	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30347	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30348	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30342	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30343	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30344	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30540	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30541	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30542	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30350	13/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30537	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30539	02/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA30332	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30333	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30334	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30115	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30116	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30117	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30338	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30339	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30341	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30335	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30336	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30337	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32674	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32673	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32676	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32675	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32670	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32669	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32672	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32671	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32683	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32682	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33264	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32684	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32678	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32677	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32681	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32680	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32657	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32656	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32659	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32658	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32601	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32599	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32655	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32602	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32666	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32665	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32668	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32667	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32662	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32661	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32664	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32663	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33266	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35422	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35420	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35424	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35423	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35417	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35416	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35419	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35418	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35794	20/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35429	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35796	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35795	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35426	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35425	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35428	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35427	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33781	21/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33272	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34221	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33782	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33268	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33267	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33271	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33269	06/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA35413	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35412	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35415	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35414	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34588	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34543	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35411	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35410	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32507	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32508	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32509	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32448	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32445	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32446	22/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32447	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32516	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32593	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32594	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32514	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32510	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32511	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32513	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32444	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32433	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32435	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32436	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32432	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32192	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32429	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32431	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32441	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32442	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32443	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32440	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32437	07/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32438	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32439	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32596	08/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32595	06/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32598	02/01/20	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32597	07/01/20	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA15912	20/01/20	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA02695	20/01/20	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA15339	20/01/20	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA16211	20/01/20	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA16212	20/01/20	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA16207	20/01/20	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA16209	20/01/20	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA02694	20/01/20	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA16556	17/01/20	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA16345	17/01/20	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA16243	17/01/20	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA17347	17/01/20	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA24468	17/01/20	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA24471	17/01/20	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA17348	17/01/20	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA24466	17/01/20	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA15917	20/01/20	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA15916	20/01/20	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA15915	20/01/20	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA16215	20/01/20	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA26783	20/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 30FT 110V TRS	LA17670	20/01/20	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA16216	20/01/20	S	S	S	S	S	S	S	S	S
16A 3PH (4 PIN) - 2 X 16A 3PH (4 PIN)	LA15621	13/01/20	S	S	S	S	S	S	S	S	S
16A 3PH (4 PIN) - 2 X 16A 3PH (4 PIN)	LA15622	13/01/20	S	S	S	S	S	S	S	S	S
16A 3PH (4 PIN) - 2 X 16A 3PH (4 PIN)	LA42975	13/01/20	S	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA22058	13/01/20	S	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA16707	19/02/20	S	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA17026	13/01/20	S	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA17025	13/01/20	S	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA16708	13/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 10M	LA33511	10/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 15M	LA33523	30/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA32367	10/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA32368	10/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA32366	10/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA42934	22/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA42937	10/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA32365	10/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA43150	22/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA43149	10/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA43151	11/02/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA42936	10/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA42935	10/01/20	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA43148	10/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA42358	04/02/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA42346	04/02/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA25764	20/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39229	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA42353	04/02/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA26933	20/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32837	20/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA33512	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32836	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39228	20/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32835	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39227	10/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32824	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32823	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32825	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32827	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32826	04/02/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32822	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA33507	09/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA17217	10/01/20	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA42354	04/02/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
10M											
16A 415V/110V MOTOR CABLE	LA15521	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA15522	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36268	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36276	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36275	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36270	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36271	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36263	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36273	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA00996	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36272	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36277	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36269	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36266	21/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA39225	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA39221	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA34706	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA42355	06/02/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA34698	20/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA39226	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36267	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36274	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA36265	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA42340	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA39222	21/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA32833	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA32832	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA33513	04/02/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA32834	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA32829	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA32828	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA32831	20/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA32830	09/01/20	S	S	S	S	S	S	S	S	S
10M											
16A 415V/110V MOTOR CABLE	LA46751	17/02/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA33522	04/02/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA33518	10/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA32347	10/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
15M											
16A 415V/110V MOTOR CABLE	LA33517	10/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA15524	10/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA32349	21/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA32348	20/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA32350	20/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA15523	10/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA33521	21/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA33516	20/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA38932	04/02/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA38931	20/01/20	S	S	S	S	S	S	S	S	S
15M											
16A 415V/110V MOTOR CABLE	LA36053	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32795	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32794	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32796	29/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32799	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32798	20/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32797	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36048	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36054	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36055	04/02/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36049	21/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36052	04/02/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36051	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36050	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA37772	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36047	31/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36046	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA33070	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA25771	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA33062	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA33065	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32802	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32801	20/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32800	04/02/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32803	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA33067	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA32805	09/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
2.5M											
16A 415V/110V MOTOR CABLE	LA32804	31/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36291	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36285	21/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA33545	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36280	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36289	20/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36282	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA33546	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36278	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA33063	04/02/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36283	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36279	29/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36288	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36292	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36290	09/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36281	20/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA36286	20/01/20	S	S	S	S	S	S	S	S	S
2.5M											
16A 415V/110V MOTOR CABLE	LA16163	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA15570	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA16158	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA42930	04/02/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA16159	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA39895	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA42933	04/02/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA36357	11/02/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA42932	04/02/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA39893	20/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA36355	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA39894	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA39900	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA36358	20/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA36356	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA30923	11/02/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA42939	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA30915	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA42938	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA42929	04/02/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
25M											
16A 415V/110V MOTOR CABLE	LA30916	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA30920	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA30922	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA30917	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA30918	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA00333	10/01/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA39896	04/02/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA42931	04/02/20	S	S	S	S	S	S	S	S	S
25M											
16A 415V/110V MOTOR CABLE	LA32816	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32808	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32806	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36249	20/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36258	20/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36257	20/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36251	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36262	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36250	31/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32807	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36238	29/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA33495	04/02/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32814	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32815	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA33500	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36233	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36241	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36235	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36244	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36240	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36242	04/02/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36236	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36256	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36254	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36237	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36247	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36239	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36245	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36234	20/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
5M											
16A 415V/110V MOTOR CABLE	LA36255	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32818	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32819	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32817	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36253	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36243	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36260	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36248	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA36259	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32820	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32821	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32813	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32345	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32346	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32343	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32344	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32484	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32487	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32488	20/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32485	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32486	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA44000	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA44003	04/02/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA44002	29/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA33499	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA30910	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA30913	20/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32341	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA30911	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA30912	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32489	12/02/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32810	29/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32811	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32809	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32490	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 415V/110V MOTOR CABLE	LA32812	09/01/20	S	S	S	S	S	S	S	S	S
5M											
16A 5FT 110V TRS	LA17640	20/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 5FT 110V TRS	LA17671	20/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33988	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33986	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33987	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33991	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33990	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33989	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA04763	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA16305	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA42624	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA04733	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA30371	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA30372	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA30369	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA30370	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33992	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33998	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33999	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33995	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33996	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33997	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33994	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA26941	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA38527	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33993	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33948	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA17688	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA16493	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33946	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA26624	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33947	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA16491	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02840	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02843	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02589	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02594	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA16285	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA16290	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02846	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02588	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33974	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33973	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33976	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33975	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33972	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33969	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33968	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33971	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33970	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33983	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33982	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33985	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33984	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33981	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33978	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33977	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33980	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33979	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33967	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33955	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33954	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33957	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33956	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33953	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33950	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33949	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33952	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33951	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33964	08/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A XLR5 COMBI CABLE 20FT	LA33963	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33966	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33965	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33962	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33959	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33958	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33961	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33960	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA01251	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA01215	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA38993	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02576	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02582	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02581	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02577	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02608	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02848	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02852	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02849	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA01214	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA42594	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02597	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA01401	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02853	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA26626	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA26625	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA16109	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA26627	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA17623	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA16289	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA04766	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA17622	02/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA16495	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA02928	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA02927	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA26631	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA16499	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17371	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16299	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17372	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17677	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17676	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16261	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16260	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16262	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16266	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16265	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17678	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30368	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30367	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30373	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA38954	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA33265	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17931	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17679	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30364	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30366	08/01/20	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30365	08/01/20	S	S	S	S	S	S	S	S	S
1KVA 110V TRANSFORMERS	LA25635	02/01/20	P	S	0.05 P	>300 P	0.13 P	<0.10 P	S	S	S
1KVA 110V TRANSFORMERS	LA25634	02/01/20	P	S	0.05 P	>300 P	0.13 P	<0.10 P	S	S	S
1KVA 110V TRANSFORMERS	LA25636	02/01/20	P	S	0.05 P	>300 P	0.13 P	<0.10 P	S	S	S
1KVA 110V TRANSFORMERS	LA20748	02/01/20	P	S	0.05 P	>300 P	0.12 P	<0.10 P	S	S	S
2K MOLE RICHARDSON MOLEBEAM PROJECTOR	LA24680	25/02/20	P	S	0.06 P	>300 P	1.91 P	<0.10 P	S	S	S
3.0KVA 110V TRANSFORMER	LA31979	02/01/20	P	S	0.06 P	>300 P	0.21 P	<0.10 P	S	S	S
3.0KVA 110V TRANSFORMER	LA31978	02/01/20	P	S	0.06 P	>300 P	0.17 P	<0.10 P	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA25814	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA17521	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA25816	14/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
32A 1PH - 16A 1PH ADAPTOR	LA33340	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA30136	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA16312	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA03445	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA33339	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA33338	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA33337	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA33336	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA16309	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 2 X 16A 1PH ADAPTOR	LA20642	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 32A 3PH ADAPTOR	LA17039	13/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 32A 3PH ADAPTOR	LA17024	13/01/20	S	S	S	S	S	S	S	S	S
32A 1PH - 63A 1PH ADAPTOR	LA38043	22/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30141	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA42627	30/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30140	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30138	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30139	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 2 WAY SPLITTER	LA25818	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 2 WAY SPLITTER	LA25817	14/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA38991	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA39000	30/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA39001	30/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA32423	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA42104	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA26963	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA30144	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA30145	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA32426	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA15710	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA42623	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA42588	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA42598	30/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA32428	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA16190	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA39035	30/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA39031	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA32427	08/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA39033	29/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 5FT TRS	LA15511	29/01/20	S	S	S	S	S	S	S	S	S
32A 1PH 5FT TRS	LA44026	30/01/20	S	S	S	S	S	S	S	S	S
32A 1PH FOH DISTRO (2 X 13A, 4 X 16A)	LA15807	20/01/20	S	S	S	S	S	S	S	S	S
32A 1PH FOH DISTRO (2 X 13A, 4 X 16A)	LA20474	20/01/20	S	S	S	S	S	S	S	S	S
32A 1PH FOH DISTRO (2 X 13A, 4 X 16A)	LA22097	20/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32029	13/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36008	20/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36010	13/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA22048	24/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA46666	28/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA42153	13/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32031	13/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32030	20/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32028	13/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36012	20/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32288	13/01/20	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH	LA32287	13/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SPLITTER											
32A 3PH - 16A 3PH (4 PIN) MOTOR ADAPTOR	LA26754	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 16A 3PH (4 PIN) MOTOR ADAPTOR	LA15639	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 16A 3PH (5 PIN) ADAPTOR	LA17023	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 32A 1PH ADAPTOR	LA42961	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA42562	20/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32908	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32907	09/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32909	21/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA42563	09/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32910	20/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA26960	21/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA37774	20/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA21558	21/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA38592	21/01/20	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA21074	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA26954	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA42981	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA36113	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA20309	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA36114	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22049	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22044	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22051	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22050	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA20182	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH LUGGED TAILS	LA15900	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH LUGGED TAILS	LA21112	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA42347	19/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33505	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA46703	19/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33640	28/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33506	19/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33641	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33367	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA46702	11/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33643	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30509	11/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30508	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30754	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30763	20/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30755	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30506	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30503	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30504	30/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30505	19/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38839	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38838	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38837	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA33060	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38846	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38840	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38836	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32459	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32460	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32461	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38937	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32912	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32911	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA33515	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38936	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA30768	10/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
32A 3PH MAINS CABLE 15M	LA30756	12/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA33519	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38940	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32282	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32283	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA33632	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32281	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30771	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30769	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30800	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30801	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30516	11/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA33628	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA39015	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30517	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30525	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33625	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30524	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30522	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30523	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30774	12/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30757	11/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30775	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30802	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30776	12/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30520	13/12/19	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33364	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33365	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33657	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33534	26/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA25327	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38850	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38851	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38849	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33366	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38848	10/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30494	11/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30493	11/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA33315	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30753	13/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30487	11/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA42878	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30491	11/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30490	11/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32916	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32915	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32395	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32917	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32913	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32482	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA39160	27/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32397	29/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32398	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA39062	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25338	30/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25340	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32394	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25333	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25335	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33496	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33494	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30502	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33647	20/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33501	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33497	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33655	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30501	22/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33649	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25350	13/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
32A 3PH MAINS CABLE 5M	LA33651	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30247	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30498	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30497	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30496	06/02/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32393	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32392	13/01/20	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32389	13/01/20	S	S	S	S	S	S	S	S	S
35MM CAMS - POWERLOK ADAPTOR	LA42809	21/01/20	S	S	S	S	S	S	S	S	S
35MM CAMS - POWERLOK ADAPTOR	LA20328	18/12/19	S	S	S	S	S	S	S	S	S
35MM POWERLOCK LINK 1M	LA30085	09/01/20	S	S	S	S	S	S	S	S	S
3KW MOLE PAR	LA31754	25/02/20	P	S	0.09 P	>300 P	1.06 P	<0.10 P	S	S	S
3M MONITOR LOOM 2X DVI 1 X POWERCON - IEC	LA37453	18/02/20	S	S	S	S	S	S	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26881	19/12/19	P	S	0.04 P	>300 P	0.43 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26880	19/12/19	P	S	0.05 P	>300 P	0.54 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26888	19/12/19	P	S	0.06 P	>300 P	0.43 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26887	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26882	19/12/19	P	S	0.05 P	>300 P	0.43 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26838	19/12/19	P	S	0.04 P	>300 P	0.44 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26702	19/12/19	P	S	0.05 P	>300 P	0.40 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26701	19/12/19	P	S	0.06 P	>300 P	0.42 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26699	19/12/19	P	S	0.05 P	>300 P	0.40 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26837	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26738	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26737	19/12/19	P	S	0.03 P	>300 P	0.49 P	<0.10 P	S	S	S
50MM POWERLOCK CABLE 10M	LA20468	23/01/20	S	S	S	S	S	S	S	S	S
50MM POWERLOCK CABLE 3M	LA21290	23/01/20	S	S	S	S	S	S	S	S	S
50MM POWERLOCK CABLE 5M	LA20470	21/01/20	S	S	S	S	S	S	S	S	S
63A 1PH - 125A 1PH ADAPTOR	LA30759	21/01/20	S	S	S	S	S	S	S	S	S
63A 1PH - 2 X 32A 1PH ADAPTOR	LA17018	22/01/20	S	S	S	S	S	S	S	S	S
63A 1PH - 2 X 63A 1PH SPLITTER	LA17017	22/01/20	S	S	S	S	S	S	S	S	S
63A 1PH - 32A 1PH ADAPTOR	LA38044	22/01/20	S	S	S	S	S	S	S	S	S
63A 1PH - 63A 3PH ADAPTER	LA37913	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA21206	12/12/19	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA20303	12/12/19	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA42568	12/12/19	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA42569	13/12/19	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA35152	12/12/19	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA22248	17/12/19	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA26971	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA42717	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA26961	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA20466	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA42716	20/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA34391	13/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA35199	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA32385	22/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA42564	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA42565	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 63A 1PH ADAPTOR	LA38526	23/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 63A 1PH ADAPTOR	LA15716	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - 63A 3PH / 32A 3PH ADAPTOR	LA35192	30/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK	LA42960	10/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTER 3M											
63A 3PH - POWERLOCK ADAPTOR 3M	LA42879	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA22326	20/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA21446	09/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA37825	17/12/19	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA31371	20/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA22330	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA42571	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA21311	09/01/20	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA21432	13/01/20	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA22182	20/01/20	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA42744	22/01/20	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA20315	09/01/20	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA21433	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA42880	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA21310	20/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA42776	20/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA42775	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA32466	09/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA42557	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA32465	09/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA33627	22/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA39005	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA21309	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA42554	09/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA42555	20/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA21308	20/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 3M	LA39161	22/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 3M	LA42560	21/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 3M	LA42561	22/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 3M	LA39164	22/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA33650	28/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA42559	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA42558	09/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA21428	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA20643	09/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA16538	20/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA32467	10/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA34533	09/01/20	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA25625	09/01/20	S	S	S	S	S	S	S	S	S
70MM CAMS - POWERLOCK ADAPTOR 3M	LA22135	18/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK BARE END TAILS	LA33406	18/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK BARE END TAILS	LA42720	13/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK BARE END TAILS	LA42734	07/01/20	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 10M	LA33403	12/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 10M	LA42770	18/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 10M	LA42771	12/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 20M	LA33402	18/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 20M	LA42790	12/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 20M	LA42789	12/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 5M	LA42749	12/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 5M	LA42753	16/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 5M	LA33404	18/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK LINK E	LA42697	13/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
1.5M											
70MM POWERLOCK LINK E	LA42855	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42692	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42694	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42695	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42854	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42857	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42856	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42693	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42691	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42690	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK E	LA42689	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42833	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42651	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42652	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42657	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42649	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42836	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42655	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42654	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42835	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42834	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42650	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L1	LA42656	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42841	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42840	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42842	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42838	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42662	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42664	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42660	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42839	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42666	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42661	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42667	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L2	LA42663	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42843	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42844	13/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
1.5M											
70MM POWERLOCK LINK L3	LA42845	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42846	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42674	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42670	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42671	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42847	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42675	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42858	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42673	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK L3	LA42672	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42679	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42682	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42852	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42683	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42851	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42680	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42684	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42681	12/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42850	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42687	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42849	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LINK N	LA42686	13/12/19	S	S	S	S	S	S	S	S	S
1.5M											
70MM POWERLOCK LUGGED TAILS	LA42722	07/01/20	S	S	S	S	S	S	S	S	S
70MM POWERLOCK LUGGED TAILS	LA42735	13/12/19	S	S	S	S	S	S	S	S	S
70MM POWERLOCK LUGGED TAILS	LA33407	18/12/19	S	S	S	S	S	S	S	S	S
95MM CAMS - POWERLOCK ADAPTOR 3M	LA42862	19/12/19	S	S	S	S	S	S	S	S	S
95MM CAMS - POWERLOCK ADAPTOR 3M	LA22252	17/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK BARE END TAILS	LA42740	18/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK BARE END TAILS	LA21157	19/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK BARE END TAILS	LA21816	17/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA42772	17/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA42773	19/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA15136	18/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA42774	12/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 20M	LA21740	18/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 20M	LA42791	17/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE	LA42792	19/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
20M											
95MM POWERLOCK CABLE 2M	LA31945	21/01/20	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42742	21/01/20	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42739	21/01/20	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA39163	18/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA31669	17/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA31610	18/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42745	19/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA21814	17/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42743	17/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA22971	19/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42764	21/01/20	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA21744	17/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 5M	LA42762	12/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 5M	LA42755	19/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 5M	LA42761	18/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK LUGGED TAILS	LA21158	18/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK LUGGED TAILS	LA42763	17/12/19	S	S	S	S	S	S	S	S	S
95MM POWERLOCK LUGGED TAILS	LA42748	19/12/19	S	S	S	S	S	S	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24136	19/12/19	P	S	0.02 P	>300 P	0.76 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24137	19/12/19	P	S	0.04 P	>300 P	0.81 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24134	19/12/19	P	S	0.02 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24135	19/12/19	P	S	0.03 P	>300 P	0.80 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25974	19/12/19	P	S	0.03 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25633	19/12/19	P	S	0.03 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25973	19/12/19	P	S	0.03 P	>300 P	0.54 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25631	19/12/19	P	S	0.03 P	>300 P	0.81 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25632	19/12/19	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24129	19/12/19	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24132	19/12/19	P	S	0.02 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24133	19/12/19	P	S	0.02 P	>300 P	0.81 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24139	19/12/19	P	S	0.05 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24138	19/12/19	P	S	0.04 P	>300 P	0.77 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24131	19/12/19	P	S	0.03 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25629	19/12/19	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25630	19/12/19	P	S	0.04 P	>300 P	0.81 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000	LA24140	19/12/19	P	S	0.03 P	>300 P	0.82 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PHOTOFLOOD C/W BARNDOR											
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24130	19/12/19	P	S	0.03 P	>300 P	0.81 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34889	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34692	23/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34238	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34237	23/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34239	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34691	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34690	23/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34894	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34893	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34896	23/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34895	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34890	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34891	23/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34892	23/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONIC S1205 SWITCH PACK 192 32A 3PH	LA38651	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONIC S1205 SWITCH PACK 192 32A 3PH	LA38649	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONIC S1205 SWITCH PACK 192 DMX 32A 3PH	LA25750	17/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS INLINE 5KW DIMMER DMX 32A 1PH	LA20810	24/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K090 S192 10A 6 WAY SWITCH PACK	LA21299	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K090 S192 10A 6 WAY SWITCH PACK	LA24071	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA25036	24/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA26087	24/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA20324	24/01/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA25035	24/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA26088	24/01/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37627	24/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37628	24/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37625	24/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37626	24/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA38466	24/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA38467	29/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA38468	24/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
APPLE MAC MINI 2.5GHZ 250GB SSD	LA33388	27/01/20	P	S	S	>300 P	S	S	S	S	S
APPLE MAC MINI 2.5GHZ 250GB SSD	LA33392	27/01/20	P	S	S	>300 P	S	S	S	S	S
APPLE MAC MINI 2.5GHZ	LA33389	27/01/20	P	S	S	>300 P	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
250GB SSD											
APPLE MACPRO 6.1 8 CORE	LA41327	18/12/19	P	S	S	>300 P	S	S	S	S	S
APPLE MACPRO 6.1 8 CORE	LA41326	18/12/19	P	S	S	>300 P	S	S	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA25416	16/12/19	P	S	0.06 P	S	<0.05 P	0.43 P	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA34751	16/12/19	P	S	0.04 P	S	<0.05 P	0.44 P	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA25369	16/12/19	P	S	0.04 P	S	<0.05 P	0.36 P	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA38505	16/12/19	P	S	0.05 P	S	<0.05 P	0.47 P	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA38411	16/12/19	P	S	0.04 P	S	<0.05 P	0.30 P	S	S	S
ASL PS285 TALKBACK AUX PSU	LA25359	16/12/19	P	S	0.07 P	S	<0.05 P	0.42 P	S	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVM SWITCH	LA44603	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVM SWITCH	LA41554	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVM SWITCH	LA44602	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVMP SWITCH	LA39522	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVMP SWITCH	LA37119	27/01/20	P	S	S	>300 P	S	S	S	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVMP SWITCH	LA37117	27/01/20	P	S	S	>300 P	S	S	S	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVMP SWITCH	LA39521	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVMP SWITCH	LA41466	24/01/20	P	S	0.09 P	S	<0.05 P	0.10 P	S	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVMP SWITCH	LA37159	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
AVO ART 2000 POWER CUBE	LA31779	14/02/20	P	S	0.06 P	>300 P	S	S	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA31569	05/02/20	P	S	0.06 P	>300 P	<0.05 P	0.54 P	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA31873	04/03/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO ART2000 T4 FRAME C/W POWERLOCK	LA34809	09/01/20	P	S	0.04 P	>300 P	<0.05 P	0.59 P	S	S	S
AVO DMX OPTO ISOLATOR TRUSS MOUNT (6 OUT)	LA31412	24/01/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR TRUSS MOUNT (6 OUT)	LA31944	24/01/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVOCENT DUAL DVI KVM EXTENDER (RECEIVER)	LA39452	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
AVOCENT DUAL DVI KVM EXTENDER (RECEIVER)	LA39454	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
AVOCENT DUAL DVI KVM EXTENDER (RECEIVER)	LA39450	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
AVOCENT DUAL DVI KVM EXTENDER (RECEIVER)	LA39448	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
AVOCENT DUAL DVI KVM EXTENDER (TRANSMITTER)	LA39449	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
AVOCENT DUAL DVI KVM EXTENDER (TRANSMITTER)	LA39453	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
AVOCENT DUAL DVI KVM EXTENDER (TRANSMITTER)	LA39447	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
AYRTON MAGIC PANEL 602	LA34660	18/12/19	P	S	0.08 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34659	17/12/19	P	S	0.07 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34650	17/12/19	P	S	0.06 P	>300 P	<0.05 P	0.25 P	S	S	S
AYRTON MAGIC PANEL 602	LA34661	18/12/19	P	S	0.07 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA41422	18/12/19	P	S	0.08 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA41423	17/12/19	P	S	0.07 P	>300 P	<0.05 P	0.25 P	S	S	S
AYRTON MAGIC PANEL 602	LA41420	17/12/19	P	S	0.08 P	>300 P	<0.05 P	0.25 P	S	S	S
AYRTON MAGIC PANEL 602	LA34651	18/12/19	P	S	0.07 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34655	18/12/19	P	S	0.08 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34656	18/12/19	P	S	0.08 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34653	17/12/19	P	S	0.08 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34658	18/12/19	P	S	0.07 P	>300 P	<0.05 P	0.27 P	S	S	S
AYRTON MAGIC PANEL 602	LA34652	17/12/19	P	S	0.08 P	>300 P	<0.05 P	0.26 P	S	S	S
AYRTON MAGICBLADE-R	LA37959	23/01/20	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
AYRTON MAGICBLADE-R	LA37958	23/01/20	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
AYRTON MAGICDOT-R	LA37862	17/12/19	P	S	0.09 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37865	17/01/20	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37868	17/01/20	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
AYRTON MAGICDOT-R	LA37867	17/12/19	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37866	20/01/20	P	S	0.04 P	>300 P	<0.05 P	0.12 P	S	S	S
AYRTON MAGICDOT-R	LA38777	17/12/19	P	S	0.07 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA38778	17/01/20	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38775	16/01/20	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38776	17/01/20	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37898	17/01/20	P	S	0.04 P	>300 P	<0.05 P	0.12 P	S	S	S
AYRTON MAGICDOT-R	LA37897	17/01/20	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37935	16/01/20	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
AYRTON MAGICDOT-R	LA37899	17/12/19	P	S	0.08 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37833	16/01/20	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37835	17/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37834	17/01/20	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
AYRTON MAGICDOT-R	LA38774	17/12/19	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38773	17/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37832	17/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
BLACKMAGIC SMART VIEW DUO	LA39458	18/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
CAMLOK - 125A 3PH ADAPTOR	LA34718	12/12/19	S	S	S	S	S	S	S	S	S
CAMLOK - 125A 3PH ADAPTOR	LA17068	17/12/19	S	S	S	S	S	S	S	S	S
CAMLOK - 63A 3PH ADAPTOR	LA20300	20/01/20	S	S	S	S	S	S	S	S	S
CAMLOK - 63A 3PH ADAPTOR	LA34534	10/01/20	S	S	S	S	S	S	S	S	S
CAMLOK - 63A 3PH ADAPTOR	LA17166	13/01/20	S	S	S	S	S	S	S	S	S
CCT 650W FRESNEL - BLACK	LA24460	05/03/20	P	S	0.06 P	>300 P	0.68 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31661	05/03/20	P	S	0.04 P	>300 P	0.67 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31662	05/03/20	P	S	0.04 P	>300 P	0.68 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31852	05/03/20	P	S	0.04 P	>300 P	0.69 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA24068	05/03/20	P	S	0.04 P	>300 P	0.67 P	<0.10 P	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26398	24/01/20	P	S	S	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26855	24/01/20	P	S	S	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26856	24/01/20	P	S	S	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26046	10/01/20	P	S	0.05 P	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA24146	24/01/20	P	S	S	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA24715	24/01/20	P	S	S	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA24716	24/01/20	P	S	S	>300 P	S	S	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41395	06/03/20	P	S	0.03 P	>300 P	0.08 P	0.36 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41397	14/02/20	P	S	0.03 P	>300 P	0.08 P	0.43 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41393	14/02/20	P	S	0.04 P	>300 P	0.08 P	0.36 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41396	06/03/20	P	S	0.03 P	>300 P	0.08 P	0.39 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41412	06/03/20	P	S	0.03 P	>300 P	0.08 P	0.35 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41418	14/02/20	P	S	0.03 P	>300 P	0.08 P	0.35 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41402	06/03/20	P	S	0.03 P	>300 P	0.09 P	0.35 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41409	14/02/20	P	S	0.03 P	>300 P	0.08 P	0.36 P	S	S	S
CHROMA-Q STUDIO FORCE V 12	LA41475	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CHROMA-Q STUDIO FORCE V 12	LA41471	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
CHROMA-Q STUDIO FORCE V 12	LA41472	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CHROMA-Q STUDIO FORCE V 12	LA41468	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CHROMA-Q STUDIO FORCE V 12	LA41473	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CHROMA-Q STUDIO FORCE V 12	LA41470	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
12 CHROMA-Q STUDIO FORCE V	LA41469	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
12 CHROMA-Q STUDIO FORCE V	LA41474	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37292	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37294	23/12/19	P	S	0.06 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37439	17/12/19	P	S	0.04 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37289	17/12/19	P	S	0.04 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37291	17/12/19	P	S	0.07 P	>300 P	0.05 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37466	17/12/19	P	S	0.06 P	>300 P	0.05 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37677	23/12/19	P	S	0.06 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37437	17/12/19	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37431	17/12/19	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37432	17/12/19	P	S	0.04 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37430	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37428	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37429	17/12/19	P	S	0.08 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37435	18/12/19	P	S	0.07 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37286	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37287	17/12/19	P	S	0.06 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34946	17/12/19	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34578	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34942	17/12/19	P	S	0.07 P	>300 P	0.06 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37295	17/12/19	P	S	0.07 P	>300 P	0.05 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37303	17/12/19	P	S	0.06 P	>300 P	0.05 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37302	18/12/19	P	S	0.07 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37300	23/12/19	P	S	0.05 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37307	10/01/20	P	S	0.05 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37306	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37305	17/12/19	P	S	0.06 P	>300 P	0.05 P	0.45 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37299	17/12/19	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37681	17/12/19	P	S	0.04 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37424	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37421	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37422	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37423	17/12/19	P	S	0.04 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37415	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37414	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37413	17/12/19	P	S	0.04 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37420	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37417	17/12/19	P	S	0.04 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37416	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37409	17/12/19	P	S	0.08 P	>300 P	0.05 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37310	17/12/19	P	S	0.06 P	>300 P	0.06 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37308	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37412	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37411	17/12/19	P	S	0.07 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37410	17/12/19	P	S	0.04 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37427	17/12/19	P	S	0.04 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37426	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37425	17/12/19	P	S	0.05 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37297	10/01/20	P	S	0.04 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37679	23/12/19	P	S	0.04 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37680	17/12/19	P	S	0.06 P	>300 P	0.06 P	0.47 P	S	S	S
CLEAR-COM FREESPEAK II WIRELESS BASESTATION	LA41804	04/03/20	P	S	0.06 P	>300 P	S	S	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA37967	06/01/20	P	S	0.04 P	>300 P	S	S	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA35409	06/01/20	P	S	0.05 P	>300 P	S	S	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA35408	06/01/20	P	S	0.06 P	>300 P	S	S	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA39996	16/12/19	P	S	0.05 P	S	<0.05 P	0.61 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA39997	16/12/19	P	S	0.04 P	S	<0.05 P	0.62 P	S	S	S
CM4 4 WAY MOTOR CONTROLLER	LA20289	17/02/20	P	S	0.08 P	>300 P	S	S	S	S	S
COLOUR KINETIC	LA26403	05/03/20	P	S	0.04 P	>300 P	0.06 P	0.27 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COLOURBLAZE 48LED BATTEN V3 (1.2M)											
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26405	05/03/20	P	S	0.04 P	>300 P	0.05 P	0.27 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26410	05/03/20	P	S	0.06 P	>300 P	0.06 P	0.27 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31361	05/03/20	P	S	0.05 P	>300 P	0.09 P	0.40 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31364	05/03/20	P	S	0.06 P	>300 P	0.08 P	0.40 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA34548	05/03/20	P	S	0.07 P	>300 P	0.10 P	0.40 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31363	05/03/20	P	S	0.04 P	>300 P	0.08 P	0.41 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31367	05/03/20	P	S	0.06 P	>300 P	0.08 P	0.40 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31368	05/03/20	P	S	0.08 P	>300 P	0.08 P	0.39 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31365	05/03/20	P	S	0.08 P	>300 P	0.09 P	0.40 P	S	S	S
COUNTDOWN CONFERENCE CLOCK CONTROLLER	LA31653	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
CUE SERVER PRO C/W PSU	LA34065	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
CUE SERVER PRO C/W PSU	LA34066	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
DATAPATH 4 WAY DVI SPLITTER CAT	LA39177	18/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
EDISON (US) MALE - 16A 1PH 0.5M	LA35148	14/01/20	S	S	S	S	S	S	S	S	S
EDISON (US) MALE - 16A 1PH 0.5M	LA39473	17/01/20	S	S	S	S	S	S	S	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA34350	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA34349	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA34114	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA37791	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA37794	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA37793	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA37792	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
FILMGEAR 1000W FRESNEL	LA34735	07/01/20	P	S	0.05 P	>300 P	0.98 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34736	07/01/20	P	S	0.05 P	>300 P	0.91 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34734	07/01/20	P	S	0.05 P	>300 P	0.96 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34424	07/01/20	P	S	0.05 P	>300 P	0.96 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34418	02/01/20	P	S	0.06 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34729	07/01/20	P	S	0.05 P	>300 P	0.97 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34727	07/01/20	P	S	0.04 P	>300 P	0.97 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34728	02/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34422	02/01/20	P	S	0.05 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34423	07/01/20	P	S	0.05 P	>300 P	0.98 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34421	07/01/20	P	S	0.05 P	>300 P	0.98 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34419	07/01/20	P	S	0.05 P	>300 P	0.97 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34420	07/01/20	P	S	0.05 P	>300 P	0.98 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34726	02/01/20	P	S	0.06 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34452	02/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34451	07/01/20	P	S	0.05 P	>300 P	0.97 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34453	02/01/20	P	S	0.06 P	>300 P	0.99 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34733	02/01/20	P	S	0.05 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34732	02/01/20	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34731	07/01/20	P	S	0.05 P	>300 P	0.95 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FILMGEAR 1000W FRESNEL	LA34730	02/01/20	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34725	07/01/20	P	S	0.05 P	>300 P	0.98 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34450	07/01/20	P	S	0.05 P	>300 P	0.95 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34425	07/01/20	P	S	0.05 P	>300 P	0.97 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA41620	08/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA41621	08/01/20	P	S	0.03 P	>300 P	1.91 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA41622	08/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA41617	08/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA41618	08/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA41619	08/01/20	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38565	08/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38566	08/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38567	08/01/20	P	S	0.03 P	>300 P	1.94 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38594	08/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38596	08/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38595	08/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FURMAN 10A POWER CONDITIONER	LA17382	16/12/19	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
FURMAN 10A POWER CONDITIONER	LA17383	16/12/19	P	S	0.08 P	S	<0.05 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 10	LA41457	24/01/20	P	S	0.03 P	>300 P	0.07 P	0.30 P	S	S	S
GLP IMPRESSION X4 BAR 10	LA41456	24/01/20	P	S	0.05 P	>300 P	0.07 P	0.29 P	S	S	S
GLP IMPRESSION X4 BAR 10	LA41454	24/01/20	P	S	0.03 P	>300 P	0.07 P	0.29 P	S	S	S
GLP IMPRESSION X4 BAR 10	LA41645	24/01/20	P	S	0.03 P	>300 P	0.07 P	0.29 P	S	S	S
GLP IMPRESSION X4 BAR 10	LA41455	24/01/20	P	S	0.03 P	>300 P	0.07 P	0.30 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41627	24/01/20	P	S	0.04 P	>300 P	0.10 P	0.54 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41642	08/01/20	P	S	0.06 P	>300 P	0.10 P	0.68 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41625	22/01/20	P	S	0.03 P	>300 P	0.10 P	0.63 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41626	23/01/20	P	S	0.03 P	>300 P	0.10 P	0.56 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41628	22/01/20	P	S	0.03 P	>300 P	0.10 P	0.58 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41633	22/01/20	P	S	0.04 P	>300 P	0.10 P	0.65 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41632	23/01/20	P	S	0.04 P	>300 P	0.09 P	0.54 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41629	24/01/20	P	S	0.04 P	>300 P	0.10 P	0.56 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41634	20/01/20	P	S	0.05 P	>300 P	0.10 P	0.53 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41859	07/01/20	P	S	0.03 P	>300 P	0.10 P	0.64 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41643	24/01/20	P	S	0.04 P	>300 P	0.10 P	0.55 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41644	22/01/20	P	S	0.05 P	>300 P	0.10 P	0.56 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41637	23/01/20	P	S	0.03 P	>300 P	0.10 P	0.58 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41636	23/01/20	P	S	0.05 P	>300 P	0.10 P	0.51 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41635	08/01/20	P	S	0.06 P	>300 P	0.10 P	0.70 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41640	22/01/20	P	S	0.04 P	>300 P	0.10 P	0.56 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41641	22/01/20	P	S	0.03 P	>300 P	0.10 P	0.58 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41638	22/01/20	P	S	0.04 P	>300 P	0.10 P	0.55 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41639	22/01/20	P	S	0.03 P	>300 P	0.10 P	0.56 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41443	22/01/20	P	S	0.03 P	>300 P	0.11 P	0.58 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41444	22/01/20	P	S	0.03 P	>300 P	0.11 P	0.58 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41568	07/01/20	P	S	0.05 P	>300 P	0.11 P	0.67 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41442	08/01/20	P	S	0.06 P	>300 P	0.11 P	0.71 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41516	23/01/20	P	S	0.03 P	>300 P	0.10 P	0.56 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41519	03/03/20	P	S	0.07 P	>300 P	0.08 P	0.56 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41520	23/01/20	P	S	0.04 P	>300 P	0.10 P	0.54 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41517	23/01/20	P	S	0.05 P	>300 P	0.10 P	0.53 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41518	22/01/20	P	S	0.03 P	>300 P	0.10 P	0.59 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41440	22/01/20	P	S	0.03 P	>300 P	0.11 P	0.65 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41433	24/01/20	P	S	0.03 P	>300 P	0.11 P	0.58 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41434	24/01/20	P	S	0.04 P	>300 P	0.11 P	0.59 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41431	23/01/20	P	S	0.04 P	>300 P	0.11 P	0.54 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41432	23/01/20	P	S	0.04 P	>300 P	0.11 P	0.49 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41435	20/01/20	P	S	0.08 P	>300 P	0.11 P	0.51 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
GLP IMPRESSION X4 BAR 20	LA41438	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.56 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41439	07/01/20	P	S	0.05 P	>300 P	0.11 P	0.68 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41436	23/01/20	P	S	0.04 P	>300 P	0.11 P	0.59 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41437	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.53 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41649	23/01/20	P	S	0.03 P	>300 P	0.10 P	0.55 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41655	07/01/20	P	S	0.04 P	>300 P	0.10 P	0.63 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41656	22/01/20	P	S	0.03 P	>300 P	0.10 P	0.58 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41654	08/01/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41453	24/01/20	P	S	0.04 P	>300 P	0.11 P	0.61 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41648	22/01/20	P	S	0.03 P	>300 P	0.10 P	0.56 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41630	24/01/20	P	S	0.05 P	>300 P	0.10 P	0.58 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41631	23/01/20	P	S	0.04 P	>300 P	0.10 P	0.52 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41647	23/01/20	P	S	0.04 P	>300 P	0.10 P	0.57 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41646	24/01/20	P	S	0.03 P	>300 P	0.10 P	0.59 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41653	22/01/20	P	S	0.03 P	>300 P	0.10 P	0.59 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41448	22/01/20	P	S	0.04 P	>300 P	0.11 P	0.63 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41449	08/01/20	P	S	0.07 P	>300 P	0.11 P	0.69 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41446	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.59 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41447	08/01/20	P	S	0.05 P	>300 P	0.11 P	0.70 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41450	20/01/20	P	S	0.03 P	>300 P	0.11 P	0.66 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41651	22/01/20	P	S	0.04 P	>300 P	0.10 P	0.61 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41452	23/01/20	P	S	0.04 P	>300 P	0.11 P	0.57 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41451	22/01/20	P	S	0.04 P	>300 P	0.11 P	0.61 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41650	23/01/20	P	S	0.03 P	>300 P	0.10 P	0.56 P	S	S	S
GLP JDC1 STROBE	LA44581	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.68 P	S	S	S
GLP JDC1 STROBE	LA44580	23/01/20	P	S	0.03 P	>300 P	0.10 P	0.16 P	S	S	S
GLP JDC1 STROBE	LA44533	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.18 P	S	S	S
GLP JDC1 STROBE	LA44585	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.65 P	S	S	S
GLP JDC1 STROBE	LA44579	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.65 P	S	S	S
GLP JDC1 STROBE	LA44578	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.65 P	S	S	S
GLP JDC1 STROBE	LA44523	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.16 P	S	S	S
GLP JDC1 STROBE	LA44525	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.16 P	S	S	S
GLP JDC1 STROBE	LA44529	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.16 P	S	S	S
GLP JDC1 STROBE	LA44516	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.17 P	S	S	S
GLP JDC1 STROBE	LA44517	23/01/20	P	S	0.04 P	>300 P	0.11 P	0.15 P	S	S	S
GLP JDC1 STROBE	LA44520	23/01/20	P	S	0.04 P	>300 P	0.11 P	0.16 P	S	S	S
GLP JDC1 STROBE	LA44591	23/01/20	P	S	0.04 P	>300 P	0.10 P	0.16 P	S	S	S
GLP JDC1 STROBE	LA44590	23/01/20	P	S	0.04 P	>300 P	0.10 P	0.15 P	S	S	S
GLP JDC1 STROBE	LA44589	23/01/20	P	S	0.03 P	>300 P	0.10 P	0.16 P	S	S	S
GLP JDC1 STROBE	LA44594	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.68 P	S	S	S
GLP JDC1 STROBE	LA44592	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.65 P	S	S	S
GLP JDC1 STROBE	LA44593	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.61 P	S	S	S
GLP JDC1 STROBE	LA44583	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.65 P	S	S	S
GLP JDC1 STROBE	LA44582	23/01/20	P	S	0.03 P	>300 P	0.10 P	0.16 P	S	S	S
GLP JDC1 STROBE	LA44584	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.66 P	S	S	S
GLP JDC1 STROBE	LA44588	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.67 P	S	S	S
GLP JDC1 STROBE	LA44587	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.66 P	S	S	S
GLP JDC1 STROBE	LA44586	23/01/20	P	S	0.03 P	>300 P	0.11 P	0.63 P	S	S	S
GRANDMA 2 FULL SIZE CONTROL DESK	LA34614	18/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA41367	14/02/20	P	S	0.06 P	>300 P	S	S	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA41350	18/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA41210	11/02/20	P	S	0.04 P	>300 P	S	S	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA41368	18/12/19	P	S	0.05 P	>300 P	S	S	S	S	S
GRANDMA 3 8PORT NODE	LA41990	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
GRANDMA 3 8PORT NODE	LA41989	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
GRANDMA 3 8PORT NODE	LA41975	04/03/20	P	S	0.04 P	>300 P	S	S	S	S	S
GRANDMA 3 8PORT NODE	LA41974	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
GRANDMA 3 8PORT NODE	LA41991	04/03/20	P	S	0.04 P	>300 P	S	S	S	S	S
GRANDMA 3 8PORT NODE	LA41994	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
GRANDMA 3 FULL SIZE CONSOLE	LA44405	18/12/19	P	S	0.05 P	>300 P	S	S	S	S	S
GRANDMA 3 FULL SIZE CONSOLE	LA44406	18/12/19	P	S	0.05 P	>300 P	S	S	S	S	S
GRANDMA 3 LIGHT CONSOLE	LA44309	18/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
GRANDMA 3 PROCESSING UNIT M	LA41998	04/03/20	P	S	0.04 P	>300 P	S	S	S	S	S
GRANDMA 3 PROCESSING UNIT M	LA44562	18/12/19	P	S	0.09 P	>300 P	S	S	S	S	S
GRANDMA 3 PROCESSING	LA44513	04/03/20	P	S	0.03 P	>300 P	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
UNIT M											
GRANDMA 3 PROCESSING UNIT M	LA41996	18/12/19	P	S	0.05 P	>300 P	S	S	S	S	S
GRANDMA 3 PROCESSING UNIT M	LA44561	18/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA41325	06/01/20	P	S	0.07 P	>300 P	S	S	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA41370	06/01/20	P	S	0.04 P	>300 P	S	S	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA31342	06/01/20	P	S	0.07 P	>300 P	S	S	S	S	S
HALF 16`` MIRROR BALL - 10MM FACETS	LA34926	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
HALF 16`` MIRROR BALL - 10MM FACETS	LA34927	02/01/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
HALF 16`` MIRROR BALL - 10MM FACETS	LA34925	02/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
HALF 16`` MIRROR BALL - 10MM FACETS	LA34923	02/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
HALF 16`` MIRROR BALL - 10MM FACETS	LA34924	02/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
HANSPREE TOUCH SCREEN MONITOR 22``	LA44323	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
HANSPREE TOUCH SCREEN MONITOR 22``	LA44324	19/12/19	P	S	0.06 P	>300 P	S	S	S	S	S
HES FULL BOAR 4 CONSOLE	LA38361	18/12/19	P	S	0.09 P	>300 P	S	S	S	S	S
HES FULL BOAR 4 CONSOLE	LA38362	18/12/19	P	S	0.09 P	>300 P	S	S	S	S	S
HES FULL BOAR 4 CONSOLE	LA37445	18/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
HES FULL BOAR 4 CONSOLE	LA34930	18/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
HES FULL BOAR 4 CONSOLE	LA34931	18/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
HES HEDGE HOG 4X CONSOLE	LA38291	19/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA41267	18/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA41266	18/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA41268	18/02/20	P	S	0.06 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA38506	18/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA38783	18/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA38365	18/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA38520	19/12/19	P	S	0.05 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA38364	19/12/19	P	S	0.06 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA38288	18/12/19	P	S	0.06 P	>300 P	S	S	S	S	S
HES HOG 4 DP 8000	LA38289	18/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
HES PLAYBACK WING 4	LA34932	18/12/19	P	S	0.09 P	>300 P	S	S	S	S	S
HES PLAYBACK WING 4	LA34933	18/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
HES RACK HOG 4 CONSOLE	LA37112	18/02/20	P	S	0.06 P	>300 P	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25515	16/01/20	S	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25514	17/01/20	S	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA24377	17/01/20	S	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25518	17/01/20	S	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA26483	17/01/20	S	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25519	17/01/20	S	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25517	17/01/20	S	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA15749	17/01/20	S	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA35073	17/01/20	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34426	17/01/20	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34436	17/01/20	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34434	17/01/20	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34431	17/01/20	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34430	17/01/20	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34428	17/01/20	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34489	17/01/20	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA15757	18/02/20	S	S	S	S	S	S	S	S	S
IEC - IEC 6 WAY SPLITTER	LA38799	17/01/20	S	S	S	S	S	S	S	S	S
IEC (F) - 16A 1PH (M)&(F) ADAPTOR 0.5M	LA32049	11/02/20	S	S	S	S	S	S	S	S	S
IEC (F) - 16A 1PH (M)&(F) ADAPTOR 0.5M	LA30147	13/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON (F) ADAPTOR 0.5M	LA46669	28/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON (F) ADAPTOR 0.5M	LA42213	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON (F) ADAPTOR 0.5M	LA46693	27/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA16188	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32889	18/02/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32906	18/02/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32887	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32888	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA40309	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44454	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44448	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44446	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44458	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44447	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44450	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44444	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32570	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32569	18/02/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32567	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32635	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44455	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44449	18/02/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44440	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44457	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44442	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44456	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44445	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA46692	27/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA46670	28/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA46644	30/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44452	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32636	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44443	17/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44459	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44453	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44441	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA44451	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35637	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35639	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35640	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA35615	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA35616	24/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA35617	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32566	18/02/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32481	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32479	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32478	18/02/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32565	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32564	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32563	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32896	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32898	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32899	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32893	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32894	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32895	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32902	17/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA34574	18/02/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA35084	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA35114	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32903	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA33312	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA33563	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA38312	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA38313	12/02/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA38317	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA38309	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA38310	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA38311	22/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32891	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA17989	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA32890	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA38318	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA38319	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA39476	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA42210	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M IEC (M) - POWERCON (F)	LA30392	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30389	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32476	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32474	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42209	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30391	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35642	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38308	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42120	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30388	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA26711	16/01/20	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46163	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46172	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46166	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46167	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46171	05/02/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46694	27/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46671	28/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46164	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46169	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46161	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46162	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46165	05/02/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46168	16/01/20	S	S	S	S	S	S	S	S	S
IEC (M) - POWERCON TRUE1 (F) ADAPTOR 0.5M	LA46170	05/02/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33419	18/02/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33418	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33425	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33422	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32099	22/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32097	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32102	22/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32101	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA35117	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42139	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42137	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42142	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42138	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42143	17/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42202	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42141	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42140	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32094	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25485	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25483	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25488	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25487	17/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA15753	16/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
IEC EXTENSION 0.25M	LA40390	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA15858	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA15856	17/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32093	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40300	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40299	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40305	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40302	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40293	17/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40292	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40297	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40296	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33409	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA15850	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32107	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32110	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42128	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32109	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42111	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA26713	17/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA40306	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA40303	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33415	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA40307	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33410	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33411	18/02/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA40308	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA25489	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17781	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17785	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA46655	30/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42145	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42148	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42146	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42147	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA46650	30/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33416	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA25492	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA25494	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA46645	30/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA46651	30/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA16232	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17788	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25500	18/02/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25832	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25501	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA16383	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25497	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24770	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25507	22/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24768	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17990	17/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA26732	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24727	22/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24726	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25505	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25164	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25224	18/02/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA42163	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24771	17/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24783	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA42165	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17796	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA46638	13/02/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA16382	24/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17790	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17798	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17987	18/02/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17988	24/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
IEC EXTENSION 1M	LA17800	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17986	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA26735	17/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA26724	16/01/20	S	S	S	S	S	S	S	S	S
IEC EXTENSION 3M	LA22708	16/01/20	S	S	S	S	S	S	S	S	S
IYAMA 22`` TOUCH SCREEN MONITOR	LA44598	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
IYAMA 22`` TOUCH SCREEN MONITOR	LA44599	17/12/19	P	S	0.09 P	>300 P	S	S	S	S	S
IYAMA 22`` TOUCH SCREEN MONITOR	LA44600	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
IYAMA 22`` TOUCH SCREEN MONITOR	LA41541	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
IYAMA 22`` TOUCH SCREEN MONITOR	LA31707	17/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
IYAMA 22`` TOUCH SCREEN MONITOR	LA44601	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
JANDS STAGE CL COMPACT LIGHTING PSU	LA41553	17/12/19	P	S	S	>300 P	<0.05 P	0.22 P	S	S	S
JANDS STAGE CL COMPACT LIGHTING PSU	LA34347	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
JANDS STAGE CL COMPACT LIGHTING PSU	LA41205	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
JANDS STAGE CL COMPACT LIGHTING PSU	LA34345	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
JANDS STAGE CL COMPACT LIGHTING PSU	LA41552	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
JANDS STAGE CL LED CONSOLE	LA34344	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
JANDS STAGE CL LED CONSOLE	LA41204	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
JANDS STAGE CL LED CONSOLE	LA34346	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
JANDS STAGE CL LED CONSOLE	LA41202	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
JANDS STAGE CL LED CONSOLE	LA41203	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
JEM AF-1 DMX FAN	LA41800	05/03/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34119	14/02/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA37942	24/02/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA37936	25/02/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34243	05/03/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA22817	14/02/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA17507	10/02/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA16316	10/02/20	P	S	0.08 P	>300 P	0.13 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA31522	17/02/20	P	S	0.05 P	>300 P	0.12 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA24813	10/02/20	P	S	0.09 P	>300 P	0.12 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA22818	17/02/20	P	S	0.07 P	>300 P	0.13 P	<0.10 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA34440	14/02/20	P	S	0.05 P	4.97 P	2.02 P	0.37 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA34012	17/02/20	P	S	0.06 P	18.87 P	2.07 P	0.39 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA37552	14/02/20	P	S	0.05 P	>300 P	2.00 P	0.35 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA34752	14/02/20	P	S	0.04 P	>300 P	<0.05 P	0.41 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA31520	14/02/20	P	S	0.04 P	202.90 P	<0.05 P	0.39 P	S	S	S
KINESYS ARRAY 485 8 WAY DATA SPLITTER	LA37277	28/01/20	P	S	0.05 P	>300 P	S	S	S	S	S
KINESYS ARRAY 485 8 WAY DATA SPLITTER	LA37276	24/01/20	P	S	0.04 P	>300 P	S	S	S	S	S
KINESYS ARRAY PDES-T POWERLOCK DISTRO	LA34175	24/01/20	P	S	0.03 P	>300 P	S	S	S	S	S
KINESYS DIGIHOIST 8 WAY MOTOR CONTROLLER	LA37461	17/02/20	P	S	0.03 P	>300 P	S	S	S	S	S
KINESYS DIGIHOIST MOTOR SPIDER 415V FAN OUT	LA46141	20/01/20	S	S	S	S	S	S	S	S	S
KINESYS DIGIHOIST MOTOR SPIDER 415V FAN OUT	LA46143	20/01/20	S	S	S	S	S	S	S	S	S
KINESYS DIGIHOIST MOTOR SPIDER 415V FAN OUT	LA46137	21/01/20	S	S	S	S	S	S	S	S	S
KINESYS DIGIHOIST MOTOR	LA42965	09/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA42969	09/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA42966	09/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA42968	09/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA46140	21/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA46146	09/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA46147	09/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA24722	04/02/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA24991	18/02/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA24989	04/02/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA46149	09/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA46145	09/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA46148	18/02/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA46138	10/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS DIGIHOIST MOTOR	LA46139	09/01/20	S	S	S	S	S	S	S	S	S
SPIDER 415V FAN OUT											
KINESYS K2 USB CONTROL	LA22751	27/01/20	P	S	S	>300 P	S	S	S	S	S
WING											
KINESYS K2 USB CONTROL	LA37114	27/01/20	P	S	S	>300 P	S	S	S	S	S
WING											
KINESYS LIBRAPRO POWER	LA41931	06/01/20	P	S	0.06 P	>300 P	S	S	S	S	S
SUPPLY											
KRAMER 1:4 DISTRIBUTION	LA22414	17/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
AMP - DVI											
KRAMER 6X6 MATRIX - DVI	LA31766	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
KRAMER 6X6 MATRIX - DVI	LA26357	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
KRAMER 6X6 MATRIX - DVI	LA31303	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
LA 300 NETWORK SWITCH (1U	LA33400	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA35631	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA35632	17/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA33399	06/01/20	P	S	0.04 P	>300 P	S	S	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA33391	17/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA33396	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA33397	17/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA39067	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA39066	24/01/20	P	S	0.08 P	S	<0.05 P	0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA35636	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA39068	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA35633	04/03/20	P	S	0.02 P	2.11 P	S	S	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA39089	27/01/20	P	S	S	>300 P	S	S	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA35635	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA26980	17/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA26981	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											
LA 300 NETWORK SWITCH (1U	LA26982	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
RACK MOUNT)											

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33390	17/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA26983	04/03/20	P	S	0.02 P	2.11 P	S	S	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA39697	19/12/19	P	S	0.03 P	>300 P	S	S	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA39701	06/01/20	P	S	0.07 P	>300 P	S	S	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA42585	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA42584	19/12/19	P	S	0.06 P	>300 P	S	S	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA42582	18/02/20	P	S	0.09 P	>300 P	S	S	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA39702	06/01/20	P	S	0.09 P	>300 P	S	S	S	S	S
LIGHTWARE MX 16X16 DVI PLUS MATRIX	LA34749	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
LIGHTWARE MX 8X8 MATRIX DVI-D PRO SWITCHER	LA39179	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
LIGHTWARE MX 8X8 MATRIX DVI-D PRO SWITCHER	LA39178	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA41391	17/02/20	P	S	0.05 P	9.15 P	1.57 P	0.27 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA41389	14/02/20	P	S	0.07 P	6.41 P	1.50 P	0.22 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA41392	14/02/20	P	S	0.06 P	7.37 P	1.52 P	0.24 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17427	02/01/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17426	02/01/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA24064	02/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA24063	02/01/20	P	S	0.08 P	>300 P	0.64 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17809	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17312	02/01/20	P	S	0.07 P	>300 P	0.64 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA03908	02/01/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA04639	02/01/20	P	S	0.07 P	34.46 P	<0.05 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA03918	19/12/19	P	S	0.06 P	>300 P	0.49 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA03913	19/12/19	P	S	0.09 P	>300 P	0.78 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA24143	19/12/19	P	S	0.06 P	>300 P	0.83 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA03914	19/12/19	P	S	0.06 P	>300 P	0.55 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA34287	19/12/19	P	S	0.09 P	>300 P	0.77 P	<0.10 P	S	S	S
LSC GENVI 12 CHANNEL DIMMER RCBO	LA41889	04/03/20	P	S	0.05 P	>300 P	S	S	S	S	S
LSC GENVI 12 CHANNEL DIMMER RCBO	LA41890	04/03/20	P	S	0.05 P	>300 P	S	S	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38660	06/01/20	P	S	0.06 P	>300 P	S	S	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38431	06/01/20	P	S	0.04 P	>300 P	S	S	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38432	06/01/20	P	S	0.04 P	>300 P	S	S	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA37155	06/01/20	P	S	0.08 P	>300 P	S	S	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA41333	04/03/20	P	S	0.05 P	>300 P	S	S	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38659	06/01/20	P	S	0.04 P	>300 P	S	S	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38658	06/01/20	P	S	0.03 P	>300 P	S	S	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38657	04/03/20	P	S	0.06 P	>300 P	S	S	S	S	S
MAC AURA LED WASH	LA34622	19/02/20	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA XB LED WASH	LA41114	08/01/20	P	S	0.03 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41115	09/01/20	P	S	0.05 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41112	10/01/20	P	S	0.05 P	>300 P	0.06 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41113	10/01/20	P	S	0.05 P	>300 P	0.05 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41110	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41108	10/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41111	09/01/20	P	S	0.03 P	>300 P	0.06 P	0.40 P	S	S	S
MAC AURA XB LED WASH	LA41850	08/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41833	09/01/20	P	S	0.03 P	>300 P	0.05 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41830	08/01/20	P	S	0.03 P	>300 P	0.05 P	0.37 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC AURA XB LED WASH	LA41832	09/01/20	P	S	0.03 P	>300 P	0.05 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41834	08/01/20	P	S	0.05 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41848	09/01/20	P	S	0.05 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41829	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41831	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41856	15/01/20	P	S	0.04 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41046	16/01/20	P	S	0.03 P	>300 P	0.05 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41855	16/01/20	P	S	0.04 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41051	09/01/20	P	S	0.04 P	>300 P	0.05 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41064	10/01/20	P	S	0.05 P	>300 P	0.06 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41068	09/01/20	P	S	0.04 P	>300 P	0.06 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41065	10/01/20	P	S	0.06 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41851	10/01/20	P	S	0.04 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41069	10/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41071	10/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41846	10/01/20	P	S	0.04 P	>300 P	0.05 P	0.40 P	S	S	S
MAC AURA XB LED WASH	LA41072	08/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41073	09/01/20	P	S	0.03 P	>300 P	0.06 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41853	15/01/20	P	S	0.05 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41070	09/01/20	P	S	0.04 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41847	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41854	16/01/20	P	S	0.05 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41852	10/01/20	P	S	0.05 P	>300 P	0.05 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41053	10/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41050	10/01/20	P	S	0.03 P	>300 P	0.06 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41055	09/01/20	P	S	0.03 P	>300 P	0.05 P	0.42 P	S	S	S
MAC AURA XB LED WASH	LA41056	16/01/20	P	S	0.05 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41052	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.37 P	S	S	S
MAC AURA XB LED WASH	LA41049	10/01/20	P	S	0.05 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41047	15/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41057	09/01/20	P	S	0.04 P	>300 P	0.05 P	0.42 P	S	S	S
MAC AURA XB LED WASH	LA41048	10/01/20	P	S	0.05 P	>300 P	0.06 P	0.40 P	S	S	S
MAC AURA XB LED WASH	LA41058	15/01/20	P	S	0.03 P	>300 P	0.05 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41063	15/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41066	09/01/20	P	S	0.03 P	>300 P	0.05 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41067	09/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41062	16/01/20	P	S	0.04 P	>300 P	0.06 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41061	09/01/20	P	S	0.04 P	>300 P	0.05 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41054	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41059	09/01/20	P	S	0.03 P	>300 P	0.05 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41060	15/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41090	08/01/20	P	S	0.05 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41101	09/01/20	P	S	0.04 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41093	08/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41845	10/01/20	P	S	0.04 P	>300 P	0.06 P	0.42 P	S	S	S
MAC AURA XB LED WASH	LA41104	08/01/20	P	S	0.04 P	>300 P	0.06 P	0.37 P	S	S	S
MAC AURA XB LED WASH	LA41092	16/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41106	10/01/20	P	S	0.05 P	>300 P	0.06 P	0.40 P	S	S	S
MAC AURA XB LED WASH	LA41102	15/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41105	09/01/20	P	S	0.05 P	>300 P	0.06 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41849	10/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41099	15/01/20	P	S	0.03 P	>300 P	0.05 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41100	15/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41103	09/01/20	P	S	0.04 P	>300 P	0.05 P	0.36 P	S	S	S
MAC AURA XB LED WASH	LA41096	10/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41094	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41097	15/01/20	P	S	0.04 P	>300 P	0.06 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41098	10/01/20	P	S	0.05 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41095	09/01/20	P	S	0.08 P	>300 P	0.05 P	0.35 P	S	S	S
MAC AURA XB LED WASH	LA41077	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41081	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41084	09/01/20	P	S	0.03 P	>300 P	0.05 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41080	10/01/20	P	S	0.04 P	>300 P	0.06 P	0.37 P	S	S	S
MAC AURA XB LED WASH	LA41087	08/01/20	P	S	0.04 P	>300 P	0.05 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41082	10/01/20	P	S	0.07 P	>300 P	0.05 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41085	16/01/20	P	S	0.03 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41083	09/01/20	P	S	0.03 P	>300 P	0.06 P	0.41 P	S	S	S
MAC AURA XB LED WASH	LA41086	10/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41088	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC AURA XB LED WASH	LA41091	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41107	09/01/20	P	S	0.04 P	>300 P	0.05 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41089	15/01/20	P	S	0.04 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41109	08/01/20	P	S	0.04 P	>300 P	0.06 P	0.37 P	S	S	S
MAC AURA XB LED WASH	LA41079	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41076	15/01/20	P	S	0.03 P	>300 P	0.06 P	0.38 P	S	S	S
MAC AURA XB LED WASH	LA41074	10/01/20	P	S	0.03 P	>300 P	0.06 P	0.39 P	S	S	S
MAC AURA XB LED WASH	LA41075	09/01/20	P	S	0.04 P	>300 P	0.06 P	0.42 P	S	S	S
MAC QUANTUM LED PROFILE	LA37145	22/01/20	P	S	0.06 P	>300 P	0.08 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37142	22/01/20	P	S	0.05 P	>300 P	0.08 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37141	22/01/20	P	S	0.07 P	>300 P	0.08 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37144	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37143	22/01/20	P	S	0.05 P	>300 P	0.08 P	0.35 P	S	S	S
MAC QUANTUM LED PROFILE	LA37147	22/01/20	P	S	0.06 P	>300 P	0.08 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37146	22/01/20	P	S	0.04 P	>300 P	0.08 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37149	22/01/20	P	S	0.04 P	>300 P	0.08 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37148	22/01/20	P	S	0.06 P	>300 P	0.08 P	0.36 P	S	S	S
MAC QUANTUM LED WASH	LA37536	03/01/20	P	S	0.04 P	205.20 P	0.05 P	0.36 P	S	S	S
MAC QUANTUM LED WASH	LA37535	03/01/20	P	S	0.03 P	>300 P	<0.05 P	0.38 P	S	S	S
MAC QUANTUM LED WASH	LA37537	03/01/20	P	S	0.03 P	>300 P	0.06 P	0.35 P	S	S	S
MAC QUANTUM LED WASH	LA37540	03/01/20	P	S	0.05 P	177.30 P	0.06 P	0.36 P	S	S	S
MAC QUANTUM LED WASH	LA37538	03/01/20	P	S	0.04 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37123	03/01/20	P	S	0.04 P	>300 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34875	17/02/20	P	S	0.03 P	>300 P	<0.05 P	0.36 P	S	S	S
MAC QUANTUM LED WASH	LA34874	03/01/20	P	S	0.04 P	178.70 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34876	17/02/20	P	S	0.06 P	>300 P	<0.05 P	0.35 P	S	S	S
MAC QUANTUM LED WASH	LA34879	03/01/20	P	S	0.04 P	>300 P	<0.05 P	0.38 P	S	S	S
MAC QUANTUM LED WASH	LA34877	03/01/20	P	S	0.07 P	127.80 P	<0.05 P	0.37 P	S	S	S
MAC VIPER AIRFX	LA38654	15/01/20	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA34444	09/01/20	P	S	0.05 P	>300 P	<0.05 P	0.31 P	S	S	S
MAC VIPER AIRFX	LA34446	11/02/20	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA34448	02/03/20	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA34447	25/02/20	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA34441	21/02/20	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA34901	14/01/20	P	S	0.07 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA34442	03/02/20	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA34443	08/01/20	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA34449	15/01/20	P	S	0.05 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER AIRFX	LA37193	08/01/20	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37192	14/01/20	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37191	28/02/20	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37195	19/02/20	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37200	18/02/20	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37198	03/02/20	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37197	08/01/20	P	S	0.06 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA34908	20/02/20	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER AIRFX	LA37911	29/01/20	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER AIRFX	LA38388	08/01/20	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA38389	15/01/20	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37908	16/01/20	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA34905	13/02/20	P	S	0.04 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER AIRFX	LA34903	30/01/20	P	S	0.04 P	>300 P	<0.05 P	0.41 P	S	S	S
MAC VIPER AIRFX	LA34902	11/02/20	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37753	30/01/20	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37751	18/02/20	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37750	18/02/20	P	S	0.04 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER AIRFX	LA37799	21/02/20	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37905	16/01/20	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37904	03/02/20	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37902	08/01/20	P	S	0.08 P	>300 P	<0.05 P	0.34 P	S	S	S
MAC VIPER AIRFX	LA37748	17/02/20	P	S	0.06 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37356	27/02/20	P	S	0.04 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER AIRFX	LA37355	13/01/20	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37202	29/01/20	P	S	0.05 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER AIRFX	LA37359	25/02/20	P	S	0.06 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER AIRFX	LA37747	08/01/20	P	S	0.06 P	>300 P	<0.05 P	0.34 P	S	S	S
MAC VIPER AIRFX	LA37364	30/01/20	P	S	0.05 P	>300 P	<0.05 P	0.23 P	S	S	S
MAC VIPER AIRFX	LA37363	20/02/20	P	S	0.04 P	>300 P	<0.05 P	0.25 P	S	S	S
MAC VIPER AIRFX	LA38391	13/01/20	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC VIPER AIRFX	LA38392	16/01/20	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA44554	10/01/20	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA41378	24/02/20	P	S	0.04 P	>300 P	<0.05 P	0.42 P	S	S	S
MAC VIPER PROFILE	LA41376	09/01/20	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA37133	24/02/20	P	S	0.05 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA37131	21/01/20	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA41374	18/02/20	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA41164	14/01/20	P	S	0.07 P	>300 P	<0.05 P	0.42 P	S	S	S
MAC VIPER PROFILE	LA41373	29/01/20	P	S	0.03 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC VIPER PROFILE	LA41379	21/01/20	P	S	0.07 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA41372	14/01/20	P	S	0.05 P	>300 P	<0.05 P	0.39 P	S	S	S
MAC VIPER PROFILE	LA37719	14/01/20	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA37717	09/01/20	P	S	0.05 P	>300 P	<0.05 P	0.43 P	S	S	S
MAC VIPER PROFILE	LA37724	24/02/20	P	S	0.04 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA37726	29/01/20	P	S	0.04 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA37725	21/01/20	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA37138	09/01/20	P	S	0.04 P	>300 P	<0.05 P	0.42 P	S	S	S
MAC VIPER PROFILE	LA37135	24/02/20	P	S	0.05 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA37714	09/01/20	P	S	0.03 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA37715	09/01/20	P	S	0.08 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA41375	09/01/20	P	S	0.04 P	>300 P	<0.05 P	0.43 P	S	S	S
MAC VIPER PROFILE	LA34043	29/01/20	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA41167	18/02/20	P	S	0.05 P	>300 P	<0.05 P	0.40 P	S	S	S
MAC VIPER PROFILE	LA37731	04/02/20	P	S	0.05 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA34044	14/01/20	P	S	0.07 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA37728	29/01/20	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA37734	29/01/20	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA37735	24/02/20	P	S	0.07 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA37733	09/01/20	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA34042	18/02/20	P	S	0.07 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA34040	21/01/20	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA34234	21/01/20	P	S	0.06 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA34233	04/02/20	P	S	0.07 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA34235	04/02/20	P	S	0.05 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA41165	04/02/20	P	S	0.05 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA37129	09/01/20	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA34048	18/02/20	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA34045	21/01/20	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA34109	24/02/20	P	S	0.05 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA34231	29/01/20	P	S	0.04 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA34229	04/02/20	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA41171	09/01/20	P	S	0.05 P	>300 P	<0.05 P	0.41 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25690	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25684	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25685	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25697	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25695	14/02/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25692	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25682	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25727	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25728	14/02/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25730	14/02/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25726	24/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25679	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25675	24/02/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25725	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25699	14/02/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25716	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25715	24/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25714	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25719	24/02/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25724	24/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25723	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25720	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25704	24/02/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25703	24/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25702	24/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25705	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25711	24/02/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25709	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25706	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25735	24/02/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25742	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25740	24/02/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ ELECTRO	LA25738	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KABUKI MECHANISM											
MAGNET-SCHULTZ KABUKI	LA34343	24/02/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
CONTROLLER											
MAGNET-SCHULTZ KABUKI	LA34332	14/02/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
CONTROLLER											
MAGNET-SCHULTZ KABUKI	LA25972	24/02/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
CONTROLLER 16A EXT											
MARTIN ATOMIC 3000 DMX	LA26849	24/01/20	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26848	23/01/20	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26865	24/01/20	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26923	24/01/20	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26866	23/01/20	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26847	23/01/20	P	S	0.03 P	18.30 P	<0.05 P	0.28 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26554	23/01/20	P	S	0.05 P	>300 P	<0.05 P	0.28 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26553	23/01/20	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26552	24/01/20	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26846	23/01/20	P	S	0.02 P	>300 P	<0.05 P	0.27 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26555	23/01/20	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26924	23/01/20	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26535	24/01/20	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26536	23/01/20	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26534	24/01/20	P	S	0.06 P	150.20 P	<0.05 P	0.28 P	S	S	S
STROBE											
MARTIN ATOMIC 3000 DMX	LA26387	24/01/20	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
STROBE											
MARTIN ATOMIC 3000 DMX STROBE	LA26533	23/01/20	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26537	24/01/20	P	S	0.05 P	>300 P	<0.05 P	0.28 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA24810	24/01/20	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA24166	23/01/20	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA37551	23/01/20	P	S	0.03 P	>300 P	<0.05 P	0.26 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26550	24/01/20	P	S	0.06 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26551	23/01/20	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41385	24/01/20	P	S	0.08 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41386	24/01/20	P	S	0.04 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA44412	24/01/20	P	S	0.03 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA44414	24/01/20	P	S	0.02 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA44413	24/01/20	P	S	0.02 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41952	24/01/20	P	S	0.02 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41951	24/01/20	P	S	0.03 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41949	24/01/20	P	S	0.03 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41938	24/01/20	P	S	0.05 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41950	24/01/20	P	S	0.02 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41286	24/01/20	P	S	0.06 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41282	24/01/20	P	S	0.07 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41886	24/01/20	P	S	0.05 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41287	24/01/20	P	S	0.04 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41281	24/01/20	P	S	0.05 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA44416	24/01/20	P	S	0.02 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA44415	24/01/20	P	S	0.02 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA44417	24/01/20	P	S	0.02 P	>300 P	S	S	S	S	S
MARTIN IP66 PSU 240W	LA41388	24/01/20	P	S	0.07 P	>300 P	S	S	S	S	S
MARTIN P3 POWERPORT 1500	LA39439	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN P3 POWERPORT 1500	LA39438	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN P3 POWERPORT 1500	LA39440	17/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MEGA POINTE	LA41714	19/12/19	P	S	0.04 P	>300 P	0.14 P	0.15 P	S	S	S
MEGA POINTE	LA41709	06/01/20	P	S	0.03 P	>300 P	0.14 P	0.15 P	S	S	S
MEGA POINTE	LA41710	06/01/20	P	S	0.03 P	>300 P	0.14 P	0.15 P	S	S	S
MEGA POINTE	LA41712	20/12/19	P	S	0.07 P	>300 P	0.14 P	0.18 P	S	S	S
MEGA POINTE	LA41711	20/12/19	P	S	0.09 P	>300 P	0.14 P	0.16 P	S	S	S
MEGA POINTE	LA41713	24/02/20	P	S	0.07 P	>300 P	0.14 P	0.15 P	S	S	S
MEGA POINTE	LA41715	20/12/19	P	S	0.07 P	>300 P	0.14 P	0.17 P	S	S	S
MEGA POINTE	LA41705	19/12/19	P	S	0.04 P	>300 P	0.14 P	0.15 P	S	S	S
MEGA POINTE	LA41703	20/12/19	P	S	0.06 P	>300 P	0.14 P	0.16 P	S	S	S
MEGA POINTE	LA41704	19/12/19	P	S	0.03 P	>300 P	0.14 P	0.16 P	S	S	S
MEGA POINTE	LA41707	07/01/20	P	S	0.03 P	>300 P	0.13 P	0.16 P	S	S	S
MEGA POINTE	LA41708	19/12/19	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
MEGA POINTE	LA41706	07/01/20	P	S	0.03 P	>300 P	0.14 P	0.15 P	S	S	S
MIRROR BALL ROTATOR	LA37169	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA38489	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA24824	02/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA00885	02/01/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA02950	23/12/19	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34022	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34021	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34024	07/01/20	P	S	0.04 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34023	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34018	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34017	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34020	07/01/20	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34019	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34035	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34034	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34033	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34036	07/01/20	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34039	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34038	07/01/20	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34037	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MOLEFAY 2 LITE THOMAS	LA34032	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34027	07/01/20	P	S	0.04 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34026	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34025	07/01/20	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34028	07/01/20	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34031	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34030	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34029	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31656	07/01/20	P	S	0.04 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA26892	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA26891	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31657	07/01/20	P	S	0.04 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31851	19/12/19	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31850	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31849	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17920	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17919	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17918	07/01/20	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17921	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA26890	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17923	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17922	19/12/19	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31884	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31894	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31893	07/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31892	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31895	19/12/19	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34016	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34015	07/01/20	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34014	19/12/19	P	S	0.01 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31887	19/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31886	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31885	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31888	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31891	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31890	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31889	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26823	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26824	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26825	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26821	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26815	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26816	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26818	19/12/19	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26833	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26834	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26835	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26830	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26826	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26828	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26829	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26812	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24665	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24666	19/12/19	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MOLEFAY 4 LITE LINEAR THOMAS	LA24668	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24664	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24646	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24649	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24651	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26809	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26810	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26811	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26808	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24669	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24670	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26807	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21884	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21885	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21349	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21883	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21886	04/03/20	P	S	0.03 P	>300 P	1.32 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22224	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22765	05/03/20	P	S	0.08 P	>300 P	2.62 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21887	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21888	04/03/20	P	S	0.01 P	>300 P	2.57 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34862	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34863	19/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34341	04/03/20	P	S	0.01 P	>300 P	2.61 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34861	04/03/20	P	S	0.01 P	>300 P	2.60 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34864	04/03/20	P	S	0.01 P	>300 P	2.59 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21347	19/12/19	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21348	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21099	20/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21345	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22766	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34865	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34340	04/03/20	P	S	0.02 P	>300 P	2.58 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22865	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34866	04/03/20	P	S	0.03 P	>300 P	2.63 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34867	20/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34868	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MOLEFAY 4 LITE SQUARE THOMAS	LA22768	05/03/20	P	S	0.09 P	>300 P	1.31 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22769	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22770	07/01/20	P	S	0.04 P	>300 P	2.46 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22864	04/03/20	P	S	0.01 P	>300 P	2.63 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22771	19/12/19	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22767	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOTOROLA GP340 6 WAY CHARGER	LA37630	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
MTP FIBRE BREAKOUT BOX - STAGE	LA33474	04/03/20	P	S	0.06 P	>300 P	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA24733	17/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA38435	30/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA38794	17/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA24735	17/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA17752	17/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA25880	17/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA26934	17/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA17751	17/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA38796	17/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA38795	17/01/20	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA38793	17/01/20	S	S	S	S	S	S	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25135	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25142	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25144	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25146	02/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25138	02/01/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25140	02/01/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25141	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37089	08/01/20	P	S	0.09 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37079	08/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37087	07/01/20	P	S	0.08 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37081	08/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37082	07/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37078	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37072	07/01/20	P	S	0.08 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37071	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37074	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37076	08/01/20	P	S	0.09 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37075	07/01/20	P	S	0.09 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34974	19/12/19	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34968	19/12/19	P	S	0.04 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37030	19/12/19	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37028	19/12/19	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PARCAN											
PAR 56 SHORT NOSE BLACK PARCAN	LA34969	19/12/19	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34972	19/12/19	P	S	0.04 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34973	19/12/19	P	S	0.04 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34970	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34971	19/12/19	P	S	0.07 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37032	19/12/19	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37035	19/12/19	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37036	19/12/19	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37033	19/12/19	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37034	19/12/19	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA20635	05/03/20	P	S	0.07 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA24300	14/02/20	P	S	0.06 P	>300 P	1.05 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA15293	14/02/20	P	S	0.06 P	>300 P	1.05 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21176	19/12/19	P	S	0.03 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21177	19/12/19	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21178	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22261	19/12/19	P	S	0.04 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22857	19/12/19	P	S	0.03 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22856	19/12/19	P	S	0.03 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22262	19/12/19	P	S	0.03 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21165	19/12/19	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21166	19/12/19	P	S	0.04 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21164	19/12/19	P	S	0.04 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA16792	19/12/19	P	S	0.03 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21168	19/12/19	P	S	0.03 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21174	19/12/19	P	S	0.03 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21175	19/12/19	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21169	19/12/19	P	S	0.08 P	>300 P	0.53 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21170	19/12/19	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22858	19/12/19	P	S	0.03 P	>300 P	0.54 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22861	19/12/19	P	S	0.03 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22860	19/12/19	P	S	0.03 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22859	19/12/19	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30375	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30378	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA26092	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA26341	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30380	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35096	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA39479	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30382	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA32900	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA35132	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA46642	10/02/20	S	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA42109	18/02/20	S	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA46641	10/02/20	S	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA35102	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA32904	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34859	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34935	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34939	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34938	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34858	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34857	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34936	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34937	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA44390	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38270	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38266	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38265	17/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA42157	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40290	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40289	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA46662	29/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA46660	29/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40288	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40417	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40420	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40971	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40972	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40975	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40968	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40976	07/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40973	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40974	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40967	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40416	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40408	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40407	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40409	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA30386	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40404	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA16308	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40406	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40405	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40403	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40413	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40412	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40415	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40414	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40402	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40401	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40411	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40410	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44147	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44124	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44144	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44156	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40986	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42433	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42986	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42990	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42987	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42431	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40391	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42432	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40969	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42450	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42421	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42420	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42437	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42422	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42418	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42415	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42414	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42417	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42416	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42436	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42425	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42426	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42423	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42424	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42427	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42430	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42435	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42428	29/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42429	22/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42444	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42445	29/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42442	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42443	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42446	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42406	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42449	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42448	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42407	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42441	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42412	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42411	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42413	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42434	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42409	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42439	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42440	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42408	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42438	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44146	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42486	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42487	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42488	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42485	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42482	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42483	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42484	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42489	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42494	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42495	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42496	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42493	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42490	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42491	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42492	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40978	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40977	16/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44138	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40979	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40982	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40981	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40980	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44108	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42286	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42285	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42481	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42279	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42275	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42280	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42287	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42497	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44117	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44125	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44110	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44111	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42501	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44121	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44127	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44131	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42505	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44128	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44143	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42504	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44152	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42502	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42503	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42278	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42282	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42272	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42276	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42498	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42499	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42500	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42288	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42284	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42273	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42271	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42289	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42281	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42283	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42277	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44149	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44153	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44116	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44130	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44140	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44137	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44136	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44120	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44154	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44139	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44119	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44122	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44109	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44132	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44155	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42451	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44133	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44123	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44126	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44142	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44107	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44134	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44148	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44114	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44118	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44129	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44145	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44141	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44112	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA44113	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42452	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42471	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42473	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42474	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42470	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42467	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42468	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42469	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42475	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42480	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40984	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40983	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42479	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42476	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42477	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42478	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42457	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42455	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42459	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42458	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42454	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42453	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42274	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42270	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42464	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42463	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42466	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42465	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42460	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42461	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42462	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40644	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40643	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40645	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40647	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40646	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40639	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40637	17/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40640	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40642	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40641	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40648	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40665	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40666	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40667	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40662	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40663	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40664	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40668	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40672	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40675	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40676	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40669	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40670	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40671	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40652	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40653	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40654	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40649	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40650	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40651	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40655	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40659	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40660	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40661	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40656	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40657	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40658	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40609	12/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40610	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40607	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40608	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40611	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40614	16/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40615	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40612	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40613	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40606	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40599	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40600	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40597	12/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40598	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40601	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40604	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40605	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40602	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40603	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40616	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40630	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40631	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40628	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40629	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40632	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40635	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40636	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40633	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40634	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40627	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40619	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40621	29/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40617	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40618	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40622	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40625	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40626	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40623	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40624	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46036	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46032	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46004	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46042	27/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46003	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46689	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46691	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46043	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34773	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34770	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46050	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA42183	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46698	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34769	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46023	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46034	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46009	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46696	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46699	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46690	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46033	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46701	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46020	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46688	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46695	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46697	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46035	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46015	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46014	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46013	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34766	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46017	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46016	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA42176	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA42180	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA42985	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46011	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34767	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA46010	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34763	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34764	27/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34758	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34760	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35590	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32621	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32420	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32421	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32622	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32626	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32625	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32623	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32624	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32419	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35591	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35592	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40865	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40866	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA39087	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32417	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32418	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32415	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32416	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35583	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32628	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35585	12/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35584	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32629	07/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40589	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32632	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32630	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32631	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40583	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35587	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35586	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32620	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35588	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32619	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40585	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40584	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32618	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32617	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40848	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40849	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40847	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40845	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40846	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40581	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40590	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40852	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40850	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40851	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40844	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40573	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40837	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40572	18/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40574	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40575	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40842	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40843	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40840	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40838	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40839	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40586	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40580	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40860	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40859	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40857	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40858	31/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE TRS 10FT	LA40863	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40864	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40582	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40861	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40862	12/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40856	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40576	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40577	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40571	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40588	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40587	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40854	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40855	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40853	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40579	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40578	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36308	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36309	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36354	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36353	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36352	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36306	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36311	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36314	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36307	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36310	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36332	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36335	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36334	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36318	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36319	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36320	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36331	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36343	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36341	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36316	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36336	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36333	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36339	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36344	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36349	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36321	11/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36350	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36340	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36342	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36347	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36328	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36327	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36317	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36323	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36324	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36326	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40593	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40592	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40594	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40596	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40595	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40591	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36348	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36346	10/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36345	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36313	22/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36312	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40565	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40557	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40547	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40570	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40556	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40554	23/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE TRS 5FT	LA40544	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40550	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40567	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40564	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40566	21/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40563	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40805	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40558	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40806	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40808	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40807	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40560	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40553	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40552	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40549	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40562	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40559	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40542	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40790	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40791	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40789	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40787	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40788	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40792	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40797	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40798	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40796	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40793	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40794	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40799	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40568	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40541	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40545	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40569	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40546	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40555	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40801	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40800	12/02/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40802	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40561	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40803	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40809	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32411	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32413	16/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32410	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32408	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32409	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35625	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35629	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35630	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35628	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32414	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA33783	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35626	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32407	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32405	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA42317	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA42292	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA42316	27/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32404	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32400	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32399	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32401	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32403	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32402	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40836	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40818	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40817	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40819	08/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE TRS 5FT	LA40821	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40820	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40816	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40811	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40810	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40812	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40815	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40813	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40822	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40831	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40830	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40832	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40835	23/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40834	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40829	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40824	24/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40823	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40826	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40828	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40827	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40913	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40912	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40911	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40916	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40915	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40914	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40907	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40906	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40905	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40910	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40909	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40908	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40490	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40491	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40492	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40489	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40485	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40486	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40488	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40493	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40498	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40499	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40500	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40497	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40494	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA40495	31/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5	LA40496	08/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40473	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40474	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40475	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40471	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40899	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40898	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40897	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40476	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40481	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40482	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40484	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40480	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40477	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40478	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40479	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40520	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40896	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40895	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40519	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40516	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40517	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40518	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40894	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40889	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40888	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40887	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40890	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40893	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40892	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40891	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40505	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40506	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40507	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40504	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40501	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40502	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40503	31/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40508	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40513	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40514	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40515	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40512	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40509	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40510	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40511	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39940	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39939	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39938	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39941	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39944	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39943	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39942	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39937	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39932	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39931	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39930	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39933	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39936	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39935	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39934	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39955	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39954	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39953	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39956	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39959	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39958	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39957	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39952	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39947	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39946	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39945	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39948	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39951	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39950	08/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39949	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39929	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39693	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39692	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40902	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40901	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39696	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39695	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39694	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39689	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39690	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39691	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39688	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40903	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40904	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39687	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39915	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39924	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39923	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39922	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39925	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39928	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39927	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39926	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39917	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39916	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40900	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39918	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39921	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39920	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39919	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40537	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40536	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40539	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40538	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40535	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40526	08/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40527	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40528	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40521	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40522	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40525	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40532	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40533	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40534	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40529	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40530	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40531	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA33030	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA38959	22/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40459	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40458	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40460	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40462	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40461	23/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40454	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40453	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40455	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40457	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40456	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40463	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40886	23/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40470	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40885	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40883	22/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40884	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40465	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40464	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40467	23/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40469	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40468	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40452	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA39680	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA39681	08/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 5FT POWERCON TRUE XLR5	LA39679	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA35993	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA39677	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA39685	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA39686	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA39684	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA39682	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA39683	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA35981	27/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA30417	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA30644	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40449	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40451	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40450	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA33172	23/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA33174	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA33169	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA30647	30/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA33149	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40436	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40437	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40435	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40433	30/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40434	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40441	30/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40442	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40440	30/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40438	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40439	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40432	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40425	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40426	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40423	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40421	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40422	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT POWERCON TRUE XLR5	LA40430	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5	LA40431	08/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40429	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40427	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40428	30/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40443	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40876	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40877	30/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40875	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40873	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40874	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40881	30/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40882	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40880	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40878	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40879	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40872	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40447	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40448	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40446	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40444	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40445	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40870	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40871	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40869	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40867	31/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40868	08/01/20	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON XLR3 COMBI	LA30397	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30398	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30396	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30394	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30395	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30408	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30407	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30406	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30409	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30413	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30412	31/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30411	09/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 10FT											
POWERCON XLR3 COMBI	LA30401	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30400	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30399	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30402	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30405	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30404	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30403	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30742	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30745	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30747	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30729	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30737	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30739	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33864	21/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33862	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33866	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33869	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33868	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33860	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33855	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33854	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33856	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33859	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33858	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33878	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33877	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33879	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA42615	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33880	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33876	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33871	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33870	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33872	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33875	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33873	31/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33032	21/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33031	21/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 10FT											
POWERCON XLR5 COMBI	LA33034	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33036	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33035	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30662	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30654	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30653	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30657	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30661	21/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30660	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33845	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33844	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33846	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33851	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33847	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33049	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33041	31/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33037	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33045	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33047	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33046	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33182	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33181	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33179	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA42200	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33184	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33183	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33191	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33190	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33189	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA25282	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33195	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33192	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33884	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33052	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33053	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25405	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33051	30/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 20FT											
POWERCON XLR5 COMBI	LA33057	31/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33058	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33054	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33055	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33905	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33890	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33889	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA38996	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33891	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33894	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33893	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33892	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33885	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25402	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25403	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33886	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA39002	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33888	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33887	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33898	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33896	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33895	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33899	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33901	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33903	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33904	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25230	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 3FT											
POWERCON XLR5 COMBI	LA30646	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30645	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30643	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33144	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33141	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33143	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30649	31/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30650	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33145	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35980	09/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 5FT											
POWERCON XLR5 COMBI	LA33175	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33170	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35985	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35984	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35983	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33148	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33147	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33146	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33167	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33166	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33150	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30434	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA24520	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA25236	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44485	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44475	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44473	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA26353	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30415	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA25247	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA25242	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA25245	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44482	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30425	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30423	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30427	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30430	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30428	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44484	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44474	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30416	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30422	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30419	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35987	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44479	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44477	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44480	09/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 5FT											
POWERCON XLR5 COMBI	LA44478	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44489	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44490	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44492	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44486	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40212	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40211	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40210	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40214	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44487	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44488	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40216	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44496	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44029	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44471	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44464	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44470	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA42311	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44463	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44460	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44472	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44462	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44465	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44467	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44469	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44494	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44468	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA44461	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA38801	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35999	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35998	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA38802	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40188	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40187	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA38804	30/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35996	09/01/20	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35990	30/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 5FT											
POWERCON XLR5 COMBI CABLE 5FT	LA35989	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA35988	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA35991	09/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA35995	09/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA35994	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA35992	08/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40189	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40201	09/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40200	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40199	09/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40208	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40203	09/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40206	09/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40207	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40198	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40194	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40195	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40193	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40190	30/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40191	09/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40196	09/01/20	S	S	S	S	S	S	S	S	S
POWERCON XLR5 COMBI CABLE 5FT	LA40197	09/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK - 125A 3PH ADAPTOR 3M	LA32471	12/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK - 125A 3PH ADAPTOR 3M	LA22671	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK - 125A 3PH ADAPTOR 3M	LA26974	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK - 125A 3PH ADAPTOR 3M	LA30795	12/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK - 125A 3PH ADAPTOR 3M	LA30796	12/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA21431	09/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA31372	17/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA22247	09/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA42573	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA42572	20/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA22244	10/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA22243	10/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA22246	21/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK - 63A 3PH ADAPTOR 3M	LA42325	09/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA42853	24/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERLOCK LINK E 1.5M	LA42696	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33469	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33468	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33467	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33466	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA42698	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38830	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38833	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38834	31/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38832	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33465	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38831	17/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38835	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38809	31/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38806	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA42653	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38808	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38811	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38807	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38810	17/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33447	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33446	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33445	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33448	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA42658	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA42837	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33449	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA38812	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA42659	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA42665	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA38815	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA38814	17/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA38813	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA33452	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA33451	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA33450	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA35196	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA33454	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA33453	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA38817	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.5M	LA38816	31/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38819	17/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38820	31/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38821	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA42677	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33455	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38818	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33459	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33458	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA42859	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA42678	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38823	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38822	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33457	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33456	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33464	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA42688	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA42685	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33463	23/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33460	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33461	24/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33462	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38827	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38828	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38829	31/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38826	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA42848	22/01/20	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38824	13/12/19	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38825	17/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS ARENACOB FULL COLOUR	LA41144	28/01/20	P	S	0.05 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41142	13/02/20	P	S	0.04 P	>300 P	<0.05 P	0.23 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41145	13/02/20	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41302	28/01/20	P	S	0.03 P	>300 P	<0.05 P	0.26 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41148	28/01/20	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38099	28/01/20	P	S	0.04 P	>300 P	<0.05 P	0.26 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38111	28/01/20	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38117	28/01/20	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38109	28/01/20	P	S	0.04 P	>300 P	<0.05 P	0.26 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38102	06/02/20	P	S	0.04 P	>300 P	<0.05 P	0.18 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38104	28/01/20	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38080	27/01/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38082	28/01/20	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38074	14/02/20	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38665	13/02/20	P	S	0.04 P	>300 P	<0.05 P	0.23 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41297	13/02/20	P	S	0.04 P	>300 P	<0.05 P	0.24 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38089	28/01/20	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA44624	17/01/20	P	S	0.04 P	>300 P	<0.05 P	0.23 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38124	28/01/20	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38128	27/01/20	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38093	28/01/20	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38399	27/01/20	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38258	27/01/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38260	06/02/20	P	S	0.05 P	>300 P	<0.05 P	0.19 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38067	06/02/20	P	S	0.07 P	>300 P	<0.05 P	0.21 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38068	06/02/20	P	S	0.06 P	>300 P	<0.05 P	0.21 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38071	27/01/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38066	06/02/20	P	S	0.05 P	>300 P	<0.05 P	0.20 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38062	06/02/20	P	S	0.06 P	>300 P	<0.05 P	0.22 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38061	27/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38064	27/01/20	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38254	27/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38256	27/01/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38253	06/02/20	P	S	0.05 P	>300 P	<0.05 P	0.19 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38250	06/02/20	P	S	0.07 P	>300 P	<0.05 P	0.21 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38252	27/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE BACK END	LA41314	05/03/20	P	S	0.06 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE BACK END	LA41317	05/03/20	P	S	0.05 P	>300 P	0.05 P	0.27 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE BACK END	LA41964	05/03/20	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE BACK END	LA41960	05/03/20	P	S	0.04 P	>300 P	<0.05 P	0.32 P	S	S	S
PROLIGHTS FLATPAR 3Q	LA41616	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS FLATPAR 3Q	LA41615	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS FLATPAR 3Q	LA41614	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS FLATPAR 3Q	LA41612	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS FLATPAR 3Q	LA41613	19/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38180	06/03/20	P	S	0.04 P	>300 P	0.07 P	0.86 P	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38179	06/03/20	P	S	0.04 P	>300 P	0.07 P	0.87 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38178	06/03/20	P	S	0.05 P	>300 P	0.07 P	0.85 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38181	06/03/20	P	S	0.05 P	>300 P	0.07 P	0.83 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38336	06/03/20	P	S	0.07 P	>300 P	0.07 P	0.92 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38183	06/03/20	P	S	0.06 P	>300 P	0.07 P	0.84 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38182	06/03/20	P	S	0.06 P	>300 P	0.07 P	0.89 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38173	06/03/20	P	S	0.05 P	>300 P	0.07 P	0.90 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38059	06/03/20	P	S	0.05 P	>300 P	0.07 P	0.83 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38058	06/03/20	P	S	0.05 P	>300 P	0.07 P	0.90 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38174	06/03/20	P	S	0.06 P	>300 P	0.07 P	0.84 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38177	06/03/20	P	S	0.05 P	>300 P	0.07 P	0.85 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38176	06/03/20	P	S	0.04 P	>300 P	0.07 P	0.84 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38175	06/03/20	P	S	0.04 P	>300 P	0.07 P	0.85 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38493	30/01/20	P	S	0.06 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37765	30/01/20	P	S	0.05 P	>300 P	0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38495	14/02/20	P	S	0.06 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38494	30/01/20	P	S	0.09 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37764	30/01/20	P	S	0.06 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37761	14/02/20	P	S	0.07 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37760	30/01/20	P	S	0.09 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37763	30/01/20	P	S	0.08 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37762	30/01/20	P	S	0.06 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38500	30/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38499	14/02/20	P	S	0.08 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38502	30/01/20	P	S	0.09 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38501	14/02/20	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38503	30/01/20	P	S	0.06 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38497	30/01/20	P	S	0.06 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38496	30/01/20	P	S	0.08 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38504	14/02/20	P	S	0.07 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA38498	30/01/20	P	S	0.07 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37759	30/01/20	P	S	0.06 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37646	30/01/20	P	S	0.07 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37645	30/01/20	P	S	0.08 P	>300 P	0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37647	30/01/20	P	S	0.09 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37671	14/02/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37648	30/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37644	30/01/20	P	S	0.09 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37639	14/02/20	P	S	0.05 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37638	14/02/20	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37640	14/02/20	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37643	30/01/20	P	S	0.06 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37641	30/01/20	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37756	30/01/20	P	S	0.06 P	>300 P	0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37757	14/02/20	P	S	0.05 P	>300 P	<0.05 P	0.10 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37754	30/01/20	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37755	14/02/20	P	S	0.05 P	>300 P	<0.05 P	0.11 P	S	S	S
PROLIGHTS SMARTBATIP BATTERY LED PROJECTOR	LA37758	30/01/20	P	S	0.07 P	>300 P	0.05 P	0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38685	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38694	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38749	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38740	20/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38746	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38672	20/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38676	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38668	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38693	22/01/20	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38690	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38738	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38715	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38718	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38728	22/01/20	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38707	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38703	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38704	18/02/20	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38706	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38729	20/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38687	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38735	20/12/19	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38736	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38695	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38731	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38700	20/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBFC FULL COLOUR	LA41526	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS STUDIOCOBUV LED UV	LA38021	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38020	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38019	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38202	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38203	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38204	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38201	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38198	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38199	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38200	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38209	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38210	23/12/19	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38029	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38208	23/12/19	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38205	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38206	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38207	22/01/20	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38188	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38189	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38190	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38187	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38030	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38185	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38186	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38195	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38196	23/12/19	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38197	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38194	23/12/19	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38191	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38192	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38193	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38028	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38226	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38219	23/12/19	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38220	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38215	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38216	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROLIGHTS STUDIOCOBUV LED UV	LA38217	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38221	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38225	23/12/19	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38023	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38024	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38222	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38223	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38224	22/01/20	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38027	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38212	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38213	22/01/20	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38022	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38218	22/01/20	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38211	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38026	23/12/19	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38025	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38214	23/12/19	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS WIFIBOX WIFI/DMX INTERFACE	LA37649	30/01/20	P	S	S	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34886	23/12/19	P	S	0.04 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34884	18/02/20	P	S	0.06 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34934	23/12/19	P	S	0.05 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA37468	23/12/19	P	S	0.03 P	>300 P	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34887	16/12/19	P	S	0.06 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34888	16/12/19	P	S	0.07 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA44508	06/01/20	P	S	0.05 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA44509	16/12/19	P	S	0.03 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA44510	16/12/19	P	S	0.04 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA44505	16/12/19	P	S	0.06 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA44506	06/01/20	P	S	0.07 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA44507	23/12/19	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34883	06/01/20	P	S	0.09 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34304	16/12/19	P	S	0.07 P	S	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34303	16/12/19	P	S	0.08 P	S	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34326	23/12/19	P	S	0.07 P	>300 P	<0.05 P	0.16 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34305	16/12/19	P	S	0.03 P	S	<0.05 P	0.16 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34300	16/12/19	P	S	0.03 P	S	<0.05 P	0.17 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA26968	16/12/19	P	S	0.04 P	S	<0.05 P	0.15 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROPLEX DMX OPTO ISOLATOR	LA34302	16/12/19	P	S	0.05 P	S	<0.05 P	0.19 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34301	06/01/20	P	S	0.08 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34327	16/12/19	P	S	0.05 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34806	16/12/19	P	S	0.05 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34805	18/02/20	P	S	0.04 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34808	23/12/19	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34807	06/01/20	P	S	0.06 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34329	16/12/19	P	S	0.06 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34328	16/12/19	P	S	0.04 P	S	<0.05 P	0.16 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34804	16/12/19	P	S	0.09 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34803	18/02/20	P	S	0.05 P	>300 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41310	16/12/19	P	S	0.09 P	S	<0.05 P	0.26 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41311	16/12/19	P	S	0.07 P	S	<0.05 P	0.25 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41312	16/12/19	P	S	0.05 P	S	<0.05 P	0.26 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41307	16/12/19	P	S	0.09 P	S	<0.05 P	0.25 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41308	16/12/19	P	S	0.06 P	S	<0.05 P	0.26 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41309	16/12/19	P	S	0.02 P	S	<0.05 P	0.25 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38303	16/12/19	P	S	0.07 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38304	04/03/20	P	S	0.05 P	2.11 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38301	04/03/20	P	S	0.06 P	>300 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38302	04/03/20	P	S	0.05 P	2.11 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38516	16/12/19	P	S	0.08 P	S	<0.05 P	0.25 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38517	16/12/19	P	S	0.06 P	S	<0.05 P	0.26 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38305	16/12/19	P	S	0.07 P	S	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38306	04/03/20	P	S	0.05 P	2.11 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38300	04/03/20	P	S	0.05 P	>300 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38294	16/12/19	P	S	0.03 P	S	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38295	04/03/20	P	S	0.06 P	>300 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38031	16/12/19	P	S	0.07 P	S	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38032	16/12/19	P	S	0.02 P	S	<0.05 P	0.17 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38298	04/03/20	P	S	0.05 P	2.11 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38299	16/12/19	P	S	0.02 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38296	16/12/19	P	S	0.07 P	S	<0.05 P	0.18 P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38297	04/03/20	P	S	0.05 P	>300 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38518	04/03/20	P	S	0.04 P	2.11 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38519	04/03/20	P	S	0.04 P	2.11 P	S	S	S	S	S
PROPLEX SCENE SWITCH 8	LA38371	06/01/20	P	S	0.03 P	>300 P	S	S	S	S	S
PROPLEX SCENE SWITCH 8	LA41187	16/12/19	P	S	0.06 P	S	<0.05 P	0.17 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PROPLEX SCENE SWITCH 8	LA41186	16/12/19	P	S	0.04 P	S <0.05 P	0.25 P	S	S	S	
PROPLEX SCENE SWITCH 8	LA38370	16/12/19	P	S	0.08 P	S <0.05 P	0.17 P	S	S	S	
PROPLEX SCENE SWITCH 8	LA38369	04/03/20	P	S	0.04 P	>300 P S	S	S	S	S	
PROPLEX SCENE SWITCH 8	LA38368	04/03/20	P	S	0.04 P	>300 P S	S	S	S	S	
PULSAR UNI PAK 10A DIMMER	LA44649	10/02/20	P	S	0.07 P	>300 P <0.05 P	<0.10 P	S	S	S	
PULSAR UNI PAK 10A DIMMER	LA41739	10/02/20	P	S	0.06 P	>300 P <0.05 P	<0.10 P	S	S	S	
PULSAR UNI PAK 10A DIMMER	LA44657	17/02/20	P	S	0.06 P	>300 P <0.05 P	<0.10 P	S	S	S	
PULSAR UNI PAK 10A DIMMER	LA22933	24/01/20	P	S	S	>300 P S	S	S	S	S	
PULSAR UNI PAK 10A DIMMER	LA22937	24/01/20	P	S	S	>300 P S	S	S	S	S	
REEL FX DF50 CRACKER	LA25006	24/01/20	P	S	0.06 P	>300 P 0.37 P	<0.10 P	S	S	S	
REEL FX DF50 CRACKER	LA24941	10/02/20	P	S	0.08 P	>300 P 0.36 P	<0.10 P	S	S	S	
REEL FX DF50 CRACKER	LA31432	10/02/20	P	S	0.09 P	>300 P 0.49 P	<0.10 P	S	S	S	
REEL FX DF50 CRACKER	LA31431	27/01/20	P	S	0.06 P	>300 P <0.05 P	<0.10 P	S	S	S	
ROBE MEGA POINTE	LA44360	20/12/19	P	S	0.06 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44359	20/12/19	P	S	0.07 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44358	19/12/19	P	S	0.04 P	>300 P 0.14 P	0.16 P	S	S	S	
ROBE MEGA POINTE	LA44377	20/12/19	P	S	0.06 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44362	07/01/20	P	S	0.03 P	>300 P 0.14 P	0.16 P	S	S	S	
ROBE MEGA POINTE	LA44361	20/12/19	P	S	0.06 P	>300 P 0.14 P	0.19 P	S	S	S	
ROBE MEGA POINTE	LA41690	19/12/19	P	S	0.04 P	>300 P 0.14 P	0.15 P	S	S	S	
ROBE MEGA POINTE	LA44500	20/12/19	P	S	0.07 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44434	20/12/19	P	S	0.07 P	>300 P 0.14 P	0.16 P	S	S	S	
ROBE MEGA POINTE	LA44432	19/12/19	P	S	0.05 P	>300 P 0.14 P	0.16 P	S	S	S	
ROBE MEGA POINTE	LA44501	06/01/20	P	S	0.03 P	>300 P 0.14 P	0.15 P	S	S	S	
ROBE MEGA POINTE	LA44502	07/01/20	P	S	0.03 P	>300 P 0.14 P	0.16 P	S	S	S	
ROBE MEGA POINTE	LA44504	20/12/19	P	S	0.06 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44376	20/12/19	P	S	0.06 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44367	19/12/19	P	S	0.04 P	>300 P 0.14 P	0.17 P	S	S	S	
ROBE MEGA POINTE	LA44366	04/03/20	P	S	0.04 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44365	19/12/19	P	S	0.03 P	>300 P 0.14 P	0.16 P	S	S	S	
ROBE MEGA POINTE	LA44363	19/12/19	P	S	0.04 P	>300 P <0.05 P	0.32 P	S	S	S	
ROBE MEGA POINTE	LA44369	06/01/20	P	S	0.02 P	>300 P 0.14 P	0.16 P	S	S	S	
ROBE MEGA POINTE	LA44368	06/01/20	P	S	0.02 P	>300 P 0.14 P	0.16 P	S	S	S	
ROBE MEGA POINTE	LA44364	19/12/19	P	S	0.03 P	>300 P 0.14 P	0.17 P	S	S	S	
ROBE MEGA POINTE	LA44373	07/01/20	P	S	0.04 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44374	19/12/19	P	S	0.03 P	>300 P 0.14 P	0.17 P	S	S	S	
ROBE MEGA POINTE	LA44375	20/12/19	P	S	0.06 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44370	19/12/19	P	S	0.03 P	>300 P <0.05 P	0.32 P	S	S	S	
ROBE MEGA POINTE	LA44371	19/12/19	P	S	0.03 P	>300 P 0.14 P	0.17 P	S	S	S	
ROBE MEGA POINTE	LA44372	06/01/20	P	S	0.03 P	>300 P 0.14 P	0.16 P	S	S	S	
ROBE MEGA POINTE	LA44433	19/12/19	P	S	0.07 P	>300 P <0.05 P	0.30 P	S	S	S	
ROBE MEGA POINTE	LA44431	11/02/20	P	S	0.07 P	>300 P 0.14 P	0.18 P	S	S	S	
ROBE MEGA POINTE	LA44430	19/12/19	P	S	0.06 P	>300 P 0.14 P	0.25 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41491	14/01/20	P	S	0.03 P	>300 P <0.05 P	0.20 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41502	14/01/20	P	S	0.03 P	>300 P <0.05 P	0.19 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41508	14/01/20	P	S	0.04 P	>300 P <0.05 P	0.19 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41513	14/01/20	P	S	0.04 P	>300 P <0.05 P	0.18 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41494	14/01/20	P	S	0.03 P	>300 P <0.05 P	0.18 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41497	14/01/20	P	S	0.03 P	>300 P <0.05 P	0.18 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41505	14/01/20	P	S	0.05 P	>300 P <0.05 P	0.18 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41504	14/01/20	P	S	0.05 P	>300 P <0.05 P	0.18 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41486	14/01/20	P	S	0.03 P	>300 P <0.05 P	0.19 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41509	14/01/20	P	S	0.03 P	>300 P <0.05 P	0.18 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41498	14/01/20	P	S	0.03 P	>300 P <0.05 P	0.18 P	S	S	S	
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41501	14/01/20	P	S	0.04 P	>300 P <0.05 P	0.19 P	S	S	S	
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA37934	09/01/20	P	S	0.09 P	>300 P <0.05 P	<0.10 P	S	S	S	
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA37962	07/01/20	P	S	0.07 P	>300 P <0.05 P	<0.10 P	S	S	S	

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA34741	07/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA34743	07/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA37973	09/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA37457	07/01/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA37396	06/02/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA37974	07/01/20	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA37961	07/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA41460	09/01/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT FLO 1800 MSR FOLLOW SPOT BALLAST	LA34745	09/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBERT JULIAT LANCELOT 4K FOLLOW SPOT 2/5 DEG	LA38047	27/02/20	P	S	0.09 P	>300 P	0.28 P	2.78 P	S	S	S
ROBERT JULIAT LANCELOT 4K FOLLOW SPOT 2/5 DEG	LA37447	27/02/20	P	S	0.10 P	>300 P	0.26 P	3.00 P	S	S	S
ROBERT JULIAT LANCELOT 4K FOLLOW SPOT BALLAST	LA37258	27/02/20	P	S	0.09 P	>300 P	0.28 P	2.96 P	S	S	S
ROBERT JULIAT LANCELOT 4K FOLLOW SPOT BALLAST	LA37124	27/02/20	P	S	0.10 P	>300 P	0.27 P	3.01 P	S	S	S
ROBERT JULIAT LANCELOT 4K FOLLOW SPOT BALLAST	LA38049	27/02/20	P	S	0.10 P	>300 P	0.28 P	2.87 P	S	S	S
ROCKSWITCH 8 PRO DMX / ETHERNET SWITCH	LA37390	16/12/19	P	S	0.09 P	S	<0.05 P	0.45 P	S	S	S
ROCKSWITCH 8 PRO DMX / ETHERNET SWITCH	LA37400	16/12/19	P	S	0.06 P	S	<0.05 P	0.45 P	S	S	S
ROCKSWITCH 8 PRO DMX / ETHERNET SWITCH	LA38359	16/12/19	P	S	0.05 P	S	<0.05 P	<0.10 P	S	S	S
ROCKSWITCH 8 PRO DMX / ETHERNET SWITCH	LA37389	16/12/19	P	S	0.05 P	S	<0.05 P	0.46 P	S	S	S
ROCKSWITCH 8 PRO DMX / ETHERNET SWITCH	LA38358	16/12/19	P	S	0.05 P	S	<0.05 P	<0.10 P	S	S	S
ROCKSWITCH 8 PRO DMX / ETHERNET SWITCH	LA37401	16/12/19	P	S	0.06 P	S	<0.05 P	0.45 P	S	S	S
ROCKSWITCH 8 PRO DMX / ETHERNET SWITCH	LA38357	16/12/19	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
ROCKSWITCH 8 PRO DMX / ETHERNET SWITCH	LA37553	16/12/19	P	S	0.09 P	S	<0.05 P	0.46 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34689	05/03/20	P	S	0.04 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26202	05/03/20	P	S	0.04 P	>300 P	<0.05 P	0.33 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34671	05/03/20	P	S	0.09 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26199	05/03/20	P	S	0.09 P	>300 P	<0.05 P	0.35 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26194	05/03/20	P	S	0.05 P	77.84 P	<0.05 P	0.34 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26198	02/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34669	05/03/20	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34668	05/03/20	P	S	0.03 P	>300 P	<0.05 P	0.33 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26295	02/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26203	02/01/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26294	02/01/20	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34672	02/01/20	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34684	05/03/20	P	S	0.09 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA24316	05/03/20	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34688	05/03/20	P	S	0.03 P	>300 P	<0.05 P	0.32 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SHOWTEC SUNSTRIP ACTIVE DMX	LA34687	05/03/20	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA24319	02/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34677	05/03/20	P	S	0.07 P	>300 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34673	05/03/20	P	S	0.07 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34678	05/03/20	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26193	02/01/20	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA35127	20/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17483	20/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15630	22/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA42105	20/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17643	20/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17484	20/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17485	20/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17642	22/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15595	18/02/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15587	22/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15592	14/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA42099	17/01/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15598	18/02/20	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA42097	17/01/20	S	S	S	S	S	S	S	S	S
SHUKO - IEC EURO ADAPTOR	LA26059	20/01/20	S	S	S	S	S	S	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31627	02/01/20	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA43145	04/02/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30781	04/02/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA43093	10/01/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30163	03/03/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30629	04/02/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30633	04/02/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30631	03/03/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20283	04/02/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20285	04/02/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20282	04/02/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20277	04/02/20	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT BOX	LA20278	04/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20527	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20533	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20528	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20525	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20522	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20526	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX - 6 X 16A 1PH STAGE/TRUSS BOX	LA37775	03/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX - 6 X 16A 1PH STAGE/TRUSS BOX	LA34900	06/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX - 6 X 16A 1PH STAGE/TRUSS BOX	LA34898	06/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 3 WAY 415V/110V MOTOR FAN IN	LA32868	04/02/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA22321	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA22322	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA22323	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21133	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21944	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21945	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32277	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32278	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32280	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA22324	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32275	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32276	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA17466	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA20187	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA17465	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA40287	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA17462	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA20189	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21130	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21131	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA20190	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32840	03/03/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32843	03/03/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32846	03/03/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32841	10/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35896	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35898	18/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35895	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35556	04/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35894	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35899	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35903	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35904	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35902	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40283	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35901	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35555	06/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35545	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35546	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43087	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35552	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35553	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35549	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43090	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35554	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43089	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35550	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43088	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35905	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40165	18/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40166	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40164	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40161	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40162	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40167	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40171	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40172	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40170	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40168	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40169	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40160	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35911	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35912	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35910	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35908	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35909	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35913	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40158	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40159	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40157	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA36231	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA36232	10/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40185	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40183	06/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32574	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32522	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32573	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40182	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40177	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40176	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40178	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40181	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40180	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32521	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43091	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA42216	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43092	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43094	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43095	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA42108	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32519	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32520	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40186	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA42129	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32518	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40173	18/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35099	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35131	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35091	18/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32692	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32693	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35539	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35543	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35544	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35542	07/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35540	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35541	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32691	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32579	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32581	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32578	06/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32575	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32576	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32582	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32688	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32690	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32687	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32685	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32686	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24955	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22977	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24958	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24956	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22911	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22650	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22649	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40315	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22651	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24961	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24969	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24968	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24973	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24970	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24967	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24963	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24962	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24966	21/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24965	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21783	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21782	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21934	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21932	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21781	11/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21778	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21777	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21780	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21779	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21935	06/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22646	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22645	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22648	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22647	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22644	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21946	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21936	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22643	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21947	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24974	10/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32265	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30536	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32269	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32266	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30535	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30532	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30531	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30534	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30533	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32271	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35146	10/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35092	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA46661	29/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA37180	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA34568	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32273	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32272	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA33313	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32274	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40284	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26876	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26879	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26878	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26874	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA25116	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24975	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26870	02/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26869	21/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26913	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30528	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30527	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30530	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30529	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26927	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26916	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26914	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40298	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26917	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21776	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01416	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40304	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01612	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40316	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17274	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17124	21/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40318	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01659	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01844	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01843	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40295	18/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01977	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01748	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA15638	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01979	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17811	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20358	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20359	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17895	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20356	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21772	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21774	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20361	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20439	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17879	06/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17815	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17818	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17820	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17825	04/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17824	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17821	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42261	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42265	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA40175	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42230	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA40163	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA40174	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42248	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42262	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42260	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42220	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42267	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA32270	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42263	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40724	18/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40722	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40725	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40712	12/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40710	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40717	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40716	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40719	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40721	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40720	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40726	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40679	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40680	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40678	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40713	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40677	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40685	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40686	22/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40683	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40681	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40682	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40701	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40703	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40700	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40699	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40714	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40705	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40704	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40706	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40708	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40707	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40698	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40690	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40691	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40688	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40715	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40687	21/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40696	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40697	19/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40695	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40693	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40694	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42250	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42239	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42252	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42238	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42241	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42255	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42236	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42221	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42222	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42257	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42268	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40991	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40992	14/01/20	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40990	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40987	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40988	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40993	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42245	08/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42234	07/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42243	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40995	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40996	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42226	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42227	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42264	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42254	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42224	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42223	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42259	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42229	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42225	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42233	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42244	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42249	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42251	21/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42231	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42266	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42240	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42232	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42247	14/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42235	17/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42246	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42242	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42256	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) IP67 - 6 X 16A 1PH FAN OUT	LA43137	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) IP67 - 6 X 16A 1PH FAN OUT	LA42619	02/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) IP67 - 6 X 16A 1PH FAN OUT	LA43134	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX (M) IP67 - 6 X 16A 1PH FAN OUT	LA43136	29/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 10M	LA46105	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 10M	LA46102	19/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 10M	LA46106	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 10M	LA46103	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 10M	LA46104	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 10M	LA46101	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 20M	LA46108	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 20M	LA46111	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 20M	LA46110	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 20M	LA46107	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 20M	LA46112	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 20M	LA46109	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 30M	LA46118	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 30M	LA46117	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 30M	LA46113	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 30M	LA46115	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 30M	LA46114	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM 2 WAY LOOM (HOIST) 30M	LA46116	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA17148	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA43068	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36078	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36079	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA34695	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36076	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36080	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36177	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36216	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36149	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36151	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA30761	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA30852	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA22848	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA30195	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA31994	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32308	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32360	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32038	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32073	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA21785	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA34709	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA32793	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA32792	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA32042	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30946	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA36084	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30854	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA21904	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA21788	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA43050	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30853	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30783	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30308	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36155	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21145	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21302	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20546	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20540	18/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 1.5MM CABLE 2.5M	LA20544	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20545	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36170	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36111	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36171	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36169	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA22759	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA24291	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30859	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30889	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA32033	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA31997	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA31351	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36063	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36061	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36060	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA34547	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30933	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30862	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA17624	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30890	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30865	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30894	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30931	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA37099	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA40326	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA22879	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA36086	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA36185	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA21150	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA17283	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA21153	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA22720	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 30M	LA17074	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 40M	LA01995	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36141	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36073	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36143	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36142	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36173	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36207	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36172	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36145	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36148	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA22758	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA26605	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA22063	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA21540	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA21900	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30197	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30305	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30194	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30190	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30193	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20562	05/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20112	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20427	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20054	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA17272	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA17282	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20555	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20556	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20554	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20429	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20553	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30765	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36067	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30941	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30888	18/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 1.5MM CABLE 5M	LA30942	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30944	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30948	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA34696	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36071	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36070	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36072	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30850	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36069	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30855	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30851	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43065	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36215	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32229	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43070	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43069	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43073	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36152	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36132	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36179	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32231	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43066	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32232	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36180	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43067	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30467	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30468	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30469	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30466	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30462	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30465	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36181	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32226	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32227	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32228	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32225	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30470	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30857	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32040	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25591	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21922	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21923	21/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21924	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21921	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36198	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36182	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21920	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25586	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25589	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25590	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25585	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA22522	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA22523	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25583	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32533	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32534	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32535	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32497	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32499	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32500	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32536	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32541	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32542	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32643	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32538	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32539	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32540	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21716	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21802	17/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 10M	LA21919	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21644	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21675	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA44342	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32233	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32492	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32494	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32496	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32304	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32359	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32491	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32361	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36034	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43142	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36020	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32875	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32876	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32926	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36083	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43063	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43064	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36082	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43140	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43139	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32756	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32647	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32648	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32753	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32644	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32645	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32646	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32791	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32758	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32757	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32754	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32755	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32874	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32243	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22433	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22429	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43098	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43096	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43097	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33021	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33022	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33019	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33020	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33026	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33027	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33023	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33025	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33013	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33014	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33011	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33012	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33017	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33018	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33015	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33016	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32240	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32241	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32238	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32239	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32248	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32249	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32244	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32247	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36184	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30486	17/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 15M	LA36021	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36022	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32235	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32237	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32006	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32074	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33010	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22436	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32759	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32603	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32604	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22440	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30484	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32760	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43132	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32544	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32545	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32301	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32543	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32550	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32552	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32547	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32549	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32862	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32877	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32860	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32861	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33008	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33009	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32878	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32923	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32763	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32764	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30485	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32762	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32858	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32859	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32856	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32857	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43053	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43054	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43055	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43052	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43047	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43049	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43051	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43060	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43061	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43062	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43059	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43056	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43057	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43058	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43044	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43045	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43046	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA30936	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA32605	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA30935	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA32036	22/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA32032	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA30930	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA32886	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36065	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36066	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36200	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA43112	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36039	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36064	21/01/20	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 2.5M	LA43084	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA32606	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32864	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32865	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36222	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32863	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32883	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32884	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA43116	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32882	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36191	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36193	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA43125	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA43113	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36219	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32880	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32879	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36221	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32881	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32999	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33003	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33004	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32998	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA43124	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA43141	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32996	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33005	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36024	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36026	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36090	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36023	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33006	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33007	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33061	09/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36187	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36100	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36097	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36189	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32922	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32931	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32932	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36091	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32993	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA43118	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA43119	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32991	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32988	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32989	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32990	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32340	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32224	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30975	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32553	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA31984	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32043	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30977	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30978	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30967	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30968	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30963	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30965	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30972	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30973	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30969	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30971	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32223	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32222	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32215	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32216	20/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 20M	LA32218	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32217	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32221	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32219	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32207	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32208	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32205	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32206	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32213	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32214	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32209	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32211	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32554	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32555	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32556	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21728	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22635	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21891	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21890	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32557	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32766	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32767	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32768	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32562	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32558	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32559	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32560	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30459	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30460	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30456	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30457	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30958	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30960	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30955	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30956	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22641	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30452	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22639	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22640	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30454	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30455	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30453	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30449	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30450	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30786	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30446	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30447	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30448	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30791	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30856	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30980	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30788	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30789	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30790	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21731	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21733	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21735	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36001	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36101	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA43022	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22658	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA24981	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30445	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21796	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22526	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22653	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32961	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32962	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32960	19/12/19	S	S	S	S	S	S	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 30M	LA32958	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32959	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32987	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32980	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32965	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32963	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32964	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32947	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32948	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32946	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32944	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32945	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32955	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32957	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32954	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32949	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32951	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32966	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36104	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36106	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36103	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32969	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32973	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32975	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32974	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32976	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36107	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36227	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32979	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32978	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36003	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32950	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36002	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36027	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32968	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36004	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32967	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32977	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32943	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32650	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32651	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32062	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32356	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32652	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32933	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32934	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32653	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32654	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30991	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32984	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30984	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30988	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32982	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30992	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA31583	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30983	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30981	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32938	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA43110	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA43108	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32986	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA43111	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA43107	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32941	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32942	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32939	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA43109	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32981	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 40M	LA38490	20/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 40M	LA36108	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32002	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32001	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA30994	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25473	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25472	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25479	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25476	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36197	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30938	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30939	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25478	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30481	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30476	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30472	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30480	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30479	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21929	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36176	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36175	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36202	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36201	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36074	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36037	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36144	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36110	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21640	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA20203	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21927	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21706	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36204	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36203	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36206	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36205	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32850	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32851	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32853	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32752	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43143	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43138	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32751	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36015	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43074	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43075	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36014	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32854	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32873	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36013	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32642	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32641	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32640	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32747	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32750	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32749	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32748	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32531	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32530	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32529	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32532	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32639	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32638	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32637	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43076	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32052	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32037	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30954	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32072	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32524	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32523	18/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 5M	LA32305	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30949	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30943	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30940	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30950	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30953	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30952	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30951	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43083	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32528	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36016	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43082	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43077	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43079	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43081	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36036	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32526	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32525	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36019	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36017	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32527	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36018	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40752	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40751	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40754	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40753	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40748	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40747	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40750	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40749	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA43128	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA43129	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA43126	24/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA43127	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40756	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40755	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA43130	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA43131	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40773	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40772	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40765	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40774	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40764	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40776	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40775	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40771	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40766	17/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX IP67 2.5MM CABLE 15M	LA40945	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40946	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40767	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40770	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40769	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40768	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40941	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40942	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40943	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40940	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40937	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40938	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40939	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40759	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40758	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40762	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40761	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40757	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40944	17/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40947	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40948	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40949	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40785	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA43123	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40786	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40781	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40782	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40779	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40780	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40783	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA43115	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA43117	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40784	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA43114	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40950	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40953	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40952	12/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX IP67 2.5MM CABLE 20M	LA40951	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40954	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA43122	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40777	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40955	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 20M	LA40956	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43031	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43030	23/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43011	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43012	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43010	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43033	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43032	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43026	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43025	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43027	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43029	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43028	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43006	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43007	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43009	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43024	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43008	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43013	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40962	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40961	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40963	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40965	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40964	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40957	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43099	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40958	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40960	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40959	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43041	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43040	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43042	16/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX IP67 2.5MM CABLE 30M	LA43085	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43043	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43036	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA40966	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43037	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43039	20/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43038	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43018	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43017	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43019	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43021	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43020	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43034	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43014	13/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43035	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43016	23/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43015	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43104	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43001	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43103	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43100	12/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43102	06/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43121	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43023	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43004	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43002	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 30M	LA43003	16/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40728	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40727	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40730	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40729	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40743	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40742	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40741	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40746	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40745	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40744	18/12/19	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX IP67 2.5MM CABLE 5M	LA40737	19/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40736	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40735	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40740	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40739	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40738	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40733	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40734	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40731	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 5M	LA40732	18/12/19	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA37069	06/02/20	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA37804	17/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA37805	17/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA16633	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA26977	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA26976	20/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA37802	17/01/20	S	S	S	S	S	S	S	S	S
SOCAPEX SPLITTER RUBBER BOX RB	LA37275	20/01/20	S	S	S	S	S	S	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41865	21/01/20	P	S	0.02 P	>300 P	0.05 P	0.39 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41906	22/01/20	P	S	0.02 P	>300 P	0.05 P	0.40 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41687	21/01/20	P	S	0.05 P	48.89 P	0.05 P	0.39 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41904	22/01/20	P	S	0.04 P	>300 P	0.05 P	0.39 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41905	21/01/20	P	S	0.04 P	>300 P	0.05 P	0.41 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41682	22/01/20	P	S	0.03 P	>300 P	0.05 P	0.41 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41683	22/01/20	P	S	0.16 P	>300 P	0.05 P	0.39 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41684	22/01/20	P	S	0.06 P	>300 P	0.05 P	0.38 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41689	22/01/20	P	S	0.05 P	>300 P	0.05 P	0.40 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41914	22/01/20	P	S	0.05 P	>300 P	0.05 P	0.38 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41915	22/01/20	P	S	0.03 P	>300 P	0.05 P	0.39 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41688	22/01/20	P	S	0.06 P	54.57 P	0.05 P	0.39 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41911	22/01/20	P	S	0.06 P	>300 P	0.05 P	0.40 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41910	21/01/20	P	S	0.03 P	>300 P	0.05 P	0.40 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41686	22/01/20	P	S	0.04 P	46.66 P	0.05 P	0.39 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41909	22/01/20	P	S	0.04 P	>300 P	0.05 P	0.41 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41908	22/01/20	P	S	0.02 P	>300 P	0.05 P	0.38 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41907	21/01/20	P	S	0.03 P	>300 P	0.05 P	0.42 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41685	22/01/20	P	S	0.07 P	>300 P	0.05 P	0.42 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOLARIS FLARE Q+ LED STROBE	LA41912	21/01/20	P	S	0.02 P	>300 P	0.05 P	0.40 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41913	22/01/20	P	S	0.21 P	>300 P	0.05 P	0.40 P	S	S	S
SOLARIS FLARE Q+ LED STROBE	LA41681	22/01/20	P	S	0.18 P	>300 P	0.05 P	0.38 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37981	16/01/20	P	S	0.08 P	2.36 P	0.05 P	0.81 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37978	20/01/20	P	S	0.04 P	>300 P	0.05 P	0.85 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37980	21/01/20	P	S	0.03 P	75.28 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37979	16/01/20	P	S	0.02 P	6.32 P	0.05 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37977	13/01/20	P	S	0.03 P	>300 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37541	15/01/20	P	S	0.07 P	12.24 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38426	09/01/20	P	S	0.02 P	27.15 P	0.05 P	0.87 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38427	16/01/20	P	S	0.03 P	8.18 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38424	10/01/20	P	S	0.03 P	60.95 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38425	21/01/20	P	S	0.06 P	25.76 P	0.05 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38428	21/01/20	P	S	0.07 P	>300 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41174	08/01/20	P	S	0.04 P	>300 P	0.06 P	0.86 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41175	13/01/20	P	S	0.02 P	162.60 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38429	14/01/20	P	S	0.03 P	8.91 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38430	13/01/20	P	S	0.30 P	2.57 P	0.05 P	0.86 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38423	13/01/20	P	S	0.05 P	158.60 P	0.05 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37985	20/01/20	P	S	0.04 P	28.22 P	0.05 P	0.87 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41559	15/01/20	P	S	0.04 P	73.93 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37983	16/01/20	P	S	0.04 P	3.69 P	<0.05 P	0.76 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37984	20/01/20	P	S	0.03 P	>300 P	0.06 P	0.86 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38420	08/01/20	P	S	0.07 P	>300 P	0.06 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38421	14/01/20	P	S	0.03 P	19.99 P	0.05 P	0.79 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38422	08/01/20	P	S	0.06 P	3.12 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37976	17/01/20	P	S	0.03 P	>300 P	0.06 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37975	09/01/20	P	S	0.04 P	34.88 P	0.05 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38787	21/01/20	P	S	0.05 P	63.56 P	0.05 P	0.87 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38786	15/01/20	P	S	0.06 P	5.83 P	0.05 P	0.86 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41702	13/01/20	P	S	0.02 P	66.62 P	0.05 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38788	09/01/20	P	S	0.08 P	162.10 P	0.05 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38785	20/01/20	P	S	0.14 P	73.34 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38790	15/01/20	P	S	0.36 P	>300 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38789	10/01/20	P	S	0.03 P	6.06 P	0.06 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38792	16/01/20	P	S	0.05 P	13.68 P	0.05 P	0.85 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38791	21/01/20	P	S	0.08 P	>300 P	0.06 P	0.87 P	S	S	S



Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOLARIS FLARE RGBW LED STROBE	LA41185	16/01/20	P	S	0.04 P	7.04 P	0.05 P	0.86 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41178	10/01/20	P	S	0.04 P	12.31 P	0.05 P	0.69 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41179	09/01/20	P	S	0.06 P	3.66 P	0.05 P	0.79 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41176	20/01/20	P	S	0.05 P	>300 P	0.06 P	0.87 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41177	08/01/20	P	S	0.05 P	>300 P	0.06 P	0.85 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41180	14/01/20	P	S	0.21 P	44.76 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41183	13/01/20	P	S	0.26 P	>300 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41184	14/01/20	P	S	0.03 P	2.38 P	0.05 P	0.81 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41558	21/01/20	P	S	0.11 P	>300 P	0.06 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41182	16/01/20	P	S	0.06 P	93.93 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37982	09/01/20	P	S	0.04 P	154.60 P	0.05 P	0.77 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37546	15/01/20	P	S	0.34 P	36.55 P	0.06 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37440	21/01/20	P	S	0.02 P	>300 P	0.05 P	0.89 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37441	13/01/20	P	S	0.04 P	111.90 P	0.06 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34854	10/01/20	P	S	0.07 P	10.31 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34851	20/01/20	P	S	0.17 P	36.26 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34852	09/01/20	P	S	0.09 P	>300 P	0.05 P	0.79 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34853	16/01/20	P	S	0.06 P	24.91 P	0.05 P	0.85 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37543	14/01/20	P	S	0.05 P	3.61 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37544	20/01/20	P	S	0.03 P	136.20 P	0.05 P	0.81 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37545	24/01/20	P	S	0.05 P	19.43 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37542	14/01/20	P	S	0.03 P	13.29 P	0.05 P	0.76 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37442	16/01/20	P	S	0.05 P	>300 P	0.05 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37443	15/01/20	P	S	0.05 P	4.33 P	0.05 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37467	10/01/20	P	S	0.08 P	9.64 P	0.06 P	0.84 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37946	15/01/20	P	S	0.02 P	11.07 P	0.05 P	0.72 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37945	10/01/20	P	S	0.23 P	79.19 P	0.06 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34848	20/01/20	P	S	0.03 P	>300 P	0.06 P	0.85 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34847	09/01/20	P	S	0.06 P	9.56 P	0.06 P	0.82 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34844	08/01/20	P	S	0.03 P	228.80 P	0.05 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34845	09/01/20	P	S	0.06 P	>300 P	0.05 P	0.81 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34846	10/01/20	P	S	0.04 P	48.55 P	0.05 P	0.85 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34849	08/01/20	P	S	0.05 P	163.40 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37548	10/01/20	P	S	0.04 P	18.44 P	0.05 P	0.80 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37549	13/01/20	P	S	0.04 P	>300 P	0.05 P	0.79 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37944	08/01/20	P	S	0.04 P	116.90 P	0.05 P	0.86 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34850	14/01/20	P	S	0.15 P	104.10 P	0.05 P	0.80 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOLARIS FLARE RGBW LED STROBE	LA37547	13/01/20	P	S	0.02 P	5.95 P	0.05 P	0.81 P	S	S	S
SOLARIS MOZART 10-WAY PSU	LA41678	10/01/20	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
SONNET MACPRO MOUNTING MODULE	LA41328	18/12/19	P	S	S	>300 P	S	S	S	S	S
SONNET MACPRO MOUNTING MODULE	LA41329	18/12/19	P	S	S	>300 P	S	S	S	S	S
SONNET RACKMAC PRO 4U ENCLOSURE	LA41330	18/12/19	P	S	S	>300 P	S	S	S	S	S
SOURCE 4 PARNEL	LA16788	14/02/20	P	S	0.08 P	>300 P	0.85 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01626	14/02/20	P	S	0.05 P	>300 P	0.83 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA25619	14/02/20	P	S	0.07 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA31485	02/01/20	P	S	0.04 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA25051	02/01/20	P	S	0.04 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16013	14/02/20	P	S	0.06 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16140	02/01/20	P	S	0.04 P	>300 P	0.79 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41719	02/01/20	P	S	0.08 P	152.20 P	0.66 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41720	02/01/20	P	S	0.09 P	170.10 P	0.67 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41721	02/01/20	P	S	0.09 P	>300 P	0.65 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41716	02/01/20	P	S	0.09 P	165.30 P	0.66 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41717	02/01/20	P	S	0.09 P	>300 P	0.65 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41718	02/01/20	P	S	0.08 P	>300 P	0.65 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41725	02/01/20	P	S	0.09 P	287.80 P	0.65 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41726	02/01/20	P	S	0.09 P	>300 P	0.65 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41727	02/01/20	P	S	0.09 P	>300 P	0.64 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41722	02/01/20	P	S	0.09 P	151.70 P	0.67 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41723	02/01/20	P	S	0.09 P	288.30 P	0.65 P	<0.10 P	S	S	S
SPOTLIGHT AREA 05 650W FRESNEL	LA41724	02/01/20	P	S	0.08 P	>300 P	0.65 P	<0.10 P	S	S	S
TFT MONITOR 17``	LA25034	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
TFT MONITOR 17``	LA25033	17/12/19	P	S	0.09 P	>300 P	S	S	S	S	S
TFT MONITOR 17``	LA24823	24/01/20	P	S	S	>300 P	S	S	S	S	S
TFT MONITOR 17``	LA26028	17/12/19	P	S	0.09 P	>300 P	S	S	S	S	S
TFT MONITOR 17``	LA25044	18/02/20	P	S	S	>300 P	S	S	S	S	S
TFT MONITOR 17``	LA25037	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
TFT MONITOR 17``	LA44596	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
TFT MONITOR 17``	LA44597	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA31157	27/01/20	P	S	S	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA25365	27/01/20	P	S	S	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA31159	06/02/20	P	S	0.09 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA34178	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA41537	17/12/19	P	S	0.06 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA31160	06/02/20	P	S	0.08 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA37115	17/12/19	P	S	0.08 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA44595	17/12/19	P	S	0.09 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA37391	17/12/19	P	S	0.06 P	>300 P	S	S	S	S	S
TFT MONITOR 24``	LA34179	17/12/19	P	S	0.07 P	>300 P	S	S	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA25962	16/12/19	P	S	0.07 P	S	<0.05 P	0.19 P	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA26023	16/12/19	P	S	0.05 P	S	<0.05 P	0.19 P	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA24529	16/12/19	P	S	0.07 P	S	<0.05 P	0.19 P	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA25961	16/12/19	P	S	0.07 P	S	<0.05 P	0.19 P	S	S	S
TV ONE 4 WINDOW MULTI VIEWER	LA40269	17/12/19	P	S	0.09 P	>300 P	S	S	S	S	S
TWIN HEAD EMERGENCY SPOT LIGHTS	LA31672	02/01/20	P	S	0.02 P	>300 P	S	S	S	S	S
TWIN HEAD EMERGENCY SPOT LIGHTS	LA31671	02/01/20	P	S	0.03 P	>300 P	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
TWIN HEAD EMERGENCY SPOT LIGHTS	LA31668	02/01/20	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
TWIN HEAD EMERGENCY SPOT LIGHTS	LA31670	02/01/20	P	S	0.06 P	>300 P	S	S	S	S	S
WHOLE HOG III PLAYBACK WING	LA24287	17/12/19	P	S	S	>300 P	S	S	<0.10 P	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22945	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22944	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA31664	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA31663	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22941	17/01/20	P	S	0.08 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22940	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22943	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22942	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
WIRELESS SOLUTIONS W-DMX S-1 TRANSMITTER	LA37332	16/12/19	P	S	0.05 P	S	<0.05 P	<0.10 P	S	S	S
WIRELESS SOLUTIONS W-DMX S-1 TRANSMITTER	LA22939	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S
WIRELESS SOLUTIONS W-DMX S-1 TRANSMITTER	LA22938	02/01/20	P	S	S	>300 P	S	S	<0.10 P	S	S

**Total Appliances: 7,056**  
**Total Appliances For Report: 7,056**