

**Report Of Passed Appliances
For all Sites and Locations**

lite alternative

Lite Alternative LTD
Unit 4
Duttons Way
Shadsworth Business Park
Blackburn
Lancashire
BB1 2QR
Phone: 01254 279 654

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
LA -											
1000W HALOGON FLOOD WORK LIGHT	LA20023	08/12/17	P	S	0.06 P	>300 P	1.03 P	<0.10 P	S	S	S
1000W HALOGON FLOOD WORK LIGHT	LA20021	08/12/17	P	S	0.07 P	>300 P	1.03 P	<0.10 P	S	S	S
100M KINESYS MULTICORE	LA32363	24/01/18	P	S	S	S	S	S	S	S	S
100M MULTICORE (TYPE I)	LA22719	05/02/18	S	S	S	S	S	S	S	S	S
100M MULTICORE (TYPE I)	LA21298	05/02/18	S	S	S	S	S	S	S	S	S
100M MULTICORE (TYPE III)	LA34106	05/02/18	S	S	S	S	S	S	S	S	S
100M MULTICORE (TYPE III)	LA37444	05/02/18	S	S	S	S	S	S	S	S	S
100W LED FLOOD WORK LIGHT	LA38333	16/01/18	P	S	0.09 P	>300 P	0.11 P	0.10 P	S	S	S
100W LED FLOOD WORK LIGHT	LA38332	08/12/17	P	S	0.08 P	>300 P	0.11 P	0.10 P	S	S	S
100W LED FLOOD WORK LIGHT	LA38334	16/01/18	P	S	0.09 P	>300 P	0.11 P	0.12 P	S	S	S
100W LED FLOOD WORK LIGHT	LA38016	16/01/18	P	S	0.09 P	>300 P	0.11 P	0.10 P	S	S	S
100W LED FLOOD WORK LIGHT	LA38017	16/01/18	P	S	0.08 P	>300 P	0.11 P	0.10 P	S	S	S
100W LED FLOOD WORK LIGHT	LA38330	16/01/18	P	S	0.07 P	>300 P	0.11 P	<0.10 P	S	S	S
100W LED FLOOD WORK LIGHT	LA38331	08/12/17	P	S	0.08 P	>300 P	0.11 P	0.10 P	S	S	S
100W LED FLOOD WORK LIGHT	LA38018	08/12/17	P	S	0.08 P	>300 P	0.11 P	0.10 P	S	S	S
120MM CAMLOCK - POWERLOCK 3M ADAPTOR	LA30903	29/01/18	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 3M	LA30898	29/01/18	S	S	S	S	S	S	S	S	S
120MM POWERLOCK CABLE 3M	LA30899	29/01/18	S	S	S	S	S	S	S	S	S
120MM POWERLOCK LUG - EARTH	LA33560	29/01/18	S	S	S	S	S	S	S	S	S
125A 1PH - 63A 1PH ADAPTOR	LA30758	24/01/18	P	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA32364	21/12/17	P	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA22278	21/12/17	P	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA00955	20/12/17	P	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA42567	21/12/17	P	S	S	S	S	S	S	S	S
125A 3PH - 63A 3PH ADAPTOR	LA42566	21/12/17	P	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA35101	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA21759	11/01/18	P	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA33550	26/01/18	S	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA22101	25/01/18	P	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA21059	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA17150	21/12/17	P	S	S	S	S	S	S	S	S
125A 3PH - POWERLOCK ADAPTER (3M)	LA32470	29/01/18	S	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA22670	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH BARE END TAILS	LA30797	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH LUGGED TAILS	LA35174	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA32463	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA30798	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA22668	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA33637	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 10M	LA42769	11/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA39024	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA32462	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 20M	LA22669	05/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
125A 3PH MAINS CABLE 20M	LA30799	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 3M	LA22667	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA32464	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA42715	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA22666	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA39064	05/01/18	P	S	S	S	S	S	S	S	S
125A 3PH MAINS CABLE 5M	LA42751	11/01/18	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33623	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33622	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA17889	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA04718	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33624	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26761	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA25458	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32201	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA35122	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA35090	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32194	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32195	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32199	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26219	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA24548	06/02/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA24551	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26316	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26229	18/01/18	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26221	06/02/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA32193	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36137	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36136	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26707	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36140	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36139	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36138	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36133	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA34556	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA42211	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26704	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36135	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA36134	25/01/18	P	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33621	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33608	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33607	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30291	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33609	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30292	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30288	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30297	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30298	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26966	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA26854	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30287	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30296	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA30295	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA42826	06/02/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33619	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA25158	29/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33614	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33613	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33612	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33617	26/01/18	S	S	S	S	S	S	S	S	S
13A - 16A 1PH ADAPTER 0.5M	LA33615	29/01/18	S	S	S	S	S	S	S	S	S
13A - IEC ADAPTOR	LA24503	18/12/17	P	P	0.05 P	>300 P	S	S	S	S	S
13A - IEC ADAPTOR	LA22887	07/02/18	S	S	S	S	S	S	S	S	S
13A - IEC ADAPTOR	LA17713	02/02/18	S	S	S	S	S	S	S	S	S
13A - IEC ADAPTOR	LA24380	08/02/18	P	P	0.03 P	>300 P	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA16173	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA17672	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA15157	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA17673	14/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
15A 1PH - 16A 1PH ADAPTOR	LA16519	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26499	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26500	14/12/17	P	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26501	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26498	14/12/17	P	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA15836	14/12/17	P	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA17226	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26497	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA41426	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA16523	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA16521	14/12/17	P	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26505	14/12/17	P	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26502	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26503	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA26504	14/12/17	P	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA25459	14/12/17	P	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA04489	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA04493	31/01/18	S	S	S	S	S	S	S	S	S
15A 1PH - 16A 1PH ADAPTOR	LA02802	31/01/18	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA15347	30/01/18	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA15911	30/01/18	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA15909	30/01/18	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA15910	30/01/18	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA02703	30/01/18	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA02699	31/01/18	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA15343	30/01/18	S	S	S	S	S	S	S	S	S
16A 10FT 110V TRS	LA02704	30/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA17890	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA15356	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA16245	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA16241	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA16242	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA15348	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA24552	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 16A 240V (F) ADAPTER	LA15355	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 2 X 16A 110V (F) SERIES SPLIT	LA15362	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - 2 X 16A 110V (F) SERIES SPLIT	LA15363	08/02/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA15345	02/02/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA21678	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA21677	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA16346	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA16347	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA26356	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA15358	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA15366	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA15357	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA15365	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA15364	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F) (SERIES)	LA15359	31/01/18	S	S	S	S	S	S	S	S	S
16A 110V (M) - SOCAPEX (F)	LA15367	31/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
(SERIES)											
16A 110V (M) - SOCAPEX (F)	LA15361	31/01/18	S	S	S	S	S	S	S	S	S
(SERIES)											
16A 1PH - 4 X 13A RUBBER BOX	LA37652	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37702	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37655	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37701	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37651	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37693	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37696	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37653	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37654	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA02531	30/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37695	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37787	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37779	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37788	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37694	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37778	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37785	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37783	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37786	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37781	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37699	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37698	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37782	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37784	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37780	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA01379	30/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37697	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37700	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37650	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 4 X 13A RUBBER BOX	LA37777	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 2 WAY PLUGBOARD	LA16947	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA32090	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA42214	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA30808	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA37964	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY	LA32087	26/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PLUGBOARD											
16A 1PH - 13A 4 WAY PLUGBOARD	LA32078	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA40325	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA37620	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A 4 WAY PLUGBOARD	LA20497	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA38131	30/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA16429	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA16424	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA25901	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA04474	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA17591	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 13A ADAPTOR	LA16431	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - 15A 1PH ADAPTOR	LA17219	31/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 15A 1PH ADAPTOR	LA16516	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH - 15A 1PH ADAPTOR	LA16644	31/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 15A 1PH ADAPTOR	LA17223	31/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA17029	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA17606	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA15517	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA17662	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA40313	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA30133	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA33331	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA33335	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA30132	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA15802	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - 32A 1PH ADAPTOR	LA16136	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - 6 X 13A / 1 X 16A 1PH	LA37109	29/01/18	S	S	S	S	S	S	S	S	S
RUBBER BOX											
16A 1PH - C5 IEC ADAPTOR	LA26749	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26745	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26750	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26742	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26748	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26746	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26743	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA42107	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - C5 IEC ADAPTOR	LA26740	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25804	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25803	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25802	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25913	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25914	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32744	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32743	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32742	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25177	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32746	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32745	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32741	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32736	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32737	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32738	02/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - EDISON (US) FEMALE 0.5M	LA32740	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32739	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA32735	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25172	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25173	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25174	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25171	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA35134	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA26708	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M	LA25175	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - EDISON (US) FEMALE 0.5M ADAPTOR	LA25805	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17664	07/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17829	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA30881	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17665	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17666	07/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24526	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17667	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24218	07/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24216	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17183	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17034	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA26304	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA35100	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24150	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24149	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17567	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17566	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17570	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17568	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17292	07/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17264	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17413	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA17357	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA24798	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA33936	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC (HIGH TEMP) ADAPTOR	LA34086	02/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - IEC 2 WAY SPLITTER	LA37622	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC 2 WAY SPLITTER	LA37621	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC 2 WAY SPLITTER	LA40277	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC 2 WAY SPLITTER	LA33934	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC 4 WAY SPLITTER	LA26736	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC 4 WAY SPLITTER	LA37280	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC 4 WAY SPLITTER	LA15723	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32017	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32013	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32016	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32015	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25390	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32012	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30870	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25430	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30872	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25432	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32010	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32011	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25408	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32008	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA35095	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26857	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24937	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA35098	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26303	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26928	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26919	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26920	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA35128	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32019	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32020	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA17200	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32018	30/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32026	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32027	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32024	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA32025	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA17469	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25624	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30880	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30884	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30882	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26516	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30877	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26526	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26517	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33932	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33933	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33928	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33927	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA17639	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA15012	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33935	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25598	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA34558	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24711	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30875	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA31879	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30874	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA17480	20/12/17	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24022	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24026	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26510	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26509	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26514	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26512	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA31614	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA30876	12/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH - IEC ADAPTOR	LA26508	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26506	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA16872	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA21668	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26211	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25979	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26218	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26995	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA42903	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA21670	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26996	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25899	01/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA16545	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA33548	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24352	30/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24356	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25010	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25883	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA25891	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA21593	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24299	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA24557	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26935	07/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA42096	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26994	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26950	12/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - IEC ADAPTOR	LA26991	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39497	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39505	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39317	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39314	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26712	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39319	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39320	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39780	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39496	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39503	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39502	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39313	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39792	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39303	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39284	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39498	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39506	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39285	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39302	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39306	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39307	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39309	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON	LA39311	10/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39281	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39283	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39779	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39282	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39495	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39491	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26722	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39791	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25151	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39256	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39470	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39784	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39790	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39249	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39492	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39248	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39785	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39788	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39787	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39252	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39500	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39493	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39781	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39276	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39280	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39501	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39494	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39274	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39782	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39257	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39783	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39258	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39273	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39269	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39499	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39288	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39296	25/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA26752	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39875	07/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39878	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39541	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26793	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39299	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26753	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39834	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39525	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39827	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39519	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39524	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39831	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39832	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39829	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39830	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39531	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39529	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39527	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39532	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26951	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26932	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26952	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39528	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39301	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39540	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39538	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26794	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26795	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39534	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39533	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39536	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39535	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39518	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25423	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39811	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39510	15/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39511	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39292	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39813	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39812	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39512	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39810	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39291	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39507	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39289	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39290	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39808	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39809	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39508	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39793	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39294	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39295	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39514	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39515	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39825	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39826	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39516	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39517	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39824	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39816	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39513	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39814	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39815	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39822	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39823	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39817	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39821	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39778	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39625	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26249	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26247	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39624	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39194	10/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39604	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38908	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38909	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26251	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26253	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39180	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39182	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38910	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39623	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38911	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26244	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26246	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39191	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39184	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39186	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38907	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39592	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39591	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39593	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39595	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39594	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38900	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38899	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38901	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38903	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38902	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38906	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26351	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26324	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39603	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39599	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39596	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38904	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39597	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26352	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39598	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39607	24/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA38919	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38920	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26102	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26105	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38917	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38914	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25870	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38918	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25890	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38927	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38928	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38923	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38924	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38925	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38921	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39606	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38930	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38929	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39605	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39608	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39617	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39618	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39616	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39614	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39615	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39621	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39622	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39620	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25806	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39619	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25868	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25867	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38912	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39609	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38913	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39612	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39613	10/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA25807	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25809	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25808	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39590	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26616	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26618	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39550	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39551	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39205	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39549	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26622	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26621	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26619	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26620	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39201	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39558	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39559	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38884	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38883	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39554	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39553	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39556	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39203	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39557	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26623	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26673	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26677	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39208	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25611	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39207	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39774	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39777	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39773	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39231	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26683	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39547	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39545	29/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39206	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26649	07/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA26669	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25614	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25612	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39542	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA25615	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39544	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38896	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39565	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39566	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39569	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39567	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38893	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39563	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA24076	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38895	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38894	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39585	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39579	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39586	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39588	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39587	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38897	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39572	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39573	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39575	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39574	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38892	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39638	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39639	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39637	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39635	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39636	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38889	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38888	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38890	10/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA39640	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39642	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39561	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39629	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39627	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA38891	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39626	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39560	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39633	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39632	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39630	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA39631	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33240	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32259	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33239	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32257	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33237	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32264	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32309	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32263	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32260	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32262	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32256	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35089	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35078	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33236	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33234	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33235	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32254	01/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32255	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32253	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32250	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32251	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32329	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32330	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32328	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32326	09/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA32327	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32334	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32335	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32333	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32331	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32332	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32324	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32314	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32315	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32312	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32310	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32311	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32322	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32323	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32320	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32317	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32319	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40349	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40350	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33231	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33226	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33230	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40353	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40354	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA31881	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40351	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40352	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17574	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40348	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33220	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33219	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40346	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40347	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17582	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17580	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33224	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33221	24/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA33222	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35611	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35610	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35612	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40375	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35613	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33232	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33233	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35607	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35609	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35608	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40374	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40359	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40361	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40358	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40355	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40357	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35614	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40367	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40366	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40362	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40365	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33816	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33815	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33817	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33819	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33818	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33790	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33675	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33791	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33810	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33796	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33820	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33829	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33828	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33830	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33833	24/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA33831	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33823	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33822	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33824	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33827	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33826	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33581	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33580	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33582	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33585	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33584	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33575	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33564	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33576	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33579	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33578	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33588	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33604	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33601	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33667	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33670	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33668	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33592	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33591	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33593	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33599	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33596	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35005	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33245	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35011	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33242	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35016	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA42167	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA34064	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA42161	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33248	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33263	10/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA35025	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35049	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35040	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35050	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32338	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32339	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA41429	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35028	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA41425	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35030	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA35029	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33842	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33840	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33843	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32787	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32790	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33835	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33834	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33836	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33839	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33838	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32786	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32776	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32777	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32774	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32771	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32773	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32783	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32784	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32780	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32778	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA32779	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33198	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33204	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17744	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33202	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17969	10/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA40236	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40341	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40340	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40344	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17745	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36303	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA17972	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30712	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30713	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30711	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30707	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30709	07/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30719	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30720	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30718	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30714	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30715	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40331	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40328	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40332	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40227	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40333	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36297	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40226	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36298	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36299	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40327	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40334	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36295	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36296	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40230	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40339	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40234	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40336	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40335	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40337	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40228	10/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON ADAPTOR	LA40338	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30702	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30684	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30685	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30680	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30681	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30686	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA40345	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36304	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30668	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30667	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36293	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30671	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30672	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30669	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30670	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33200	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30679	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA36294	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30677	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30678	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33213	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33218	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30692	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33212	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30693	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30694	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30701	09/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30696	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33208	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA37624	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA37623	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33206	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30691	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33211	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA33199	24/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON ADAPTOR	LA30688	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR											
16A 1PH - POWERCON TRUE 0.5M	LA40239	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40240	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40246	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35019	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35022	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35021	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40244	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40242	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40241	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40243	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35026	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32371	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32370	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32372	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32374	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32373	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40237	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA40238	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35033	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32369	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35032	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32375	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32382	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32381	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32383	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA41428	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA35031	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32377	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32376	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32378	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32380	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32379	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32611	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32610	15/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32612	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE 0.5M	LA32614	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH - POWERCON TRUE	LA32613	26/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA32609	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34710	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34776	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42219	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32608	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32607	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33801	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33805	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39297	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33799	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33800	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33806	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32616	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA32615	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33809	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33807	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA33808	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42110	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34788	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42112	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42114	26/01/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42113	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34792	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35017	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35018	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35015	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34793	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35014	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34779	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34780	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42159	26/01/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34777	19/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34778	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34781	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA42115	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34787	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34786	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA34782	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA34783	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39754	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39755	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39752	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39753	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39757	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35622	06/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35624	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39756	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39708	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39707	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39710	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39709	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39704	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39703	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39706	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39705	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39766	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39767	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35620	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35619	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39769	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39770	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40372	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39768	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39760	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39761	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39758	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39759	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35621	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39764	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39762	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39763	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39711	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39726	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39725	05/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA39728	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39727	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39721	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39720	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39723	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39722	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39736	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39735	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39738	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39737	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39730	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39729	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39732	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39731	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39750	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39717	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39748	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39749	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39713	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39712	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39715	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39714	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39739	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39740	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39719	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39718	06/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39746	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39747	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39743	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39745	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39771	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35064	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35063	29/01/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35066	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35065	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35060	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35059	15/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - POWERCON TRUE	LA35062	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35061	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35067	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40262	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35072	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40264	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40263	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35069	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35068	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35071	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35070	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35057	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40252	26/01/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40251	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40254	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40253	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40248	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40247	19/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40250	18/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40249	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40257	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35054	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35053	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35056	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA35055	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40259	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40258	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40261	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40260	06/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40279	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40265	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40266	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40278	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40282	15/01/18	P	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA39772	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40280	05/02/18	S	S	S	S	S	S	S	S	S
0.5M											
16A 1PH - POWERCON TRUE	LA40281	05/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
0.5M											
16A 1PH - SHUKO ADAPTOR	LA17489	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA17491	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA35110	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30207	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30208	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30210	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30206	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30202	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30203	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH - SHUKO ADAPTOR	LA30204	02/02/18	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA16920	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA25194	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA25192	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA25106	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA16543	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA17138	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA16921	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA25187	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA38477	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA16959	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA38544	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA26986	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA16919	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA25184	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA38524	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA25105	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA25186	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER GEWISS	LA38525	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA17280	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA17279	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA17278	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA26739	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA17258	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER RUBBER BOX	LA17276	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37062	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37063	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37060	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37061	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37064	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37068	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA40294	19/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH 2 WAY SPLITTER T-LINE	LA37065	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37067	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37056	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37055	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA35139	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37059	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37058	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER T-LINE	LA37057	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33306	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33556	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33549	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33554	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33555	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33557	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35958	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35957	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35960	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35962	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35961	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35953	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35952	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35954	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35956	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35955	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35963	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26902	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26900	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26904	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26911	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26910	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35965	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35964	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26896	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26898	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26897	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35951	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34962	05/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH 2 WAY SPLITTER Y-CORD	LA34960	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34963	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26285	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35020	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34954	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA33561	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34955	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34959	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA34958	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26288	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35946	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35163	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35947	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35949	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35948	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35142	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA26289	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35157	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35160	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA35159	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA42190	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA42205	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA42175	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA40291	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 2 WAY SPLITTER Y-CORD	LA42154	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA20582	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16875	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA00588	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA17240	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16973	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16967	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16974	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA37174	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16876	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16882	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16885	29/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA25109	25/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH 3 WAY SPLITTER GEWISS	LA25110	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA25108	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA16877	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA00726	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH 3 WAY SPLITTER GEWISS	LA37182	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30187	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30189	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30186	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25845	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25976	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25839	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA25843	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA26062	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30184	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30185	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA39167	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA30183	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 100FT	LA38591	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30578	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40111	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30584	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30583	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30582	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40112	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA34219	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40115	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40114	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40113	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26299	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30586	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30593	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30591	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30590	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30597	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30595	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30594	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30589	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30588	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30587	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24211	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26956	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26955	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40124	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40125	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40126	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40121	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40122	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40123	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17094	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17090	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39653	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17837	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40127	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17096	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24109	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24118	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24117	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24116	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40116	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40117	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40118	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40120	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24112	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24111	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24114	08/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA17843	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40119	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24584	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25903	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30013	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24589	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24588	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24585	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32700	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32699	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25922	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30012	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30010	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30009	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32702	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35430	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17098	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30014	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32704	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32703	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24594	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32701	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24591	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40107	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24598	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24596	22/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32698	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17848	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30604	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30603	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30001	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30607	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26048	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30599	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26110	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24506	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24522	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30601	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30600	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30611	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30008	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30007	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32697	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32696	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32695	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30003	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30002	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30608	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30610	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30609	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30006	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40142	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40143	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40144	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40141	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32152	06/02/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32153	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA16895	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40148	21/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40149	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40145	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40146	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40147	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26585	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26586	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32144	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26580	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26582	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26583	12/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA32148	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32150	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32151	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32145	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32146	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32147	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40108	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32162	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32163	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32164	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32159	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32160	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32161	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32168	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32169	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32170	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32165	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32166	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32167	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32155	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26635	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32156	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40150	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40151	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32154	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32157	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15950	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15960	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26637	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26638	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26639	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26579	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40129	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32172	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26705	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40128	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA16931	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA16929	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40132	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40133	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40134	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40130	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32171	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40131	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39656	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39657	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39658	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39654	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39655	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17089	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA16933	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39661	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39662	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39659	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39660	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17835	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40135	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26570	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26571	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26572	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40140	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26567	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26569	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26576	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26577	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26578	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26573	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26574	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA26575	08/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA32454	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32453	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32452	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40136	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32456	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32455	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40137	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40138	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40139	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32451	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32450	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32449	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32705	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35839	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35840	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33279	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35838	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33280	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25065	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33274	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30616	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33276	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33278	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33277	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25196	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25195	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30617	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA04701	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30618	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25050	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35836	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35837	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17131	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35835	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17293	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39088	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39086	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40110	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30627	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35841	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39085	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA40109	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39080	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39082	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39084	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39083	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30624	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30625	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33273	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30615	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24709	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30614	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15417	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA15419	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30612	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30626	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30613	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30255	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30254	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30257	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35854	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30258	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30621	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30249	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35853	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30250	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30252	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30251	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35861	12/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA35860	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35862	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35863	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24942	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35859	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35856	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35855	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35857	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30623	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35858	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA42620	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25208	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30619	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24851	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30620	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33282	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25197	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA04329	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA04080	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA33281	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25199	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35834	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25210	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35849	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35851	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35850	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25209	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24853	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24852	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24855	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24861	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24858	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38976	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38974	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38977	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35846	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35847	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38970	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38969	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38971	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38973	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38972	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38979	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32712	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32711	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38980	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32710	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35845	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30015	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32714	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38978	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32713	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38968	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35434	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35432	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35435	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35437	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35436	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30019	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30016	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA30020	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35431	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35848	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35444	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35443	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38965	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38967	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38966	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35439	08/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 10FT	LA35438	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35440	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35442	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35441	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25079	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25080	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39070	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39069	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25083	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35842	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25081	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA25082	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39071	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39077	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39076	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39079	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39078	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39073	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39072	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39075	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA39074	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35844	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA17687	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38984	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35445	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35447	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35446	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38981	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA24599	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38982	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA38983	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32709	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35448	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32707	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA32706	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 10FT	LA35449	08/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35866	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35865	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35867	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39987	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35868	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39986	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39985	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35864	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35869	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17853	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39979	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39984	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17854	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39980	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39983	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39982	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17689	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39981	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17858	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17864	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17863	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17870	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17867	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39976	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17860	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39978	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39977	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17862	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39988	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30054	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32132	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30056	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30058	13/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA30057	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30051	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32130	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30052	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32131	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30053	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32133	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35457	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35456	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32138	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32140	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35458	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32135	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32134	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32136	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30060	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32137	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32129	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32119	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32118	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26985	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32121	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32120	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32114	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32113	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32115	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32117	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32116	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32122	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32126	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32125	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32127	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32128	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35455	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35451	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32123	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35452	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35454	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35453	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32141	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30264	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32142	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39993	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30265	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30259	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30222	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30260	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30263	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30261	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39992	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39991	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35871	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39990	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35870	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39989	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30267	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30266	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30268	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35872	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35873	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30221	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35464	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35463	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35465	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35468	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35466	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35459	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39995	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35460	13/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA35461	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39994	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA35469	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30215	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30214	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30217	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30219	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30218	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17494	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17474	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30211	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30213	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30212	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24872	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24871	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24565	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24873	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24868	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26043	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24870	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24869	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24567	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25912	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24576	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32715	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25824	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24569	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24568	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24575	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24572	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26047	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24204	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26301	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24206	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24205	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26411	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24099	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA34218	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24102	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24208	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24562	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24561	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26049	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24564	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33290	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24210	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24867	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33292	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32716	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15445	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15446	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15430	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15431	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38998	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38997	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA39004	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38999	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24875	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24882	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24883	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24876	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24881	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA02845	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA02583	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24884	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA24885	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38989	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32726	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32724	13/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA32728	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32727	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32719	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32718	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32721	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32720	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32729	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38985	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32734	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38987	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA38986	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32731	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32730	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32733	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA32732	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26718	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30821	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30818	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30820	10/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17010	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA17080	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30822	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30823	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30817	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33286	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04242	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA16058	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33287	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30815	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30816	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30814	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA16503	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25057	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25059	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33284	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25212	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25086	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25087	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25180	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA25085	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33285	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30828	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30829	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30825	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30826	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04390	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04391	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04254	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA04255	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26599	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26598	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26597	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26600	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26604	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26602	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26601	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26596	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26590	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26589	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA42201	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26592	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26595	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26594	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26593	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30812	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA26641	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30810	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30811	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA30813	13/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 20FT	LA15999	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15974	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA15986	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33288	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 20FT	LA33289	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33907	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33908	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35884	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35486	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35887	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35886	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42592	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35488	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35489	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35487	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42590	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42591	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30224	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30225	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30228	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35890	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35888	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35889	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42589	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30232	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30233	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35885	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30231	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30223	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30229	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30230	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25002	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25001	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30353	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25004	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25000	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24995	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24903	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24998	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24997	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30354	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA01224	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25064	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25091	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25090	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25063	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30356	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30355	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA25062	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30357	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24900	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35880	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35881	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35878	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35879	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35883	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33302	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24898	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33300	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33301	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35876	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33295	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33296	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33293	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33294	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33297	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35874	18/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35875	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33298	13/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 30FT	LA33299	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30830	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30831	22/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30832	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30064	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30065	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA16108	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26041	05/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35891	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33913	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33912	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26039	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30833	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26040	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35892	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30081	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30078	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24089	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA34564	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30076	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA24092	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30074	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30075	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26609	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30066	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30079	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26608	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA34715	22/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA42160	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26607	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35480	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35481	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA15460	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26035	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26037	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA15451	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA26036	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35483	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35484	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35485	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35482	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA15463	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA15466	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35893	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30061	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35475	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35477	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30062	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35473	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33910	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA33909	09/02/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35470	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30837	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30838	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30839	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30834	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA35479	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 30FT	LA30836	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24265	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24266	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA25905	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA37168	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30844	16/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30842	22/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30843	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA17118	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30847	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30845	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30849	17/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 50FT	LA30848	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30841	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA26612	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA26613	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24263	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA26611	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA16120	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30360	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30363	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA16122	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30358	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA15493	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA17496	16/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33914	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30119	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35499	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30120	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33915	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33919	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33921	08/02/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33918	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33916	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33917	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35498	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35494	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35495	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35493	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35491	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35492	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30128	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35496	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA35497	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30123	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30126	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30125	16/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24893	16/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA02858	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30067	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30070	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30068	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA02615	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA39027	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA15480	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA39030	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA24896	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33926	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30246	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33925	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30237	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30239	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33922	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33923	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA33924	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30242	16/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30243	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30244	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30240	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 50FT	LA30241	14/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17869	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34588	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32516	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34543	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32594	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32593	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32514	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32510	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32509	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32511	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32513	07/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA32512	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA42291	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA34221	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA42305	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32656	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32655	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32602	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32597	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32595	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32598	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32601	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32599	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32508	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32434	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32433	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32435	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32437	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32436	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32432	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15934	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15936	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32429	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32431	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32430	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32445	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32444	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32446	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32507	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15928	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32443	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32439	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32438	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32440	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32442	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32441	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15381	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15383	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA04740	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33784	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA04736	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15387	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32683	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32682	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32684	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15391	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA15399	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33268	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33269	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33267	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33264	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33266	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33270	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33781	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33782	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA02419	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33271	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA33272	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32681	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32665	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32664	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32666	17/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32668	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32667	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32663	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32658	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32657	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32659	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32662	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32661	07/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA32676	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32675	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32677	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32680	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32678	13/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32674	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32670	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32669	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32671	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32673	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32672	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16055	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35803	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35804	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35802	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35799	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35801	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35805	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35809	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35810	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35808	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35806	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35807	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17129	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17249	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17121	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32174	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32173	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17294	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35796	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35797	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35795	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA31882	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35794	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35811	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35826	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35827	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35825	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35823	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35824	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35828	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35832	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35833	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35831	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35829	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35830	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35815	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35816	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35814	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35812	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35813	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35817	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35821	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35822	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35820	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35818	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35819	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35416	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35417	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35415	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35413	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35414	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35418	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35422	22/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35423	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35421	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35419	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35420	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16905	12/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA16908	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16632	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16263	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16586	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16912	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35410	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35411	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16984	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16981	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA16983	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35424	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32186	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32184	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32187	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32189	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32188	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32182	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32177	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32176	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32178	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32180	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32179	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35428	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35429	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35427	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35425	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA35426	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17104	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32191	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32190	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA32192	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17105	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA17107	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39651	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39652	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39650	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39648	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39649	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30347	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30345	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30348	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30351	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30350	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24123	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24122	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24125	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24453	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24127	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39646	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39647	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39643	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24120	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26480	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30344	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40082	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40080	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40083	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30332	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40084	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26560	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26561	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26559	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40078	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26558	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30339	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30338	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30341	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30343	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30342	07/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA30334	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30333	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30335	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30337	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30336	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26109	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38956	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38955	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38958	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38962	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38961	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38949	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38948	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38951	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38953	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38952	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24617	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24616	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24641	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40096	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40095	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24610	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38964	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24611	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24615	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24614	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38946	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40089	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40088	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA38945	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24600	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40090	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24511	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24510	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40085	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40087	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40086	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40093	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40092	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40094	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24608	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24607	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24602	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24601	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40091	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24605	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24603	16/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30098	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40066	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30099	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30101	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30100	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30049	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30048	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30050	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30021	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30022	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40061	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30103	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26953	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40059	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40060	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40065	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30102	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40064	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40062	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40063	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30047	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30031	12/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA30030	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30032	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30034	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30033	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30026	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30025	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30027	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30029	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30028	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30041	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30040	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30044	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30046	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30045	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30037	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30035	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30024	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30039	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30038	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40058	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40072	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40071	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40073	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40075	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40074	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39967	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39970	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39966	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40070	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40069	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26565	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26566	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26564	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26562	25/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26563	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40077	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40076	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26636	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26614	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA26628	22/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39971	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30109	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30108	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30110	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30112	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30111	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30105	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30104	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40057	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30107	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30106	05/02/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40068	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40067	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39974	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39972	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39973	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30114	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30113	19/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30116	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39975	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30117	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40097	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25073	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39472	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25149	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25074	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25072	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40101	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24835	07/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA24837	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40100	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25148	19/01/18	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30541	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30540	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24838	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40099	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30539	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25075	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA39478	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30538	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30537	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24834	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24780	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40106	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24826	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24816	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40105	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25067	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40103	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40104	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25068	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40102	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25206	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24831	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24833	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24832	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24830	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24828	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24827	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25070	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25069	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA40098	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30564	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30563	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30565	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24844	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30566	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30560	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24840	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30561	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30562	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25125	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30573	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30572	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30575	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30577	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30576	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24842	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30567	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30568	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30570	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30569	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA25126	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30547	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30546	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30548	26/01/18	S	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30550	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30549	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30543	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30542	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30544	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30545	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA24839	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30551	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30556	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30558	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30557	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30559	07/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 1PH TRS 5FT	LA30553	12/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30554	07/12/17	P	S	S	S	S	S	S	S	S
16A 1PH TRS 5FT	LA30555	07/12/17	P	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA16212	30/01/18	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA16208	30/01/18	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA16209	30/01/18	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA16211	30/01/18	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA02694	30/01/18	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA02695	30/01/18	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA15912	30/01/18	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA16207	08/02/18	S	S	S	S	S	S	S	S	S
16A 20FT 110V TRS	LA15339	30/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 1 X 240V (M) / 2 X 110V (M) SPLIT	LA16268	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 1 X 240V (M) / 2 X 110V (M) SPLIT	LA16267	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 1 X 240V (M) / 2 X 110V (M) SPLIT	LA16270	30/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 1 X 240V (M) / 2 X 110V (M) SPLIT	LA16269	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA24466	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA17348	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA16556	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA24467	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA24471	08/02/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA24468	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA17347	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA16243	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 16A 110V (F) ADAPTOR	LA16345	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 2 X 16A 110V (F) SERIES SPLIT	LA15354	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 2 X 16A 110V (F) SERIES SPLIT	LA15352	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 2 X 16A 110V (F) SERIES SPLIT	LA15349	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 2 X 16A 110V (F) SERIES SPLIT	LA15350	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 2 X 16A 110V (F) SERIES SPLIT	LA15353	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 2 X 16A 110V (F) SERIES SPLIT	LA15368	31/01/18	S	S	S	S	S	S	S	S	S
16A 240V (M) - 2 X 16A 110V (F) SERIES SPLIT	LA15351	31/01/18	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA15915	30/01/18	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA26783	30/01/18	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA17670	30/01/18	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA16216	30/01/18	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA16215	30/01/18	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA15917	30/01/18	S	S	S	S	S	S	S	S	S
16A 30FT 110V TRS	LA15916	30/01/18	S	S	S	S	S	S	S	S	S
16A 3PH (4 PIN) - 2 X 16A 3PH (4 PIN)	LA15621	29/01/18	S	S	S	S	S	S	S	S	S
16A 3PH (4 PIN) - 2 X 16A 3PH (4 PIN)	LA15622	29/01/18	S	S	S	S	S	S	S	S	S
16A 3PH (4 PIN) - 2 X 16A 3PH (4 PIN)	LA42975	02/02/18	S	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA17025	02/02/18	S	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA17026	02/02/18	S	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA22058	02/02/18	S	S	S	S	S	S	S	S	S
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA16707	08/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 3PH (5 PIN) - 32A 3PH ADAPTOR	LA16708	08/02/18	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA32368	30/01/18	S	S	S	S	S	S	S	S	S
16A 3PH 4P TRS 25M	LA32365	05/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA33508	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36269	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA17217	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA00996	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32077	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA33512	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA33513	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA26933	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA33507	05/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36277	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36276	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA25214	06/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA25204	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA33504	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36272	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36271	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36270	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36275	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36274	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36273	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39221	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA42382	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA15529	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32833	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA15530	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39222	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39225	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA15522	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA42346	31/01/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA42340	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32834	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36265	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36264	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36266	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36267	09/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 415V/110V MOTOR CABLE 10M	LA36268	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32836	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32835	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32837	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA25765	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA36263	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA15521	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32826	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32827	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39229	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32822	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA34706	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA34333	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32828	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA34704	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA34698	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39228	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32830	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39226	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32825	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32832	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32831	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32823	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32824	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA39227	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 10M	LA32829	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA24642	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32347	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32348	05/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA15524	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA36044	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA15523	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA15531	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32352	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32351	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32349	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA32350	09/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 415V/110V MOTOR CABLE 15M	LA33516	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA33517	30/01/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA38931	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA38935	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA33518	02/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA38938	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA34713	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA38932	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 15M	LA25215	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36051	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36052	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36049	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36050	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36048	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36286	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36287	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36046	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36047	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36288	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36291	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36292	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36289	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36290	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32801	05/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32800	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32799	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32802	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32805	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32804	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32803	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32798	06/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36055	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36054	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36053	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA34569	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32797	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA32796	08/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 415V/110V MOTOR CABLE 2.5M	LA32794	06/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36282	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36278	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36281	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA33062	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA25771	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36283	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36279	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA25916	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA33065	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36285	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA37772	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36284	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA33063	16/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 2.5M	LA36280	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA16163	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA16159	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA17193	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA16162	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA16161	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30918	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30917	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30921	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30920	06/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA34707	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA00333	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30916	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30915	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA36355	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA36356	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA42938	06/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA42939	06/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA36358	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30922	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA36357	06/12/17	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA30923	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA39893	09/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 415V/110V MOTOR CABLE 25M	LA37221	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA39894	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA39900	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA39895	08/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA38184	08/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA26388	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA16158	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 25M	LA15570	09/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA33500	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32341	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA25993	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32345	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA33499	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32343	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32344	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32489	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA44000	31/01/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32487	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32490	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32484	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32485	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32486	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32821	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32811	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32810	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32813	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32812	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32809	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32806	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32488	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32808	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32807	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32346	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32818	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32820	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32819	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32817	08/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 415V/110V MOTOR CABLE 5M	LA33495	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32814	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32816	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA32815	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36250	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36251	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36248	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36249	08/02/18	S	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36252	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA30913	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA30912	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36253	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36254	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36241	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36240	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36243	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36242	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36244	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36246	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36247	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36245	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36239	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA30911	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36259	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36235	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36236	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36258	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36234	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36260	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36233	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36262	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36261	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36257	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36238	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36256	25/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA30910	08/01/18	P	S	S	S	S	S	S	S	S
16A 415V/110V MOTOR CABLE 5M	LA36255	25/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A 415V/110V MOTOR CABLE 5M	LA36237	25/01/18	P	S	S	S	S	S	S	S	S
16A 5FT 110V TRS	LA25182	31/01/18	S	S	S	S	S	S	S	S	S
16A 5FT 110V TRS	LA17671	30/01/18	S	S	S	S	S	S	S	S	S
16A 5FT 110V TRS	LA17640	30/01/18	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33994	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA16305	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33993	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA38527	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33997	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33998	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33999	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33996	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33995	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33987	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA04763	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA30372	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA04733	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA30370	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA30369	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA26941	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA30371	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33990	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33992	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33991	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33988	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 10FT	LA33989	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02588	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02589	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33956	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02581	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02582	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02843	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA25403	18/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02840	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02594	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA25402	18/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33957	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33962	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33979	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33961	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33959	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33960	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02576	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02577	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33981	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33980	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33958	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33948	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33946	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33949	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33951	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33953	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33952	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33983	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33984	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33985	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33950	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA26624	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA17688	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA16493	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA16491	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33955	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA02846	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33982	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA16285	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33954	30/01/18	S	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA16290	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA25404	18/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
16A XLR5 COMBI CABLE 20FT	LA33947	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33970	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33969	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33972	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33971	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33965	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33964	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33968	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33967	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33973	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33976	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33977	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA01215	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA01251	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33975	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33974	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33978	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33059	16/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 20FT	LA33963	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA17623	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA17622	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA16289	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA42594	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02597	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02608	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02848	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA01214	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02849	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02853	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA02852	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA16495	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA01401	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA26625	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA04766	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA26626	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA26627	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 30FT	LA16109	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA02928	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA16497	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA02927	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA16119	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA34948	14/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA16499	19/01/18	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 50FT	LA26631	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16262	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16260	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30373	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16261	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA33265	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17372	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17676	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17677	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17371	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16265	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30366	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17679	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA16266	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30365	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30368	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30364	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA30367	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA17931	15/12/17	P	S	S	S	S	S	S	S	S
16A XLR5 COMBI CABLE 5FT	LA38954	15/12/17	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA25816	26/01/18	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA17520	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA16309	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA16308	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA25815	08/02/18	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA33338	19/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
32A 1PH - 16A 1PH ADAPTOR	LA36132	05/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA33340	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA16312	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA30136	26/01/18	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA17521	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA25814	26/01/18	S	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA03445	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 16A 1PH ADAPTOR	LA33337	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 2 X 16A 1PH ADAPTOR	LA20642	22/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 32A 3PH ADAPTOR	LA17039	25/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 32A 3PH ADAPTOR	LA17024	24/01/18	P	S	S	S	S	S	S	S	S
32A 1PH - 63A 1PH ADAPTOR	LA38043	24/01/18	P	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30141	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30140	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30138	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 10FT TRS	LA30139	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 2 WAY SPLITTER	LA25817	22/01/18	P	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA42104	08/02/18	S	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA32423	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA30145	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA30144	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 20FT TRS	LA26963	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA42623	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA32426	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA15710	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH 30FT TRS	LA42588	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA32427	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA16190	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 50FT TRS	LA32428	18/12/17	P	S	S	S	S	S	S	S	S
32A 1PH 5FT TRS	LA15511	19/01/18	P	S	S	S	S	S	S	S	S
32A 1PH FOH DISTRO (2 X 13A, 4 X 16A)	LA22097	29/01/18	S	S	S	S	S	S	S	S	S
32A 1PH FOH DISTRO (2 X 13A, 4 X 16A)	LA15807	29/01/18	S	S	S	S	S	S	S	S	S
32A 1PH TRS 50FT	LA39026	18/12/17	P	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36009	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32028	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA42153	31/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32287	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36010	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32288	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32031	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36011	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36008	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32030	30/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA22048	30/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA32029	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA20179	29/01/18	S	S	S	S	S	S	S	S	S
32A 3 PH - 2 X 32A 3PH SPLITTER	LA36012	29/01/18	S	S	S	S	S	S	S	S	S
32A 3PH - 16A 3PH (4 PIN) MOTOR ADAPTOR	LA15639	02/02/18	S	S	S	S	S	S	S	S	S
32A 3PH - 16A 3PH (5 PIN) ADAPTOR	LA17023	02/02/18	S	S	S	S	S	S	S	S	S
32A 3PH - 32A 1PH ADAPTOR	LA37262	02/02/18	S	S	S	S	S	S	S	S	S
32A 3PH - 32A 1PH ADAPTOR	LA25985	02/02/18	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA37774	13/12/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA26960	29/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
32A 3PH - 63A 3PH ADAPTOR	LA21074	12/12/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA42563	21/12/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA42562	12/12/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA21558	13/12/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA22979	21/12/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA38592	21/12/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32907	13/12/17	P	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32909	02/02/18	S	S	S	S	S	S	S	S	S
32A 3PH - 63A 3PH ADAPTOR	LA32908	21/12/17	P	S	S	S	S	S	S	S	S
32A 3PH - EPIC ADAPTOR	LA16952	31/01/18	S	S	S	S	S	S	S	S	S
32A 3PH - EPIC ADAPTOR	LA16951	31/01/18	S	S	S	S	S	S	S	S	S
32A 3PH - EPIC ADAPTOR	LA16953	31/01/18	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA36114	29/01/18	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA36115	29/01/18	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA36112	29/01/18	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA36113	02/02/18	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA22161	29/01/18	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA20309	29/01/18	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA26954	29/01/18	S	S	S	S	S	S	S	S	S
32A 3PH (5 PIN) - 2 X 16A 3PH (4 PIN)	LA42152	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA20182	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22049	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22050	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22051	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH BARE END TAILS	LA22044	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH LUGGED TAILS	LA15900	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH LUGGED TAILS	LA21112	08/02/18	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA34941	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33638	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33506	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33367	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA17432	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30094	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33645	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33643	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA33505	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30097	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA26261	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30510	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30762	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30763	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30509	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30506	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30505	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30508	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30504	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30754	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30503	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 10M	LA30755	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38838	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32461	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32460	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38937	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA33515	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38940	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32459	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38840	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38839	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA33060	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA30756	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38846	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA30768	16/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
32A 3PH MAINS CABLE 15M	LA38936	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32912	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38837	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA38836	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32911	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 15M	LA32458	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32282	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32283	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30516	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30517	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30772	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32281	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30801	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA32284	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA33632	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30771	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA33528	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30769	08/02/18	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA30800	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 20M	LA33628	31/01/18	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA25097	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38850	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38848	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38849	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33365	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33366	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30525	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33364	08/02/18	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30802	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30775	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA33625	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30774	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30524	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30757	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30520	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA38851	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30776	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA25327	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA25328	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30522	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 30M	LA30523	17/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32396	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32397	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32395	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32394	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32483	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30753	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA17428	26/01/18	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA33315	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA17459	26/01/18	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA32398	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA17504	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30490	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30491	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA42878	30/01/18	S	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30487	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30493	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 3M	LA30494	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32914	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32915	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32389	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33503	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30502	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33655	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32393	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32917	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32916	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32390	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30247	16/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
32A 3PH MAINS CABLE 5M	LA30248	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA32392	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33501	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25333	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30501	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25336	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25335	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30496	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30495	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30498	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA30497	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25338	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33496	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25351	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33494	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA33497	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25340	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25341	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH MAINS CABLE 5M	LA25350	16/01/18	P	S	S	S	S	S	S	S	S
32A 3PH PHASE REVERSER	LA15902	02/02/18	S	S	S	S	S	S	S	S	S
32A 3PH PHASE REVERSER	LA15903	02/02/18	S	S	S	S	S	S	S	S	S
32A 3PH PHASE REVERSER	LA33785	02/02/18	S	S	S	S	S	S	S	S	S
35MM CAMS - POWERLOK ADAPTOR	LA20330	21/12/17	P	S	S	S	S	S	S	S	S
35MM CAMS - POWERLOK ADAPTOR	LA42809	30/01/18	S	S	S	S	S	S	S	S	S
35MM POWERLOCK LINK 1M	LA30085	29/01/18	S	S	S	S	S	S	S	S	S
35MM POWERLOCK LINK 1M	LA37673	20/12/17	P	S	S	S	S	S	S	S	S
3KW MOLE PAR	LA31762	22/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31763	22/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31764	22/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31750	22/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31749	19/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31748	22/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31753	22/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31752	22/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31751	22/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31747	22/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31743	22/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31742	22/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31741	19/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31746	22/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31745	22/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31744	22/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31758	22/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31759	19/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31760	22/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31756	22/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31754	19/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31757	19/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
3KW MOLE PAR	LA31761	22/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26883	07/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26887	07/12/17	P	S	0.06 P	>300 P	0.43 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26888	07/12/17	P	S	0.09 P	>300 P	0.44 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26838	07/12/17	P	S	0.05 P	>300 P	0.43 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26880	07/12/17	P	S	0.05 P	>300 P	0.55 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26881	07/12/17	P	S	0.06 P	>300 P	0.42 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26837	07/12/17	P	S	0.05 P	>300 P	0.48 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26699	07/12/17	P	S	0.08 P	>300 P	0.40 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26738	07/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
500W HALOGEN FLOOD WORK LIGHT	LA26702	07/12/17	P	S	0.05 P	>300 P	0.39 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
500W HALOGEN FLOOD WORK LIGHT	LA26701	07/12/17	P	S	0.05 P	>300 P	0.42 P	<0.10 P	S	S	S
50M TYPE III MULTICORE 16A	LA34414	05/02/18	S	S	S	S	S	S	S	S	S
50MM POWERLOCK CABLE 10M	LA20468	30/01/18	S	S	S	S	S	S	S	S	S
50MM POWERLOCK CABLE 3M	LA21290	30/01/18	S	S	S	S	S	S	S	S	S
50MM POWERLOCK CABLE 3M	LA20470	30/01/18	S	S	S	S	S	S	S	S	S
5M FOH DESK LOOM ETHERNET & POWER	LA30726	25/01/18	P	S	S	S	S	S	S	S	S
5M FOH DESK LOOM ETHERNET & POWER	LA42156	30/01/18	S	S	S	S	S	S	S	S	S
63A 1PH - 125A 1PH ADAPTOR	LA30759	24/01/18	P	S	S	S	S	S	S	S	S
63A 1PH - 2 X 32A 1PH ADAPTOR	LA17018	24/01/18	P	S	S	S	S	S	S	S	S
63A 1PH - 2 X 63A 1PH SPLITTER	LA17017	24/01/18	P	S	S	S	S	S	S	S	S
63A 1PH - 32A 1PH ADAPTOR	LA38044	24/01/18	P	S	S	S	S	S	S	S	S
63A 1PH - 63A 3PH ADAPTER	LA37913	02/02/18	S	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA42569	05/01/18	P	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA21206	05/01/18	P	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA35152	05/01/18	P	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA42568	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA26971	05/01/18	P	S	S	S	S	S	S	S	S
63A 3PH - 125A 3PH ADAPTOR	LA22248	05/01/18	P	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA42564	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA22481	02/02/18	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA35199	02/02/18	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA42716	30/01/18	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA32385	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA42717	31/01/18	S	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA34391	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH - 32A 3PH ADAPTOR	LA42565	30/01/18	S	S	S	S	S	S	S	S	S
63A 3PH - 63A 1PH ADAPTOR	LA15716	02/02/18	S	S	S	S	S	S	S	S	S
63A 3PH - 63A 1PH ADAPTOR	LA38526	02/02/18	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTER 3M	LA42960	31/01/18	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA31371	29/01/18	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA37825	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA22326	29/01/18	S	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA42571	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA42570	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH - POWERLOCK ADAPTOR 3M	LA42879	29/01/18	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA42880	30/01/18	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA21432	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA21433	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA42744	30/01/18	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA22182	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA42575	31/01/18	S	S	S	S	S	S	S	S	S
63A 3PH BARE END TAILS	LA20315	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA21310	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA32466	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA42556	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA21427	12/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA25626	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA17167	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA00751	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 10M	LA42557	12/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA21308	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA21309	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA33627	12/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA39005	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA25627	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA32465	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA21424	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 20M	LA42555	12/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
63A 3PH MAINS CABLE 3M	LA39164	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 3M	LA42561	31/01/18	S	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 3M	LA39161	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 3M	LA42560	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA42559	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA20643	12/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA25625	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA42558	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA21428	13/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA32467	21/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA16538	12/12/17	P	S	S	S	S	S	S	S	S
63A 3PH MAINS CABLE 5M	LA34533	13/12/17	P	S	S	S	S	S	S	S	S
70MM CAMS - POWERLOCK ADAPTOR 3M	LA42721	10/01/18	P	S	S	S	S	S	S	S	S
70MM CAMS - POWERLOCK ADAPTOR 3M	LA22135	29/01/18	S	S	S	S	S	S	S	S	S
70MM POWERLOCK BARE END TAILS	LA33406	10/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK BARE END TAILS	LA42720	10/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 10M	LA42771	10/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 10M	LA33403	10/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 20M	LA42790	10/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 20M	LA33402	10/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 20M	LA42789	10/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 5M	LA42753	10/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 5M	LA33404	11/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK CABLE 5M	LA42749	29/01/18	S	S	S	S	S	S	S	S	S
70MM POWERLOCK LUGGED TAILS	LA33407	10/01/18	P	S	S	S	S	S	S	S	S
70MM POWERLOCK LUGGED TAILS	LA42735	29/01/18	S	S	S	S	S	S	S	S	S
95MM CAMS - POWERLOCK ADAPTOR 3M	LA22252	29/01/18	S	S	S	S	S	S	S	S	S
95MM CAMS - POWERLOCK ADAPTOR 3M	LA34720	29/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK BARE END TAILS	LA21157	29/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK BARE END TAILS	LA42740	26/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK BARE END TAILS	LA21816	25/01/18	P	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA42773	30/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA15136	29/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA42774	26/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 10M	LA42772	30/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 2M	LA31945	29/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA21744	29/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA39163	25/01/18	P	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA22971	29/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA21814	29/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42764	29/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42742	30/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42745	30/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42743	26/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA42739	26/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 3M	LA31610	29/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 5M	LA42755	26/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 5M	LA42762	30/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK CABLE 5M	LA42761	30/01/18	S	S	S	S	S	S	S	S	S
95MM POWERLOCK LUGGED TAILS	LA21158	25/01/18	P	S	S	S	S	S	S	S	S
95MM POWERLOCK LUGGED	LA42748	26/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
TAILS											
95MM POWERLOCK LUGGED TAILS	LA42763	29/01/18	S	S	S	S	S	S	S	S	S
ADB 9 LITE SVOBODA	LA02192	08/01/18	P	S	0.06 P	>300 P	2.34 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02196	08/01/18	P	S	0.08 P	>300 P	2.36 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02190	08/01/18	P	S	0.05 P	>300 P	2.40 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02191	08/01/18	P	S	0.05 P	>300 P	2.35 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02193	08/01/18	P	S	0.05 P	>300 P	2.33 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02198	08/01/18	P	S	0.05 P	>300 P	2.35 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02199	08/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02195	08/01/18	P	S	0.08 P	>300 P	2.29 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02197	08/01/18	P	S	0.07 P	>300 P	2.22 P	<0.10 P	S	S	S
ADB 9 LITE SVOBODA	LA02194	08/01/18	P	S	0.06 P	>300 P	2.38 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24129	07/12/17	P	S	0.03 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24138	07/12/17	P	S	0.05 P	>300 P	0.79 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24139	07/12/17	P	S	0.04 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24137	07/12/17	P	S	0.04 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24135	07/12/17	P	S	0.03 P	>300 P	0.85 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24136	07/12/17	P	S	0.03 P	>300 P	0.78 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24140	07/12/17	P	S	0.03 P	>300 P	0.85 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25974	07/12/17	P	S	0.02 P	>300 P	0.85 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25973	07/12/17	P	S	0.03 P	>300 P	0.54 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25628	07/12/17	P	S	0.04 P	>300 P	0.85 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25630	07/12/17	P	S	0.04 P	>300 P	0.84 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25629	07/12/17	P	S	0.04 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24130	07/12/17	P	S	0.03 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25631	07/12/17	P	S	0.03 P	>300 P	0.83 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25633	07/12/17	P	S	0.04 P	>300 P	0.84 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24131	07/12/17	P	S	0.03 P	>300 P	0.84 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA25632	07/12/17	P	S	0.04 P	>300 P	0.82 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24134	07/12/17	P	S	0.03 P	>300 P	0.85 P	<0.10 P	S	S	S
ALDO IANIRO MINILITE Q1000 PHOTOFLOOD C/W BARNDOR	LA24133	07/12/17	P	S	0.03 P	>300 P	0.82 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34892	18/12/17	P	S	0.02 P	>300 P	0.77 P	<0.10 P	S	S	S
ALTMAN SCOOP 161 REFLECTOR FLOODLIGHT	LA34890	18/12/17	P	S	0.02 P	>300 P	0.78 P	<0.10 P	S	S	S
ALTMAN SCOOP 161	LA34889	15/12/17	P	S	0.04 P	>300 P	0.84 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34893	20/12/17	P	S	0.03 P	>300 P	0.79 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34896	15/12/17	P	S	0.02 P	>300 P	0.80 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34891	15/12/17	P	S	0.02 P	>300 P	0.83 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34894	18/12/17	P	S	0.04 P	>300 P	0.84 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34895	15/12/17	P	S	0.04 P	>300 P	0.78 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34239	20/12/17	P	S	0.03 P	>300 P	0.51 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34692	15/12/17	P	S	0.03 P	>300 P	0.76 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34237	20/12/17	P	S	0.03 P	>300 P	0.88 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34238	15/12/17	P	S	0.03 P	>300 P	0.83 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34690	15/12/17	P	S	0.05 P	>300 P	0.86 P	<0.10 P	S	S	S
REFLECTOR FLOODLIGHT ALTMAN SCOOP 161	LA34691	15/12/17	P	S	0.03 P	>300 P	0.53 P	<0.10 P	S	S	S
ANYTRONIC S1205 SWITCH PACK 192 32A 3PH	LA38651	12/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONIC S1205 SWITCH PACK 192 32A 3PH	LA38649	12/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONIC S1205 SWITCH PACK 192 DMX 32A 3PH	LA25750	12/12/17	P	S	0.06 P	>300 P	0.12 P	<0.10 P	S	S	S
ANYTRONICS D1225 12 CHANNEL DIMMER	LA24070	12/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS D1225 12 CHANNEL DIMMER	LA25661	12/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS INLINE 5KW DIMMER DMX 32A 1PH	LA20810	13/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K090 S192 10A 6 WAY SWITCH PACK	LA24071	12/12/17	P	S	0.05 P	>300 P	0.05 P	<0.10 P	S	S	S
ANYTRONICS K090 S192 10A 6 WAY SWITCH PACK	LA21299	12/12/17	P	S	0.05 P	>300 P	0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA26088	13/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA25035	13/12/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA25036	13/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA20324	13/12/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS K117 INLINE 10A DIMMER	LA26087	10/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37628	13/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA38467	21/12/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37627	13/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA38468	13/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA38466	13/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37626	12/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
ANYTRONICS LOCATION PRO DIM 10A DIMMER	LA37625	13/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
APC 1U 450VA POWERSTACK UPS	LA41555	25/01/18	P	S	0.09 P	S	<0.05 P	0.55 P	S	S	S
APC 2U 1500VA UPS (CONTROL RACKS)	LA38172	25/01/18	P	S	0.05 P	S	<0.05 P	0.76 P	S	S	S
APC 2U 1500VA UPS (CONTROL RACKS)	LA38057	25/01/18	P	S	0.05 P	S	<0.05 P	1.31 P	S	S	S
APC 2U 1500VA UPS (CONTROL RACKS)	LA34322	25/01/18	P	S	0.05 P	S	<0.05 P	0.78 P	S	S	S
APC 2U 1500VA UPS (CONTROL RACKS)	LA41002	25/01/18	P	S	0.09 P	S	<0.05 P	1.50 P	S	S	S
APC 2U 1500VA UPS	LA37675	25/01/18	P	S	0.06 P	S	<0.05 P	0.78 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
(CONTROL RACKS)											
APC 2U 1500VA UPS	LA38050	25/01/18	P	S	0.05 P	S	<0.05 P	1.39 P	S	S	S
(CONTROL RACKS)											
APPLE MAC MINI 2.5GHZ 250GB SSD	LA33389	25/01/18	P	S	S	S	S	S	<0.10 P	S	S
APPLE MAC MINI 2.5GHZ 250GB SSD	LA33388	25/01/18	P	S	S	S	S	S	<0.10 P	S	S
APPLE MAC MINI 2.5GHZ 250GB SSD	LA41464	24/01/18	P	S	S	S	S	S	<0.10 P	S	S
APPLE MAC MINI 2.5GHZ 250GB SSD	LA41465	24/01/18	P	S	S	S	S	S	<0.10 P	S	S
ARTISTIC LICENCE ETHER-LYNX ART NET NODE	LA25345	12/01/18	P	S	0.08 P	S	<0.05 P	0.22 P	S	S	S
ARTISTIC LICENCE ETHER-LYNX ART NET NODE	LA25367	12/01/18	P	S	0.05 P	S	<0.05 P	0.23 P	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA38505	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA25416	12/12/17	P	S	0.04 P	>300 P	S	S	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA25369	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA34751	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
ASL PS278/9 TALKBACK PSU UNIT	LA38411	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
ASL PS285 TALKBACK AUX PSU	LA25359	12/12/17	P	S	0.05 P	>300 P	S	S	S	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVM SWITCH	LA41554	24/01/18	P	S	S	S	S	S	<0.10 P	S	S
ATEN 4 PORT USB DVI DUAL VIEW KVMP SWITCH	LA41466	24/01/18	P	S	S	S	S	S	<0.10 P	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA22458	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31215	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA24752	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA24753	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA22487	17/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA22486	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31846	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA26889	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31844	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31845	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31847	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR RACK MOUNT (DOUBLE)	LA31992	17/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR TRUSS MOUNT (6 OUT)	LA31412	12/01/18	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
AVO DMX OPTO ISOLATOR TRUSS MOUNT (6 OUT)	LA31944	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
AVO DMX OPTO ISOLATOR TRUSS MOUNT (6 OUT)	LA31413	15/01/18	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
AVOCENT DUAL DVI KVM EXTENDER (RECEIVER)	LA39448	24/01/18	P	S	S	S	S	S	<0.10 P	S	S
AYRTON MAGIC PANEL 602	LA41422	12/12/17	P	S	0.06 P	>300 P	<0.05 P	0.31 P	S	S	S
AYRTON MAGIC PANEL 602	LA41423	12/12/17	P	S	0.08 P	>300 P	<0.05 P	0.30 P	S	S	S
AYRTON MAGIC PANEL 602	LA41420	12/12/17	P	S	0.08 P	>300 P	<0.05 P	0.31 P	S	S	S
AYRTON MAGIC PANEL 602	LA41421	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.32 P	S	S	S
AYRTON MAGIC PANEL 602	LA34656	12/12/17	P	S	0.08 P	>300 P	<0.05 P	0.31 P	S	S	S
AYRTON MAGIC PANEL 602	LA34655	12/12/17	P	S	0.08 P	>300 P	<0.05 P	0.33 P	S	S	S
AYRTON MAGIC PANEL 602	LA34658	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.31 P	S	S	S
AYRTON MAGIC PANEL 602	LA34657	12/12/17	P	S	0.09 P	>300 P	<0.05 P	0.31 P	S	S	S
AYRTON MAGIC PANEL 602	LA34654	12/12/17	P	S	0.09 P	>300 P	<0.05 P	0.33 P	S	S	S
AYRTON MAGIC PANEL 602	LA34651	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.32 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
AYRTON MAGIC PANEL 602	LA34650	12/12/17	P	S	0.09 P	>300 P	<0.05 P	0.31 P	S	S	S
AYRTON MAGIC PANEL 602	LA34653	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.32 P	S	S	S
AYRTON MAGIC PANEL 602	LA34652	12/12/17	P	S	0.09 P	>300 P	<0.05 P	0.31 P	S	S	S
AYRTON MAGIC PANEL 602	LA34659	12/12/17	P	S	0.08 P	>300 P	<0.05 P	0.32 P	S	S	S
AYRTON MAGIC PANEL 602	LA37113	12/12/17	P	S	0.09 P	>300 P	<0.05 P	0.31 P	S	S	S
AYRTON MAGIC PANEL 602	LA34661	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.33 P	S	S	S
AYRTON MAGIC PANEL 602	LA34660	12/12/17	P	S	0.09 P	>300 P	<0.05 P	0.31 P	S	S	S
AYRTON MAGICBLADE-R	LA37959	21/12/17	P	S	0.06 P	>300 P	<0.05 P	0.19 P	S	S	S
AYRTON MAGICBLADE-R	LA37958	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICBLADE-R	LA37371	19/12/17	P	S	0.04 P	>300 P	<0.05 P	0.19 P	S	S	S
AYRTON MAGICBLADE-R	LA37370	14/12/17	P	S	0.02 P	>300 P	<0.05 P	0.19 P	S	S	S
AYRTON MAGICBLADE-R	LA37368	14/12/17	P	S	0.03 P	>300 P	<0.05 P	0.19 P	S	S	S
AYRTON MAGICBLADE-R	LA37369	14/12/17	P	S	0.03 P	>300 P	<0.05 P	0.18 P	S	S	S
AYRTON MAGICBLADE-R	LA37366	14/12/17	P	S	0.03 P	>300 P	<0.05 P	0.18 P	S	S	S
AYRTON MAGICBLADE-R	LA37954	14/12/17	P	S	0.02 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICBLADE-R	LA37957	21/12/17	P	S	0.08 P	>300 P	<0.05 P	0.22 P	S	S	S
AYRTON MAGICBLADE-R	LA37956	14/12/17	P	S	0.06 P	>300 P	<0.05 P	0.18 P	S	S	S
AYRTON MAGICBLADE-R	LA37955	21/12/17	P	S	0.06 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICBLADE-R	LA37708	21/12/17	P	S	0.05 P	>300 P	<0.05 P	0.21 P	S	S	S
AYRTON MAGICBLADE-R	LA37367	14/12/17	P	S	0.03 P	>300 P	<0.05 P	0.20 P	S	S	S
AYRTON MAGICDOT-R	LA38766	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38765	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37885	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA37876	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37888	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37889	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37886	11/01/18	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37887	12/12/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37884	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA37880	11/01/18	P	S	0.07 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37879	11/01/18	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA38767	12/12/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37881	11/01/18	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37882	11/01/18	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37883	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37878	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37877	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38758	12/12/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37870	05/01/18	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA38759	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.17 P	S	S	S
AYRTON MAGICDOT-R	LA38761	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
AYRTON MAGICDOT-R	LA38760	12/12/17	P	S	0.09 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA37871	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37875	05/01/18	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38757	12/12/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA37874	05/01/18	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37872	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37873	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38762	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA38764	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA38763	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37893	05/01/18	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37890	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37891	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA37894	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA37898	11/01/18	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37935	11/01/18	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37897	11/01/18	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37895	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37896	12/12/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37869	05/01/18	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38774	12/12/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA38773	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA38775	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA37856	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38776	12/12/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA38772	12/12/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA38771	12/12/17	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37863	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
AYRTON MAGICDOT-R	LA37847	11/01/18	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA37862	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA37855	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37857	12/12/17	P	S	0.06 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA37843	11/01/18	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA37861	05/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37842	11/01/18	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38777	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA38778	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA37860	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37858	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37841	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37846	12/12/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37844	05/01/18	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37845	05/01/18	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37864	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37835	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37834	05/01/18	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37836	11/01/18	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38768	12/12/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37837	11/01/18	P	S	0.08 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37849	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37833	11/01/18	P	S	0.09 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37832	11/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37868	05/01/18	P	S	0.06 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37852	12/12/17	P	S	0.07 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37850	11/01/18	P	S	0.05 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37838	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37866	05/01/18	P	S	0.07 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA38770	12/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37853	12/12/17	P	S	0.08 P	>300 P	<0.05 P	0.13 P	S	S	S
AYRTON MAGICDOT-R	LA37865	11/01/18	P	S	0.02 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA37854	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37867	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37839	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
AYRTON MAGICDOT-R	LA38769	12/12/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
AYRTON MAGICDOT-R	LA37848	11/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
AYRTON MAGICDOT-R	LA37840	11/01/18	P	S	0.07 P	>300 P	<0.05 P	0.14 P	S	S	S
BLACKMAGIC 20X20 MATRIX - SDI	LA39463	12/01/18	P	S	0.03 P	S	<0.05 P	0.22 P	S	S	S
CAMLOK - 125A 3PH ADAPTOR	LA34718	05/01/18	P	S	S	S	S	S	S	S	S
CAMLOK - 125A 3PH ADAPTOR	LA17068	05/01/18	P	S	S	S	S	S	S	S	S
CAMLOK - 63A 3PH ADAPTOR	LA20300	13/12/17	P	S	S	S	S	S	S	S	S
CAMLOK - 63A 3PH ADAPTOR	LA17166	13/12/17	P	S	S	S	S	S	S	S	S
CAMLOK - 63A 3PH ADAPTOR	LA34534	13/12/17	P	S	S	S	S	S	S	S	S
CCT 500W CYC UNIT	LA17555	04/01/18	P	S	0.06 P	>300 P	0.40 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17556	04/01/18	P	S	0.06 P	>300 P	0.53 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17554	04/01/18	P	S	0.09 P	>300 P	0.51 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA20011	04/01/18	P	S	0.09 P	>300 P	0.48 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA04641	04/01/18	P	S	0.07 P	>300 P	0.40 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17560	04/01/18	P	S	0.09 P	>300 P	0.42 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17561	04/01/18	P	S	0.07 P	>300 P	0.52 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17559	04/01/18	P	S	0.07 P	>300 P	0.49 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17557	04/01/18	P	S	0.07 P	>300 P	0.51 P	<0.10 P	S	S	S
CCT 500W CYC UNIT	LA17558	04/01/18	P	S	0.06 P	>300 P	0.41 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31662	04/01/18	P	S	0.02 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31853	04/01/18	P	S	0.04 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31660	04/01/18	P	S	0.05 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31661	04/01/18	P	S	0.05 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA26030	04/01/18	P	S	0.04 P	>300 P	0.64 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA26915	04/01/18	P	S	0.04 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA24068	04/01/18	P	S	0.06 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA24460	04/01/18	P	S	0.05 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - BLACK	LA31852	04/01/18	P	S	0.04 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22831	04/01/18	P	S	0.04 P	>300 P	0.64 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22823	04/01/18	P	S	0.02 P	>300 P	0.63 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22828	04/01/18	P	S	0.05 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22829	04/01/18	P	S	0.03 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22832	04/01/18	P	S	0.03 P	>300 P	0.63 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CCT 650W FRESNEL - WHITE	LA22825	04/01/18	P	S	0.03 P	>300 P	0.66 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22824	04/01/18	P	S	0.04 P	>300 P	0.64 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22827	04/01/18	P	S	0.04 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22821	04/01/18	P	S	0.03 P	>300 P	0.64 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22826	04/01/18	P	S	0.09 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22830	04/01/18	P	S	0.06 P	>300 P	0.65 P	<0.10 P	S	S	S
CCT 650W FRESNEL - WHITE	LA22822	04/01/18	P	S	0.04 P	>300 P	0.64 P	<0.10 P	S	S	S
CHAUVET COLORADO2 LED PAR 16A 5PIN	LA34928	09/01/18	P	S	0.05 P	>300 P	<0.05 P	0.56 P	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26046	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA24146	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA24715	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26856	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26855	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
CHROMAQ 12 WAY SCROLLER PSU	LA26398	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17590	17/01/18	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA34919	17/01/18	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA34920	17/01/18	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA34921	17/01/18	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17899	17/01/18	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA25014	17/01/18	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA25016	17/01/18	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMAQ 2PU 2-WAY SCROLLER PSU	LA17586	17/01/18	P	S	S	>300 P	S	S	<0.10 P	S	S
CHROMA-Q COLOR FORCE II 48	LA41396	15/12/17	P	S	0.06 P	>300 P	0.09 P	0.45 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41400	15/12/17	P	S	0.05 P	>300 P	0.08 P	0.41 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41401	15/12/17	P	S	0.05 P	>300 P	0.09 P	0.42 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41397	15/12/17	P	S	0.05 P	>300 P	0.09 P	0.51 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41398	15/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41399	15/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41417	15/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41418	15/12/17	P	S	0.06 P	>300 P	0.09 P	0.42 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41416	15/12/17	P	S	0.06 P	>300 P	0.09 P	0.42 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41403	14/12/17	P	S	0.05 P	>300 P	0.08 P	0.42 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41419	14/12/17	P	S	0.06 P	>300 P	0.09 P	0.51 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41402	14/12/17	P	S	0.05 P	>300 P	0.09 P	0.41 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41395	15/12/17	P	S	0.06 P	>300 P	0.09 P	0.42 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41394	15/12/17	P	S	0.06 P	>300 P	0.09 P	0.45 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41393	15/12/17	P	S	0.06 P	>300 P	0.08 P	0.42 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41412	14/12/17	P	S	0.06 P	>300 P	0.09 P	0.42 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41411	15/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41414	14/12/17	P	S	0.06 P	>300 P	0.08 P	0.41 P	S	S	S
CHROMA-Q COLOR FORCE II 48	LA41413	14/12/17	P	S	0.05 P	>300 P	0.09 P	0.42 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
48 CHROMA-Q COLOR FORCE II	LA41410	15/12/17	P	S	0.06 P	>300 P	0.08 P	0.42 P	S	S	S
48 CHROMA-Q COLOR FORCE II	LA41404	14/12/17	P	S	0.06 P	>300 P	0.09 P	0.50 P	S	S	S
48 CHROMA-Q COLOR FORCE II	LA41415	15/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
48 CHROMA-Q COLOR FORCE II	LA41409	14/12/17	P	S	0.05 P	>300 P	0.09 P	0.41 P	S	S	S
48 CHROMA-Q COLOR FORCE II	LA41408	15/12/17	P	S	0.06 P	>300 P	0.09 P	0.41 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34313	18/01/18	P	S	0.06 P	>300 P	<0.05 P	4.39 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34721	18/01/18	P	S	0.19 P	>300 P	0.12 P	1.97 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34314	18/01/18	P	S	0.08 P	>300 P	0.09 P	2.26 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34312	18/01/18	P	S	0.04 P	>300 P	<0.05 P	4.37 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34187	18/01/18	P	S	0.08 P	>300 P	0.08 P	2.06 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34188	18/01/18	P	S	0.17 P	>300 P	0.11 P	1.85 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34186	18/01/18	P	S	0.04 P	>300 P	<0.05 P	3.86 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34185	18/01/18	P	S	0.12 P	>300 P	0.09 P	2.09 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA37328	18/01/18	P	S	0.25 P	>300 P	0.09 P	2.06 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34194	18/01/18	P	S	0.07 P	>300 P	0.11 P	2.00 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34193	18/01/18	P	S	0.11 P	>300 P	0.12 P	2.03 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34195	18/01/18	P	S	0.40 P	>300 P	0.09 P	2.13 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34189	18/01/18	P	S	0.12 P	>300 P	0.11 P	1.86 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34192	18/01/18	P	S	0.12 P	>300 P	0.09 P	1.97 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34184	18/01/18	P	S	0.36 P	>300 P	0.09 P	2.03 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34308	18/01/18	P	S	0.09 P	>300 P	0.09 P	2.07 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34307	18/01/18	P	S	0.08 P	>300 P	0.12 P	2.02 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34309	18/01/18	P	S	0.04 P	>300 P	0.11 P	2.16 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34311	18/01/18	P	S	0.08 P	>300 P	0.09 P	2.00 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34310	18/01/18	P	S	0.05 P	>300 P	<0.05 P	4.45 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34183	18/01/18	P	S	0.07 P	>300 P	0.11 P	1.80 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34196	18/01/18	P	S	0.21 P	>300 P	<0.05 P	4.05 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34182	18/01/18	P	S	0.08 P	>300 P	0.11 P	1.87 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34306	18/01/18	P	S	0.14 P	>300 P	0.12 P	2.20 P	S	S	S
CHROMLECH ELIDY BIG PSU PSX9	LA34197	18/01/18	P	S	0.18 P	>300 P	0.12 P	1.87 P	S	S	S
CITY THEATRICAL SPDS 375TR 6-WAY IW BLAST SUPPLY	LA31132	12/01/18	P	S	0.08 P	35.21 P	<0.05 P	0.45 P	S	S	S
CITY THEATRICAL SPDS 375TR 6-WAY IW BLAST SUPPLY	LA31112	08/01/18	P	S	0.06 P	123.10 P	<0.05 P	0.47 P	S	S	S
CITY THEATRICAL SPDS 375TR 6-WAY IW BLAST SUPPLY	LA31133	12/01/18	P	S	0.05 P	24.55 P	<0.05 P	0.45 P	S	S	S
CITY THEATRICAL SPDS 375TR 6-WAY IW BLAST SUPPLY	LA31131	08/01/18	P	S	0.04 P	9.12 P	<0.05 P	0.45 P	S	S	S
CITY THEATRICAL SPDS 375TR 6-WAY IW BLAST SUPPLY	LA31116	08/01/18	P	S	0.05 P	149.30 P	<0.05 P	0.47 P	S	S	S
CITY THEATRICAL SPDS 375TR 6-WAY IW BLAST SUPPLY	LA31113	12/01/18	P	S	0.06 P	30.16 P	<0.05 P	0.44 P	S	S	S
CLAY PAKY GLOW UP 6 WAY	LA34497	20/12/17	P	S	0.09 P	>300 P	0.07 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FLIGHT CASE											
CLAY PAKY GLOW UP 6 WAY FLIGHT CASE	LA34498	20/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34461	20/12/17	P	S	0.07 P	>300 P	<0.05 P	0.36 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34460	20/12/17	P	S	0.08 P	>300 P	<0.05 P	0.40 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34459	20/12/17	P	S	0.07 P	>300 P	<0.05 P	0.36 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34462	20/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34465	20/12/17	P	S	0.07 P	>300 P	<0.05 P	0.36 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34464	20/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34463	20/12/17	P	S	0.07 P	>300 P	<0.05 P	0.36 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34456	20/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34454	20/12/17	P	S	0.08 P	>300 P	<0.05 P	0.36 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34455	20/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34458	20/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY GLOW UP LED RGBW WIRELESS BATTERY UNIT	LA34457	20/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34947	19/01/18	P	S	0.04 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37431	15/01/18	P	S	0.04 P	>300 P	0.05 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37428	01/02/18	P	S	0.04 P	>300 P	0.06 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37426	23/01/18	P	S	0.03 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37429	13/12/17	P	S	0.04 P	>300 P	0.06 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34944	21/12/17	P	S	0.03 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34943	19/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37439	20/12/17	P	S	0.03 P	>300 P	0.05 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37438	20/12/17	P	S	0.06 P	>300 P	0.06 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37465	20/12/17	P	S	0.05 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37466	06/12/17	P	S	0.09 P	>300 P	0.05 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37433	20/12/17	P	S	0.06 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34946	06/02/18	P	S	0.06 P	>300 P	0.06 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37436	08/02/18	P	S	0.03 P	>300 P	0.06 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37435	08/02/18	P	S	0.03 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37296	06/12/17	P	S	0.09 P	>300 P	0.06 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34578	19/01/18	P	S	0.03 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37297	19/01/18	P	S	0.04 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34581	26/01/18	P	S	0.03 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37295	20/12/17	P	S	0.04 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37292	26/01/18	P	S	0.05 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34577	06/02/18	P	S	0.03 P	>300 P	0.05 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34576	06/12/17	P	S	0.08 P	>300 P	0.06 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37299	21/12/17	P	S	0.04 P	>300 P	0.05 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37308	14/12/17	P	S	0.03 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37311	23/01/18	P	S	0.04 P	>300 P	0.06 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37305	26/01/18	P	S	0.04 P	>300 P	0.06 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37307	06/02/18	P	S	0.04 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37301	06/12/17	P	S	0.09 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37300	08/02/18	P	S	0.04 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34724	26/01/18	P	S	0.04 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37303	06/02/18	P	S	0.03 P	>300 P	0.06 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37291	14/12/17	P	S	0.04 P	>300 P	0.06 P	0.49 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CLAY PAKY SHARPY SPOT	LA37419	01/02/18	P	S	0.03 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37420	01/02/18	P	S	0.04 P	>300 P	0.06 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37417	06/12/17	P	S	0.09 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37418	08/02/18	P	S	0.03 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37424	01/02/18	P	S	0.04 P	>300 P	0.06 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37425	19/01/18	P	S	0.03 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37286	19/01/18	P	S	0.04 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37423	13/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37416	06/12/17	P	S	0.09 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA34575	15/01/18	P	S	0.07 P	>300 P	0.05 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37410	06/12/17	P	S	0.09 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37409	06/12/17	P	S	0.08 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37290	13/12/17	P	S	0.04 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37414	23/01/18	P	S	0.04 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37415	01/02/18	P	S	0.04 P	>300 P	0.06 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37411	06/12/17	P	S	0.08 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37412	19/01/18	P	S	0.04 P	>300 P	0.06 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38158	01/02/18	P	S	0.07 P	>300 P	0.06 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38159	08/02/18	P	S	0.05 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38133	01/02/18	P	S	0.05 P	>300 P	0.07 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38134	20/12/17	P	S	0.03 P	>300 P	0.06 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31557	06/12/17	P	S	0.09 P	>300 P	0.05 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38163	19/01/18	P	S	0.03 P	>300 P	0.05 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38165	01/02/18	P	S	0.04 P	>300 P	0.06 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38162	20/12/17	P	S	0.03 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38160	20/12/17	P	S	0.04 P	>300 P	0.06 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38161	01/02/18	P	S	0.04 P	>300 P	0.06 P	0.55 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38137	26/01/18	P	S	0.05 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31607	19/01/18	P	S	0.04 P	>300 P	0.06 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38150	23/01/18	P	S	0.04 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38157	19/01/18	P	S	0.07 P	>300 P	0.05 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38153	21/12/17	P	S	0.03 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38154	06/12/17	P	S	0.09 P	>300 P	0.06 P	0.55 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38140	13/12/17	P	S	0.05 P	>300 P	0.06 P	0.46 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38139	19/01/18	P	S	0.03 P	>300 P	0.05 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38142	14/12/17	P	S	0.05 P	>300 P	0.06 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38149	08/02/18	P	S	0.03 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38144	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38166	13/12/17	P	S	0.04 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31601	20/12/17	P	S	0.07 P	>300 P	0.05 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37679	06/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37680	20/12/17	P	S	0.04 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31602	19/01/18	P	S	0.05 P	>300 P	0.06 P	0.53 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37678	06/12/17	P	S	0.09 P	>300 P	0.05 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31560	06/12/17	P	S	0.09 P	>300 P	0.05 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38227	20/12/17	P	S	0.06 P	>300 P	0.06 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37676	20/12/17	P	S	0.05 P	>300 P	0.05 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31599	06/12/17	P	S	0.09 P	>300 P	0.05 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37682	06/12/17	P	S	0.09 P	>300 P	0.05 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37690	06/02/18	P	S	0.03 P	>300 P	0.06 P	0.45 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37689	06/02/18	P	S	0.04 P	>300 P	0.06 P	0.47 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38170	01/02/18	P	S	0.03 P	>300 P	0.06 P	0.50 P	S	S	S
CLAY PAKY SHARPY SPOT	LA31603	06/12/17	P	S	0.09 P	>300 P	0.06 P	0.55 P	S	S	S
CLAY PAKY SHARPY SPOT	LA38168	01/02/18	P	S	0.03 P	>300 P	0.06 P	0.52 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37688	06/12/17	P	S	0.09 P	>300 P	0.06 P	0.51 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37685	20/12/17	P	S	0.04 P	>300 P	0.06 P	0.49 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37686	01/02/18	P	S	0.04 P	>300 P	0.06 P	0.48 P	S	S	S
CLAY PAKY SHARPY SPOT	LA37687	20/12/17	P	S	0.03 P	>300 P	0.06 P	0.48 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA39996	17/01/18	P	S	0.08 P	S	<0.05 P	1.20 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA39997	12/12/17	P	S	0.05 P	>300 P	S	S	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA37967	17/01/18	P	S	0.06 P	S	<0.05 P	0.62 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA37966	16/01/18	P	S	0.06 P	S	<0.05 P	0.60 P	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA35408	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
CLEARCOM HMS-4X MASTER STATION	LA35409	17/01/18	P	S	0.08 P	S	<0.05 P	1.36 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CM4 4 WAY MOTOR CONTROLLER	LA20289	23/01/18	P	S	0.05 P	>300 P	S	S	S	S	S
CM4 4 WAY MOTOR CONTROLLER	LA20288	24/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26405	14/12/17	P	S	0.09 P	>300 P	0.05 P	0.31 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26407	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.31 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26410	14/12/17	P	S	0.09 P	>300 P	0.06 P	0.31 P	S	S	S
COLOUR KINETIC COLOURBLAZE 48LED BATTEN V3 (1.2M)	LA26403	14/12/17	P	S	0.08 P	>300 P	0.07 P	0.32 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31365	15/12/17	P	S	0.08 P	>300 P	0.09 P	0.45 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31373	15/12/17	P	S	0.08 P	>300 P	0.08 P	0.45 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31369	15/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31368	14/12/17	P	S	0.08 P	>300 P	0.08 P	0.44 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31366	15/12/17	P	S	0.09 P	>300 P	0.09 P	0.45 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31367	15/12/17	P	S	0.09 P	>300 P	0.09 P	0.45 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31360	15/12/17	P	S	0.09 P	>300 P	0.08 P	0.45 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31361	15/12/17	P	S	0.08 P	>300 P	0.09 P	0.45 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA34548	15/12/17	P	S	0.09 P	>300 P	0.10 P	0.46 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31359	15/12/17	P	S	0.08 P	>300 P	0.09 P	0.45 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31362	15/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31364	15/12/17	P	S	0.09 P	>300 P	0.09 P	0.46 P	S	S	S
COLOUR KINETIC COLOURBLAZE 72LED BATTEN V3 (1.85M)	LA31363	15/12/17	P	S	0.08 P	>300 P	0.08 P	0.45 P	S	S	S
COUNTDOWN CONFERENCE CLOCK CONTROLLER	LA31653	18/12/17	P	S	S	>300 P	S	S	S	S	S
DATAPATH 4 WAY DVI SPLITTER CAT	LA39174	12/01/18	P	S	0.06 P	S	<0.05 P	0.24 P	S	S	S
DATAPATH 4 WAY DVI SPLITTER CAT	LA39176	12/01/18	P	S	0.09 P	S	<0.05 P	0.24 P	S	S	S
DIGIFESTOON GLASSON LED (SMALL LAMP)	LA37330	03/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
DIGIFESTOON GLASSON LED (SMALL LAMP)	LA37331	03/01/18	P	S	0.06 P	>300 P	<0.05 P	0.27 P	S	S	S
DIGIFESTOON GLASSON LED (SMALL LAMP)	LA37333	03/01/18	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
DIGIFESTOON GLASSON LED (SMALL LAMP)	LA37319	03/01/18	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
DIGIFESTOON GLASSON LED (SMALL LAMP)	LA37318	03/01/18	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
DIGIFESTOON GLASSON LED (SMALL LAMP)	LA37320	03/01/18	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
DIGIFESTOON GLASSON PSU (LARGE LAMPS)	LA22914	04/01/18	P	S	0.06 P	>300 P	<0.05 P	0.87 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
DIGIFESTOON GLASSON PSU (LARGE LAMPS)	LA22916	04/01/18	P	S	0.18 P	>300 P	<0.05 P	0.86 P	S	S	S
DIGIFESTOON GLASSON PSU (LARGE LAMPS)	LA22915	04/01/18	P	S	0.22 P	>300 P	<0.05 P	0.98 P	S	S	S
EDISON (US) MALE - 16A 1PH 0.5M	LA35148	02/02/18	S	S	S	S	S	S	S	S	S
EDISON (US) MALE - 16A 1PH 0.5M	LA39473	02/02/18	S	S	S	S	S	S	S	S	S
ELO 1919L TOUCHSCREEN 19``	LA37789	25/01/18	P	S	S	S	S	S	<0.10 P	S	S
ELO 1919L TOUCHSCREEN 19``	LA37790	25/01/18	P	S	S	S	S	S	<0.10 P	S	S
EPIC - 32A 3PH ADAPTOR	LA15847	31/01/18	S	S	S	S	S	S	S	S	S
EPIC - 32A 3PH ADAPTOR	LA00348	31/01/18	S	S	S	S	S	S	S	S	S
EPIC - 32A 3PH ADAPTOR	LA15846	31/01/18	S	S	S	S	S	S	S	S	S
EPIC - 32A 3PH ADAPTOR	LA24919	31/01/18	S	S	S	S	S	S	S	S	S
EPIC - 32A 3PH ADAPTOR	LA16949	31/01/18	S	S	S	S	S	S	S	S	S
ES27 10 LAMP FESTOON STRING 3.3M	LA40324	21/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
ES27 10 LAMP FESTOON STRING 3.3M	LA40322	21/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
ES27 16 LAMP FESTOON STRING 5.5M	LA40323	21/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA37792	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA37793	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA37794	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA34349	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA34350	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA37791	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA34114	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM	LA34115	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM PSU	LA37797	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM PSU	LA34352	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM PSU	LA37795	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM PSU	LA37796	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM PSU	LA37798	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM PSU	LA34116	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM PSU	LA34351	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
EVICA GP10 MINI PROJECTION SYSTEM PSU	LA34117	18/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
FILMGEAR 1000W FRESNEL	LA34452	09/01/18	P	S	0.05 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34424	09/01/18	P	S	0.06 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34451	09/01/18	P	S	0.04 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34425	09/01/18	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34450	09/01/18	P	S	0.05 P	>300 P	1.02 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34733	09/01/18	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34732	09/01/18	P	S	0.05 P	>300 P	0.99 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34423	09/01/18	P	S	0.04 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34736	09/01/18	P	S	0.05 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34735	09/01/18	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34734	09/01/18	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34731	09/01/18	P	S	0.05 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34727	09/01/18	P	S	0.05 P	>300 P	1.02 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34726	09/01/18	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34725	09/01/18	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34730	09/01/18	P	S	0.05 P	>300 P	1.02 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34729	09/01/18	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34728	09/01/18	P	S	0.04 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34419	09/01/18	P	S	0.04 P	>300 P	0.99 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FILMGEAR 1000W FRESNEL	LA34420	09/01/18	P	S	0.05 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34421	09/01/18	P	S	0.05 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34418	09/01/18	P	S	0.06 P	>300 P	1.01 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34453	09/01/18	P	S	0.05 P	>300 P	1.00 P	<0.10 P	S	S	S
FILMGEAR 1000W FRESNEL	LA34422	09/01/18	P	S	0.05 P	>300 P	1.02 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38567	09/01/18	P	S	0.06 P	>300 P	2.05 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38565	09/01/18	P	S	0.05 P	>300 P	2.06 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38566	09/01/18	P	S	0.06 P	>300 P	2.03 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38596	09/01/18	P	S	0.05 P	>300 P	2.04 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38595	09/01/18	P	S	0.05 P	>300 P	2.04 P	<0.10 P	S	S	S
FILMGEAR 2000W JUNIOR FRESNEL	LA38594	09/01/18	P	S	0.05 P	>300 P	2.06 P	<0.10 P	S	S	S
FOLSOM IMAGE PRO HD/SDI SCAN CONVERTER	LA31415	23/01/18	P	S	0.08 P	S	<0.05 P	<0.10 P	S	S	S
FOLSOM IMAGE PRO HD/SDI SCAN CONVERTER	LA31414	23/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
FOLSOM IMAGE PRO HD/SDI SCAN CONVERTER	LA31210	23/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
FOLSOM IMAGE PRO HD/SDI SCAN CONVERTER	LA26029	23/01/18	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
FURMAN 10A POWER CONDITIONER	LA25593	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
FURMAN 10A POWER CONDITIONER	LA17382	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
FURMAN 10A POWER CONDITIONER	LA17383	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
GLP IMPRESSION X4 BAR 10	LA41454	15/12/17	P	S	0.07 P	>300 P	0.07 P	0.35 P	S	S	S
GLP IMPRESSION X4 BAR 10	LA41457	15/12/17	P	S	0.07 P	>300 P	0.07 P	0.34 P	S	S	S
GLP IMPRESSION X4 BAR 10	LA41456	15/12/17	P	S	0.07 P	>300 P	0.07 P	0.34 P	S	S	S
GLP IMPRESSION X4 BAR 10	LA41455	15/12/17	P	S	0.07 P	>300 P	0.07 P	0.35 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41431	18/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41440	15/12/17	P	S	0.04 P	>300 P	0.11 P	0.74 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41432	18/12/17	P	S	0.03 P	>300 P	0.12 P	0.71 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41442	15/12/17	P	S	0.05 P	>300 P	0.12 P	0.74 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41446	18/12/17	P	S	0.03 P	>300 P	0.07 P	0.26 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41444	18/12/17	P	S	0.03 P	>300 P	0.09 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41443	18/12/17	P	S	0.03 P	>300 P	0.10 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41435	18/12/17	P	S	0.03 P	>300 P	0.12 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41434	18/12/17	P	S	0.03 P	>300 P	0.05 P	0.20 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41433	18/12/17	P	S	0.03 P	>300 P	0.12 P	0.73 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41436	18/12/17	P	S	0.04 P	>300 P	0.12 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41439	15/12/17	P	S	0.07 P	>300 P	0.11 P	0.74 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41438	18/12/17	P	S	0.03 P	>300 P	0.11 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41437	18/12/17	P	S	0.03 P	>300 P	0.11 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41517	18/12/17	P	S	0.03 P	>300 P	0.08 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41516	18/12/17	P	S	0.03 P	>300 P	0.10 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41453	18/12/17	P	S	0.03 P	>300 P	0.08 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41520	18/12/17	P	S	0.03 P	>300 P	0.07 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41519	18/12/17	P	S	0.03 P	>300 P	0.09 P	0.68 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41518	18/12/17	P	S	0.03 P	>300 P	0.07 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41452	18/12/17	P	S	0.03 P	>300 P	0.07 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41449	18/12/17	P	S	0.03 P	>300 P	0.11 P	0.74 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41450	18/12/17	P	S	0.03 P	>300 P	0.10 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41447	18/12/17	P	S	0.03 P	>300 P	0.08 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41448	18/12/17	P	S	0.03 P	>300 P	0.10 P	<0.10 P	S	S	S
GLP IMPRESSION X4 BAR 20	LA41451	15/12/17	P	S	0.09 P	>300 P	0.11 P	0.68 P	S	S	S
GRANDMA 2 FULL SIZE CONTROL DESK	LA34386	22/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 FULL SIZE CONTROL DESK	LA34754	22/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 FULL SIZE CONTROL DESK	LA34514	22/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 FULL SIZE CONTROL DESK	LA34325	22/01/18	P	S	0.09 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 FULL SIZE CONTROL DESK	LA34614	22/01/18	P	S	0.06 P	S	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
GRANDMA 2 FULL SIZE CONTROL DESK	LA38652	22/01/18	P	S	0.05 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA34566	22/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA34113	22/01/18	P	S	0.09 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA38514	22/01/18	P	S	0.08 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 LIGHT CONSOLE	LA38363	22/01/18	P	S	0.09 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 ONPC COMMAND WING	LA41546	22/01/18	P	S	0.09 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA 2 ONPC FADER WING	LA38571	22/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA41325	23/01/18	P	S	0.05 P	S	<0.05 P	<0.10 P	S	S	S
GRANDMA NPU (NETWORK PROCESSING UNIT)	LA31342	23/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
HALF 1M MIRROR BALL - 25MM FACETS	LA34649	12/12/17	P	S	0.08 P	>300 P	0.07 P	<0.10 P	S	S	S
HALF 1M MIRROR BALL - 25MM FACETS	LA34648	12/12/17	P	S	0.06 P	>300 P	0.07 P	<0.10 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA34738	19/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
HES FULL BOAR 4 CONSOLE	LA38362	12/01/18	P	S	0.09 P	S	0.10 P	0.47 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA34739	22/01/18	P	S	0.05 P	S	<0.05 P	<0.10 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA38361	12/01/18	P	S	0.08 P	S	0.09 P	0.44 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA37445	12/01/18	P	S	0.06 P	S	0.10 P	0.39 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA34931	22/01/18	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
HES FULL BOAR 4 CONSOLE	LA34930	22/01/18	P	S	0.08 P	S	<0.05 P	<0.10 P	S	S	S
HES HEDGE HOG 4X CONSOLE	LA38291	17/01/18	P	S	0.07 P	S	<0.05 P	0.61 P	S	S	S
HES HOG 4 DP 8000	LA38289	17/01/18	P	S	0.06 P	S	<0.05 P	0.44 P	S	S	S
HES HOG 4 DP 8000	LA37374	17/01/18	P	S	0.07 P	S	<0.05 P	0.43 P	S	S	S
HES HOG 4 DP 8000	LA38520	17/01/18	P	S	0.07 P	S	<0.05 P	0.46 P	S	S	S
HES HOG 4 DP 8000	LA38055	16/01/18	P	S	0.05 P	S	<0.05 P	0.29 P	S	S	S
HES HOG 4 DP 8000	LA38288	16/01/18	P	S	0.05 P	S	<0.05 P	0.27 P	S	S	S
HES HOG 4 DP 8000	LA38287	17/01/18	P	S	0.05 P	S	<0.05 P	0.44 P	S	S	S
HES HOG 4 DP 8000	LA37157	17/01/18	P	S	0.09 P	S	<0.05 P	0.47 P	S	S	S
HES HOG 4 DP 8000	LA41266	24/01/18	P	S	0.06 P	S	<0.05 P	0.28 P	S	S	S
HES HOG 4 DP 8000	LA37158	17/01/18	P	S	0.08 P	S	<0.05 P	0.48 P	S	S	S
HES NANO HOG 4 CONSOLE	LA37111	19/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
HES PLAYBACK WING 4	LA34933	22/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
HES PLAYBACK WING 4	LA34932	22/01/18	P	S	0.03 P	S	<0.05 P	<0.10 P	S	S	S
HES RACK HOG 4 CONSOLE	LA37112	24/01/18	P	S	0.08 P	S	0.05 P	0.61 P	S	S	S
IEC - 16A 1PH ADAPTOR	LA15749	18/01/18	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25514	17/01/18	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA24377	18/01/18	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25515	18/01/18	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25519	18/01/18	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25517	18/01/18	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA25518	17/01/18	P	S	S	S	S	S	S	S	S
IEC - 16A 1PH ADAPTOR	LA35073	18/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 2 WAY SPLITTER	LA37282	09/02/18	S	S	S	S	S	S	S	S	S
IEC - IEC 2 WAY SPLITTER	LA37281	09/02/18	S	S	S	S	S	S	S	S	S
IEC - IEC 2 WAY SPLITTER	LA16153	09/02/18	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34436	05/02/18	S	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA15757	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA17518	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34489	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34429	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34430	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34426	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34428	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34431	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34432	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34433	24/01/18	P	S	S	S	S	S	S	S	S
IEC - IEC 4 WAY SPLITTER	LA34434	09/02/18	S	S	S	S	S	S	S	S	S
IEC - IEC 6 WAY SPLITTER	LA38799	24/01/18	P	S	S	S	S	S	S	S	S
IEC (F) - 16A 1PH (M)&(F) ADAPTOR 0.5M	LA30275	18/01/18	P	S	S	S	S	S	S	S	S
IEC (F) - 16A 1PH (M)&(F) ADAPTOR 0.5M	LA26717	06/02/18	S	S	S	S	S	S	S	S	S
IEC (F) - 16A 1PH (M)&(F) ADAPTOR 0.5M	LA35086	01/02/18	S	S	S	S	S	S	S	S	S
IEC (F) - 16A 1PH (M)&(F) ADAPTOR 0.5M	LA30285	05/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA37259	01/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA26987	01/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA25878	06/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA35052	06/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA30270	18/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA30148	01/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA30147	05/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA32049	01/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA35143	01/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA37656	05/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA35125	05/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA35150	18/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA32050	18/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (F) - 16A 1PH (M)&(F)	LA35094	06/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32477	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38311	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32476	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32478	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38307	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38308	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA16188	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32475	18/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38310	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38309	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33310	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33309	26/01/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33307	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA17989	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33312	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33311	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30388	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32635	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA37917	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30393	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30392	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA30391	06/02/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA34574	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32565	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32566	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA33563	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32563	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA39476	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32572	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA40309	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32636	26/01/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32568	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32569	18/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32571	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38312	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35639	24/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35640	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42101	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35618	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35637	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35638	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35641	26/01/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32897	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32898	18/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32899	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42100	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35084	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32896	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32890	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32891	24/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32893	26/01/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32887	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32888	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32889	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35615	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32895	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35617	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35114	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42120	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35616	24/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32894	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42210	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42212	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42209	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA26711	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42208	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA42213	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38314	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38313	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38317	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38319	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA38318	19/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32906	26/01/18	S	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32473	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32474	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32903	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA35642	18/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32902	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC (M) - POWERCON (F)	LA32901	17/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 0.5M											
IEC EXTENSION 0.25M	LA32100	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40299	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40300	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32099	08/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32102	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40296	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40293	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40297	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40292	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32098	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42139	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25487	18/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42140	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42143	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42138	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42137	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42142	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32094	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32097	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42141	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25488	06/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA32093	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA35117	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33427	26/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA15858	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA15856	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33424	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33423	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42136	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33425	02/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42202	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25485	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA42203	29/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
IEC EXTENSION 0.25M	LA25484	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40390	26/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA25483	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA15753	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40391	22/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40301	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40302	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA40305	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33418	26/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33420	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33422	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.25M	LA33419	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32112	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA40306	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA40308	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA26734	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA26713	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA40303	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17787	09/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17786	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32105	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32107	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17785	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32109	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32111	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA32108	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA17778	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42146	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42145	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42144	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42149	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42148	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42147	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA34000	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA25494	24/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA15755	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA25489	12/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA25490	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA15850	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33412	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33411	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33416	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33421	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33417	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33410	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42150	29/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA42111	07/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33409	02/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 0.5M	LA33408	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25832	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA16383	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25498	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 0.75M	LA25497	19/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25224	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24727	09/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA35116	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17794	18/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17796	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17790	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17792	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA16551	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25984	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA16382	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24771	06/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA24768	07/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17674	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25833	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25505	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25165	15/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
IEC EXTENSION 1M	LA25164	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17987	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17988	09/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17797	09/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17798	07/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25222	07/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA25168	26/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 1M	LA17799	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA24926	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA25512	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA26735	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA25836	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA24925	26/01/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA24927	18/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA24928	15/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA33942	06/02/18	S	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA26733	17/01/18	P	S	S	S	S	S	S	S	S
IEC EXTENSION 2M	LA26726	02/02/18	S	S	S	S	S	S	S	S	S
JANDS STAGE CL COMPACT LIGHTING PSU	LA34345	22/01/18	P	S	S	>300 P	S	S	S	S	S
JANDS STAGE CL COMPACT LIGHTING PSU	LA34347	22/01/18	P	S	S	>300 P	S	S	S	S	S
JANDS VISTA S1 CONSOLE	LA31985	22/01/18	P	S	0.09 P	S	<0.05 P	0.14 P	S	S	S
JEM AF-1 DMX FAN	LA22818	17/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA24813	18/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34118	18/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34119	18/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA22817	18/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA37938	18/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA16316	17/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA31522	17/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA37936	18/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA37940	17/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA17507	18/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34243	17/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA34241	18/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM AF-1 DMX FAN	LA37942	17/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA38418	18/01/18	P	S	0.04 P	>300 P	2.01 P	0.35 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA34012	18/01/18	P	S	0.05 P	2.36 P	<0.05 P	0.42 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA34440	18/01/18	P	S	0.05 P	>300 P	2.04 P	0.35 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA31520	18/01/18	P	S	0.05 P	2.53 P	1.94 P	0.37 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA38419	18/01/18	P	S	0.04 P	>300 P	2.03 P	0.35 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA34752	18/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
JEM ZR44 HI MASS SMOKE MACHINE	LA37552	18/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
KINESYS ARRAY 485 8 WAY DATA SPLITTER	LA37279	24/01/18	P	S	0.08 P	S	<0.05 P	<0.10 P	S	S	S
KINESYS ARRAY 485 8 WAY DATA SPLITTER	LA37278	24/01/18	P	S	0.06 P	S	<0.05 P	<0.10 P	S	S	S
KINESYS ARRAY PDES-T POWERLOCK DISTRO	LA21969	25/01/18	P	S	0.03 P	2.88 P	S	S	S	S	S
KINESYS ARRAY PDES-T POWERLOCK DISTRO	LA31214	24/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
KINESYS ARRAY PDES-T POWERLOCK DISTRO	LA34175	24/01/18	P	S	0.02 P	>300 P	S	S	S	S	S
KINESYS K2 USB CONTROL WING	LA22751	25/01/18	P	S	0.08 P	S	<0.05 P	0.65 P	S	S	S
KINESYS SMART 8 MOTOR CONTROLLER	LA21638	24/01/18	P	S	0.04 P	>300 P	S	S	S	S	S
KINESYS SMART 8 MOTOR CONTROLLER	LA21968	24/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
KINESYS SMART8 MOTOR SPIDER 415V FAN OUT	LA24989	25/01/18	P	S	S	S	S	S	S	S	S
KINESYS SMART8 MOTOR SPIDER 415V FAN OUT	LA24991	25/01/18	P	S	S	S	S	S	S	S	S
KINESYS SMART8 MOTOR	LA24722	25/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SPIDER 415V FAN OUT											
KRAMER 1:4 DISTRIBUTION AMP - DVI	LA22414	17/01/18	P	S	0.06 P	S <0.05 P	0.57 P	P	S	S	S
KRAMER 6X6 MATRIX - DVI	LA31303	12/01/18	P	S	0.03 P	S <0.05 P	0.35 P	P	S	S	S
KRAMER 6X6 MATRIX - DVI	LA31304	12/01/18	P	S	0.07 P	S <0.05 P	0.33 P	P	S	S	S
KRAMER 6X6 MATRIX - DVI	LA26357	23/01/18	P	S	0.05 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA39066	17/01/18	P	S	0.01 P	S <0.05 P	0.12 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA26982	23/01/18	P	S	0.05 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA39067	23/01/18	P	S	0.09 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA39089	25/01/18	P	S	0.03 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33398	23/01/18	P	S	0.08 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA35636	23/01/18	P	S	0.05 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33395	24/01/18	P	S	0.03 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA26981	23/01/18	P	S	0.04 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA35634	23/01/18	P	S	0.04 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA39068	23/01/18	P	S	0.04 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33396	17/01/18	P	S	0.01 P	S <0.05 P	0.11 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA33397	23/01/18	P	S	0.04 P	S <0.05 P	<0.10 P	P	S	S	S
LA 300 NETWORK SWITCH (1U RACK MOUNT)	LA35633	23/01/18	P	S	0.04 P	S <0.05 P	<0.10 P	P	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA42582	24/01/18	P	S	0.03 P	S <0.05 P	0.12 P	P	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA39699	17/01/18	P	S	0.03 P	S <0.05 P	0.22 P	P	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA39698	17/01/18	P	S	0.08 P	S <0.05 P	0.22 P	P	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA39697	17/01/18	P	S	0.04 P	S <0.05 P	<0.10 P	P	S	S	S
LA 600 DUAL NETWORK SWITCH (1U RACK MOUNT)	LA39700	17/01/18	P	S	0.03 P	S <0.05 P	0.28 P	P	S	S	S
LIGHTWARE MX 8X8 MATRIX DVI-D PRO SWITCHER	LA39178	23/01/18	P	S	0.06 P	S <0.05 P	<0.10 P	P	S	S	S
LIGHTWARE MX 8X8 MATRIX DVI-D PRO SWITCHER	LA33771	23/01/18	P	S	0.07 P	S <0.05 P	0.25 P	P	S	S	S
LIGHTWARE MX 8X8 MATRIX DVI-D PRO SWITCHER	LA37658	23/01/18	P	S	0.05 P	S <0.05 P	<0.10 P	P	S	S	S
LITE ALTERNATIVE SUNBED (4 X QUICK FIRE TUBE)	LA00854	08/01/18	P	S	0.09 P	29.58 P	0.10 P	<0.10 P	P	S	S
LITE ALTERNATIVE SUNBED (4 X QUICK FIRE TUBE)	LA00855	08/01/18	P	S	0.08 P	75.51 P	0.10 P	<0.10 P	P	S	S
LITE ALTERNATIVE SUNBED (4 X QUICK FIRE TUBE)	LA00857	08/01/18	P	S	0.08 P	34.51 P	0.12 P	<0.10 P	P	S	S
LITE ALTERNATIVE SUNBED (4 X QUICK FIRE TUBE)	LA00856	08/01/18	P	S	0.06 P	89.82 P	0.10 P	<0.10 P	P	S	S
LOOK SOLUTIONS ORKA FOG GENERATOR C/W FAN & CASE	LA31285	19/01/18	P	S	0.08 P	1.50 P	6.00 P	0.53 P	P	S	S
LOOK SOLUTIONS ORKA FOG GENERATOR C/W FAN & CASE	LA31286	19/01/18	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	P	S	S
LOOK SOLUTIONS ORKA FOG GENERATOR C/W FAN & CASE	LA34871	19/01/18	P	S	0.08 P	2.15 P	6.30 P	0.55 P	P	S	S
LOOK SOLUTIONS ORKA FOG GENERATOR C/W FAN & CASE	LA34872	19/01/18	P	S	0.09 P	4.93 P	S	S	P	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA38569	17/01/18	P	S	0.06 P	3.61 P	1.52 P	0.23 P	P	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA41392	17/01/18	P	S	0.06 P	3.07 P	1.52 P	0.25 P	P	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA37746	17/01/18	P	S	0.07 P	17.08 P	1.51 P	0.24 P	P	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA34467	17/01/18	P	S	0.07 P	21.80 P	1.53 P	0.19 P	P	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA37745	17/01/18	P	S	0.08 P	6.94 P	1.55 P	0.25 P	P	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
LOOK SOLUTIONS UNIQUE2 HAZER	LA41391	17/01/18	P	S	0.07 P	7.24 P	1.56 P	0.24 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA41389	17/01/18	P	S	0.06 P	4.91 P	1.51 P	0.23 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA34468	17/01/18	P	S	0.07 P	6.29 P	1.52 P	0.20 P	S	S	S
LOOK SOLUTIONS UNIQUE2 HAZER	LA41390	17/01/18	P	S	0.06 P	3.63 P	1.50 P	0.25 P	S	S	S
LOOK SOLUTIONS VIPERS 650W FOG GENERATOR	LA37806	17/01/18	P	S	0.03 P	13.55 P	0.68 P	0.18 P	S	S	S
LOOK SOLUTIONS VIPERS 650W FOG GENERATOR	LA37354	17/01/18	P	S	0.05 P	55.04 P	0.65 P	0.16 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA03908	07/12/17	P	S	0.06 P	>300 P	0.67 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA24063	07/12/17	P	S	0.06 P	>300 P	0.64 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17312	07/12/17	P	S	0.07 P	>300 P	0.63 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17809	07/12/17	P	S	0.05 P	>300 P	0.67 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA24064	07/12/17	P	S	0.06 P	>300 P	0.65 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17427	07/12/17	P	S	0.07 P	>300 P	0.64 P	<0.10 P	S	S	S
LOWELL OMNI PHOTOFLOOD	LA17426	07/12/17	P	S	0.09 P	>300 P	0.67 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA03914	07/12/17	P	S	0.07 P	>300 P	0.55 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA03918	07/12/17	P	S	0.06 P	>300 P	0.49 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA03913	07/12/17	P	S	0.07 P	>300 P	0.79 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA34287	07/12/17	P	S	0.09 P	>300 P	0.77 P	<0.10 P	S	S	S
LOWELL OMNI TOTA FLOOD	LA24143	07/12/17	P	S	0.05 P	>300 P	0.84 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38052	17/01/18	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38271	17/01/18	P	S	0.06 P	S	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38051	17/01/18	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA37090	17/01/18	P	S	0.04 P	S	<0.05 P	0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38431	16/01/18	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38272	17/01/18	P	S	0.05 P	S	<0.05 P	0.17 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA37091	17/01/18	P	S	0.04 P	S	<0.05 P	0.10 P	S	S	S
LUMINEX ETHERNET TO DMX 8 NODE MKII	LA38273	17/01/18	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA38568	23/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA22463	24/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA22781	24/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA37167	23/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA22497	23/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
LV12 12 WAY MOTOR CONTROLLER	LA41549	23/01/18	P	S	0.04 P	>300 P	S	S	S	S	S
LV6 6 WAY MOTOR CONTROLLER	LA22782	23/01/18	P	S	0.04 P	>300 P	S	S	S	S	S
LV6 6 WAY MOTOR CONTROLLER	LA34513	23/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
MA DMX MERGER	LA31224	12/01/18	P	S	0.09 P	S	<0.05 P	0.39 P	S	S	S
MA DMX MERGER	LA31225	12/01/18	P	S	0.08 P	S	<0.05 P	0.19 P	S	S	S
MA DMX MERGER	LA31226	12/01/18	P	S	0.09 P	S	<0.05 P	0.19 P	S	S	S
MAC 101CT WHITE LED	LA26689	20/12/17	P	S	0.08 P	>300 P	<0.05 P	0.38 P	S	S	S
MAC 101CT WHITE LED	LA26690	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.35 P	S	S	S
MAC 101CT WHITE LED	LA26691	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.39 P	S	S	S
MAC 101CT WHITE LED	LA26696	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.36 P	S	S	S
MAC 101CT WHITE LED	LA26695	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.39 P	S	S	S
MAC 101CT WHITE LED	LA26686	20/12/17	P	S	0.07 P	>300 P	<0.05 P	0.39 P	S	S	S
MAC 101CT WHITE LED	LA26697	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.38 P	S	S	S
MAC 101CT WHITE LED	LA26694	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.40 P	S	S	S
MAC 101CT WHITE LED	LA26687	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.39 P	S	S	S
MAC 101CT WHITE LED	LA26688	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.42 P	S	S	S
MAC 101CT WHITE LED	LA26693	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.40 P	S	S	S
MAC 101CT WHITE LED	LA26692	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.38 P	S	S	S
MAC AURA LED WASH	LA37342	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.51 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC AURA LED WASH	LA37343	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA37341	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34363	16/01/18	P	S	0.05 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA37344	13/12/17	P	S	0.08 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA34841	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34840	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34843	06/12/17	P	S	0.09 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA34842	23/01/18	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34825	16/01/18	P	S	0.03 P	>300 P	0.06 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34824	13/12/17	P	S	0.08 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34826	13/12/17	P	S	0.07 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA37110	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34828	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34819	13/12/17	P	S	0.09 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34818	25/01/18	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34820	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34823	16/01/18	P	S	0.05 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34822	13/12/17	P	S	0.08 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34836	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34835	16/01/18	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34837	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34839	13/12/17	P	S	0.07 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34838	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34831	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34830	13/12/17	P	S	0.08 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA34832	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34834	13/12/17	P	S	0.08 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA34833	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34625	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34624	16/01/18	P	S	0.07 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34627	24/01/18	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34626	14/12/17	P	S	0.09 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34622	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34072	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34469	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34909	11/01/18	P	S	0.02 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34074	13/12/17	P	S	0.09 P	>300 P	<0.05 P	0.39 P	S	S	S
MAC AURA LED WASH	LA34636	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34635	13/12/17	P	S	0.08 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA34638	14/12/17	P	S	0.09 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34637	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34634	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34630	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA34628	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34633	11/01/18	P	S	0.02 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34632	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA34470	11/01/18	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34482	13/12/17	P	S	0.07 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA34483	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA34480	13/12/17	P	S	0.08 P	>300 P	<0.05 P	0.55 P	S	S	S
MAC AURA LED WASH	LA34481	17/01/18	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34484	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34492	13/12/17	P	S	0.09 P	>300 P	<0.05 P	0.55 P	S	S	S
MAC AURA LED WASH	LA34491	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA34485	13/12/17	P	S	0.09 P	>300 P	<0.05 P	0.55 P	S	S	S
MAC AURA LED WASH	LA34486	17/01/18	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34471	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34472	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA31954	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA31950	16/01/18	P	S	0.07 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34473	06/12/17	P	S	0.09 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA34478	06/12/17	P	S	0.09 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34479	11/01/18	P	S	0.06 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA34476	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA34477	17/01/18	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA37347	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA37348	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA37339	17/01/18	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA38040	14/12/17	P	S	0.09 P	>300 P	<0.05 P	0.51 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC AURA LED WASH	LA38041	11/01/18	P	S	0.02 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA37345	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA37338	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC AURA LED WASH	LA37351	13/12/17	P	S	0.08 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA37350	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA37349	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA37337	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC AURA LED WASH	LA34103	16/01/18	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA38039	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC AURA LED WASH	LA37352	13/12/17	P	S	0.09 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA34644	11/01/18	P	S	0.02 P	>300 P	0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34645	16/01/18	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC AURA LED WASH	LA34647	14/12/17	P	S	0.07 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC AURA LED WASH	LA34639	16/01/18	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC AURA LED WASH	LA34640	13/12/17	P	S	0.08 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA34642	17/01/18	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34910	13/12/17	P	S	0.07 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC AURA LED WASH	LA34101	16/01/18	P	S	0.07 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC AURA LED WASH	LA34102	16/01/18	P	S	0.05 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA37353	06/12/17	P	S	0.08 P	>300 P	<0.05 P	0.52 P	S	S	S
MAC AURA LED WASH	LA34096	06/12/17	P	S	0.09 P	>300 P	<0.05 P	0.57 P	S	S	S
MAC AURA LED WASH	LA34099	14/12/17	P	S	0.08 P	>300 P	<0.05 P	0.56 P	S	S	S
MAC AURA LED WASH	LA34100	06/12/17	P	S	0.09 P	>300 P	<0.05 P	0.55 P	S	S	S
MAC AURA XB LED WASH	LA41059	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.47 P	S	S	S
MAC AURA XB LED WASH	LA41060	14/12/17	P	S	0.09 P	>300 P	0.06 P	0.47 P	S	S	S
MAC AURA XB LED WASH	LA41058	13/12/17	P	S	0.06 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41056	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.47 P	S	S	S
MAC AURA XB LED WASH	LA41057	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.47 P	S	S	S
MAC AURA XB LED WASH	LA41052	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.44 P	S	S	S
MAC AURA XB LED WASH	LA41051	14/12/17	P	S	0.09 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41053	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41055	13/12/17	P	S	0.09 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41054	14/12/17	P	S	0.07 P	>300 P	0.05 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41047	13/12/17	P	S	0.06 P	>300 P	0.05 P	0.44 P	S	S	S
MAC AURA XB LED WASH	LA41046	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41048	13/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41050	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.48 P	S	S	S
MAC AURA XB LED WASH	LA41049	13/12/17	P	S	0.06 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41061	13/12/17	P	S	0.07 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41097	13/12/17	P	S	0.06 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41096	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41095	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.47 P	S	S	S
MAC AURA XB LED WASH	LA41098	14/12/17	P	S	0.09 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41101	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41100	14/12/17	P	S	0.07 P	>300 P	0.05 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41099	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41090	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41089	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41088	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41091	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41094	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41093	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41092	14/12/17	P	S	0.07 P	>300 P	0.05 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41111	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41110	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41109	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41112	14/12/17	P	S	0.09 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41115	14/12/17	P	S	0.09 P	>300 P	0.05 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41114	13/12/17	P	S	0.07 P	>300 P	0.06 P	0.44 P	S	S	S
MAC AURA XB LED WASH	LA41113	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41104	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41103	14/12/17	P	S	0.08 P	>300 P	0.12 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41102	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.44 P	S	S	S
MAC AURA XB LED WASH	LA41105	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41108	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41107	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.47 P	S	S	S
MAC AURA XB LED WASH	LA41106	14/12/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC AURA XB LED WASH	LA41087	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41071	13/12/17	P	S	0.06 P	>300 P	0.06 P	0.45 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC AURA XB LED WASH	LA41070	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41069	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41074	14/12/17	P	S	0.06 P	>300 P	0.05 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41073	14/12/17	P	S	0.05 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41072	13/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41068	13/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41064	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.47 P	S	S	S
MAC AURA XB LED WASH	LA41063	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41062	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.44 P	S	S	S
MAC AURA XB LED WASH	LA41067	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41066	14/12/17	P	S	0.09 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41065	13/12/17	P	S	0.07 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41085	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.44 P	S	S	S
MAC AURA XB LED WASH	LA41080	14/12/17	P	S	0.08 P	>300 P	0.06 P	0.47 P	S	S	S
MAC AURA XB LED WASH	LA41079	13/12/17	P	S	0.06 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41083	13/12/17	P	S	0.08 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41082	13/12/17	P	S	0.06 P	>300 P	0.05 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41081	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41075	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.49 P	S	S	S
MAC AURA XB LED WASH	LA41086	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41084	13/12/17	P	S	0.07 P	>300 P	0.05 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41078	14/12/17	P	S	0.07 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AURA XB LED WASH	LA41077	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.45 P	S	S	S
MAC AURA XB LED WASH	LA41076	14/12/17	P	S	0.06 P	>300 P	0.06 P	0.46 P	S	S	S
MAC AXIOM HYBRID	LA38550	11/01/18	P	S	0.05 P	S	0.12 P	0.22 P	S	S	S
MAC QUANTUM LED PROFILE	LA37144	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37141	14/12/17	P	S	0.05 P	>300 P	0.07 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37142	14/12/17	P	S	0.03 P	>300 P	0.07 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37143	14/12/17	P	S	0.06 P	253.50 P	0.07 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37145	14/12/17	P	S	0.04 P	>300 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37148	14/12/17	P	S	0.04 P	>300 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37149	14/12/17	P	S	0.04 P	>300 P	0.07 P	0.37 P	S	S	S
MAC QUANTUM LED PROFILE	LA37146	14/12/17	P	S	0.03 P	>300 P	0.07 P	0.36 P	S	S	S
MAC QUANTUM LED PROFILE	LA37147	14/12/17	P	S	0.04 P	223.40 P	0.08 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37535	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.38 P	S	S	S
MAC QUANTUM LED WASH	LA37540	14/12/17	P	S	0.05 P	159.60 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37539	14/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC QUANTUM LED WASH	LA37537	15/01/18	P	S	0.04 P	>300 P	0.06 P	0.36 P	S	S	S
MAC QUANTUM LED WASH	LA37538	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34879	15/01/18	P	S	0.04 P	126.10 P	<0.05 P	0.39 P	S	S	S
MAC QUANTUM LED WASH	LA34878	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34877	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34882	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34881	14/12/17	P	S	0.07 P	>300 P	<0.05 P	0.38 P	S	S	S
MAC QUANTUM LED WASH	LA34880	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34873	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37123	15/01/18	P	S	0.03 P	>300 P	0.06 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA37121	11/01/18	P	S	0.03 P	64.68 P	0.06 P	0.39 P	S	S	S
MAC QUANTUM LED WASH	LA34876	15/01/18	P	S	0.05 P	>300 P	0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34875	14/12/17	P	S	0.03 P	294.50 P	<0.05 P	0.37 P	S	S	S
MAC QUANTUM LED WASH	LA34874	11/01/18	P	S	0.02 P	58.68 P	<0.05 P	0.38 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21490	14/12/17	P	S	0.06 P	>300 P	0.12 P	0.69 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21491	14/12/17	P	S	0.06 P	>300 P	0.12 P	0.67 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21906	14/12/17	P	S	0.05 P	>300 P	0.13 P	0.62 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21488	14/12/17	P	S	0.06 P	>300 P	0.13 P	0.66 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21489	14/12/17	P	S	0.06 P	>300 P	0.12 P	0.63 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21907	14/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21492	14/12/17	P	S	0.07 P	>300 P	0.13 P	0.68 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21493	15/12/17	P	S	0.09 P	>300 P	0.12 P	0.70 P	S	S	S
MAC TW1 80V 1200W TUNGSTEN WASH	LA21495	14/12/17	P	S	0.09 P	>300 P	0.12 P	0.67 P	S	S	S
MAC TW1 80V 1200W	LA21937	14/12/17	P	S	0.08 P	>300 P	0.11 P	0.66 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
TUNGSTEN WASH MAC TW1 80V 1200W	LA21807	14/12/17	P	S	0.06 P	>300 P	0.14 P	0.65 P	S	S	S
TUNGSTEN WASH MAC VIPER AIRFX	LA37906	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37907	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37361	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER AIRFX	LA37360	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37357	13/12/17	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37358	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37900	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC VIPER AIRFX	LA37356	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37359	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37909	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.39 P	S	S	S
MAC VIPER AIRFX	LA37908	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37911	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37910	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37751	13/12/17	P	S	0.07 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37752	13/12/17	P	S	0.07 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37749	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37750	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37753	13/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER AIRFX	LA37799	13/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER AIRFX	LA37903	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37905	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37904	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37363	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.25 P	S	S	S
MAC VIPER AIRFX	LA37364	13/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER AIRFX	LA37362	13/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER AIRFX	LA37901	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37365	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37747	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.37 P	S	S	S
MAC VIPER AIRFX	LA37748	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37902	13/12/17	P	S	0.07 P	>300 P	<0.05 P	0.35 P	S	S	S
MAC VIPER AIRFX	LA37355	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37198	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37199	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37200	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37195	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37196	13/12/17	P	S	0.03 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER AIRFX	LA37197	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA34901	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA34902	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA34903	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.41 P	S	S	S
MAC VIPER AIRFX	LA37201	12/01/18	P	S	0.04 P	292.60 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37202	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA37203	12/01/18	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA34444	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.31 P	S	S	S
MAC VIPER AIRFX	LA34446	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC VIPER AIRFX	LA34447	12/01/18	P	S	0.05 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC VIPER AIRFX	LA34441	13/12/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA34442	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC VIPER AIRFX	LA34443	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA37192	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA37193	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA37194	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA34448	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER AIRFX	LA34449	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER AIRFX	LA37191	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA38388	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA38389	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA38387	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA34908	12/01/18	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA34906	13/12/17	P	S	0.07 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA38390	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER AIRFX	LA38392	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.53 P	S	S	S
MAC VIPER AIRFX	LA38386	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER AIRFX	LA38391	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER AIRFX	LA34905	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37716	14/12/17	P	S	0.04 P	291.20 P	<0.05 P	0.49 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC VIPER PROFILE	LA37717	15/01/18	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37718	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA34049	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37714	14/12/17	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37715	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37723	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37722	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA41379	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.46 P	S	S	S
MAC VIPER PROFILE	LA31943	13/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAC VIPER PROFILE	LA37720	14/12/17	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37719	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37721	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA31936	14/12/17	P	S	0.07 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA41166	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA41167	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.43 P	S	S	S
MAC VIPER PROFILE	LA41165	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER PROFILE	LA41164	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA37134	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA34043	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34044	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34042	14/12/17	P	S	0.07 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34040	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34041	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER PROFILE	LA31925	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.35 P	S	S	S
MAC VIPER PROFILE	LA34047	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34046	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA31930	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA31933	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.29 P	S	S	S
MAC VIPER PROFILE	LA34048	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC VIPER PROFILE	LA37131	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37133	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA31927	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA34045	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37129	14/12/17	P	S	0.06 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37734	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37725	14/12/17	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37733	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA37731	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37732	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA41373	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.41 P	S	S	S
MAC VIPER PROFILE	LA37735	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA34231	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37724	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA34229	15/01/18	P	S	0.03 P	289.70 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34230	14/12/17	P	S	0.09 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37136	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA41171	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.44 P	S	S	S
MAC VIPER PROFILE	LA37137	14/12/17	P	S	0.06 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37172	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.50 P	S	S	S
MAC VIPER PROFILE	LA37138	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.45 P	S	S	S
MAC VIPER PROFILE	LA41375	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37728	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37730	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA37727	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA41374	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA41170	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA37135	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA41378	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA41371	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.35 P	S	S	S
MAC VIPER PROFILE	LA41376	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34109	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.48 P	S	S	S
MAC VIPER PROFILE	LA34110	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34108	14/12/17	P	S	0.06 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA41377	14/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA34234	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34235	13/12/17	P	S	0.05 P	>300 P	<0.05 P	0.47 P	S	S	S
MAC VIPER PROFILE	LA34232	13/02/18	P	S	0.05 P	>300 P	<0.05 P	0.49 P	S	S	S
MAC VIPER PROFILE	LA34233	14/12/17	P	S	0.04 P	>300 P	<0.05 P	0.51 P	S	S	S
MAC VIPER PROFILE	LA41169	13/12/17	P	S	0.04 P	>300 P	<0.05 P	0.47 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAC VIPER PROFILE	LA41168	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.42 P	S	S	S
MAC VIPER PROFILE	LA41372	13/12/17	P	S	0.06 P	>300 P	<0.05 P	0.40 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25715	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25714	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25718	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25717	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25716	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25713	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25724	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25725	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25726	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25723	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25712	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25711	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25722	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25719	02/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25671	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25670	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25673	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25681	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25680	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25679	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25674	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25677	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25678	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25721	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25720	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25675	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25676	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25727	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25743	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25742	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25710	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25702	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25703	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25696	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25740	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25693	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25741	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25695	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25694	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25707	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25706	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25708	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25698	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25697	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25699	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25704	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25709	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25701	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25700	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25705	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25692	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25683	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25732	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25731	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25730	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25738	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25736	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25735	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25734	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25737	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25733	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25684	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25689	03/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25688	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25690	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25728	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25691	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25729	03/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25685	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25739	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25682	02/01/18	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ ELECTRO KABUKI MECHANISM	LA25686	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ KABUKI 3 WAY SPLITTER BOX	LA25745	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MAGNET-SCHULTZ KABUKI CONTROLLER	LA24706	03/01/18	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ KABUKI CONTROLLER	LA34343	02/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ KABUKI CONTROLLER	LA25970	02/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAGNET-SCHULTZ KABUKI CONTROLLER	LA34332	03/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37105	08/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA31666	08/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37101	08/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37102	08/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37106	08/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37107	08/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37108	08/01/18	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37104	08/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA37103	08/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MAINTAINED EMERGENCY EXIT SIGN	LA31665	08/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26534	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26865	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.28 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26866	19/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26849	19/12/17	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26846	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.29 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26847	19/12/17	P	S	0.04 P	197.20 P	<0.05 P	0.28 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26387	19/12/17	P	S	0.06 P	>300 P	<0.05 P	0.31 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26848	19/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26923	19/12/17	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA24810	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26554	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.28 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26550	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26555	19/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26924	19/12/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26551	19/12/17	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26535	19/12/17	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26536	19/12/17	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26552	19/12/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA37551	19/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26553	19/12/17	P	S	0.07 P	>300 P	<0.05 P	0.30 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA26537	19/12/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN ATOMIC 3000 DMX STROBE	LA24166	19/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38239	19/12/17	P	S	0.06 P	>300 P	<0.05 P	0.16 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MARTIN ATOMIC 3000 LED STROBE	LA38240	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38237	19/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38238	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38244	19/12/17	P	S	0.05 P	112.10 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38245	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38243	19/12/17	P	S	0.06 P	>300 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38241	19/12/17	P	S	0.05 P	52.96 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38242	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38234	19/12/17	P	S	0.06 P	>300 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38233	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38235	19/12/17	P	S	0.06 P	197.50 P	<0.05 P	0.16 P	S	S	S
MARTIN ATOMIC 3000 LED STROBE	LA38236	19/12/17	P	S	0.05 P	69.76 P	<0.05 P	0.16 P	S	S	S
MARTIN IP66 PSU 240W	LA41386	17/01/18	P	S	0.07 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41281	17/01/18	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41387	17/01/18	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41287	17/01/18	P	S	0.06 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41284	17/01/18	P	S	0.08 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41286	17/01/18	P	S	0.07 P	>300 P	<0.05 P	0.26 P	S	S	S
MARTIN IP66 PSU 240W	LA41282	17/01/18	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41283	17/01/18	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41292	17/01/18	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41388	17/01/18	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41385	17/01/18	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41280	17/01/18	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
MARTIN IP66 PSU 240W	LA41279	17/01/18	P	S	0.08 P	>300 P	<0.05 P	0.27 P	S	S	S
MIRROR BALL ROTATOR	LA02950	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA37170	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA00885	18/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA37169	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA38489	21/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA24940	20/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
MIRROR BALL ROTATOR	LA24825	20/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17922	06/12/17	P	S	0.02 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17923	06/12/17	P	S	0.04 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17921	06/12/17	P	S	0.03 P	>300 P	1.24 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17918	06/12/17	P	S	0.09 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA17919	06/12/17	P	S	0.03 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34025	06/12/17	P	S	0.02 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34026	06/12/17	P	S	0.03 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34024	06/12/17	P	S	0.02 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34022	15/12/17	P	S	0.01 P	>300 P	1.32 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34023	06/12/17	P	S	0.02 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34027	06/12/17	P	S	0.02 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34031	06/12/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34032	06/12/17	P	S	0.02 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34030	06/12/17	P	S	0.02 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34028	15/12/17	P	S	0.01 P	>300 P	1.31 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34029	06/12/17	P	S	0.02 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34014	06/12/17	P	S	0.02 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34015	06/12/17	P	S	0.02 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA26892	06/12/17	P	S	0.03 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA26890	06/12/17	P	S	0.02 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA26891	06/12/17	P	S	0.02 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34016	06/12/17	P	S	0.03 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34020	15/12/17	P	S	0.01 P	>300 P	1.31 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34021	06/12/17	P	S	0.02 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34019	06/12/17	P	S	0.02 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34017	06/12/17	P	S	0.02 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34018	06/12/17	P	S	0.02 P	>300 P	1.28 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
MOLEFAY 2 LITE THOMAS	LA34033	06/12/17	P	S	0.02 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31887	06/12/17	P	S	0.03 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31886	06/12/17	P	S	0.02 P	>300 P	1.25 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31888	06/12/17	P	S	0.04 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31890	06/12/17	P	S	0.03 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31889	06/12/17	P	S	0.03 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31885	06/12/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31849	06/12/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31657	06/12/17	P	S	0.02 P	>300 P	1.25 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31850	06/12/17	P	S	0.02 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31884	06/12/17	P	S	0.03 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31851	06/12/17	P	S	0.02 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34036	06/12/17	P	S	0.02 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34037	06/12/17	P	S	0.02 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34035	06/12/17	P	S	0.02 P	>300 P	1.27 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34034	06/12/17	P	S	0.02 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31895	15/12/17	P	S	0.02 P	>300 P	1.31 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34038	06/12/17	P	S	0.02 P	>300 P	1.25 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31892	06/12/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31891	15/12/17	P	S	0.01 P	>300 P	1.31 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31893	15/12/17	P	S	0.02 P	>300 P	1.30 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA34039	06/12/17	P	S	0.04 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 2 LITE THOMAS	LA31894	06/12/17	P	S	0.03 P	>300 P	1.26 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26821	06/12/17	P	S	0.05 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26827	06/12/17	P	S	0.03 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26820	06/12/17	P	S	0.04 P	>300 P	2.52 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26818	06/12/17	P	S	0.04 P	>300 P	2.42 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26819	06/12/17	P	S	0.05 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26823	06/12/17	P	S	0.04 P	>300 P	2.53 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26822	06/12/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26824	06/12/17	P	S	0.04 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26826	06/12/17	P	S	0.05 P	>300 P	2.58 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26825	06/12/17	P	S	0.04 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26817	06/12/17	P	S	0.02 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26809	06/12/17	P	S	0.04 P	>300 P	2.60 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26810	06/12/17	P	S	0.04 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26808	06/12/17	P	S	0.05 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26806	06/12/17	P	S	0.02 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26807	06/12/17	P	S	0.04 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26815	06/12/17	P	S	0.04 P	>300 P	2.55 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26816	06/12/17	P	S	0.04 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26813	06/12/17	P	S	0.03 P	>300 P	2.47 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26811	06/12/17	P	S	0.05 P	>300 P	2.52 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA26812	06/12/17	P	S	0.04 P	>300 P	2.47 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA34339	06/12/17	P	S	0.02 P	>300 P	2.43 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24650	06/12/17	P	S	0.02 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24671	06/12/17	P	S	0.02 P	>300 P	2.44 P	<0.10 P	S	S	S
MOLEFAY 4 LITE LINEAR THOMAS	LA24670	06/12/17	P	S	0.04 P	>300 P	2.58 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24651	06/12/17	P	S	0.04 P	>300 P	2.44 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24654	06/12/17	P	S	0.03 P	>300 P	1.28 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24655	06/12/17	P	S	0.04 P	>300 P	2.43 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24652	06/12/17	P	S	0.04 P	>300 P	2.52 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24653	06/12/17	P	S	0.02 P	>300 P	2.46 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24647	06/12/17	P	S	0.03 P	>300 P	2.47 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA26834	06/12/17	P	S	0.04 P	>300 P	2.46 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24649	06/12/17	P	S	0.04 P	>300 P	2.58 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24648	06/12/17	P	S	0.04 P	>300 P	2.47 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA26833	06/12/17	P	S	0.04 P	>300 P	2.44 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24673	06/12/17	P	S	0.04 P	>300 P	2.42 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24672	06/12/17	P	S	0.02 P	>300 P	2.47 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA26828	06/12/17	P	S	0.04 P	>300 P	2.50 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA26829	06/12/17	P	S	0.05 P	>300 P	2.43 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24669	06/12/17	P	S	0.04 P	>300 P	2.60 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24659	06/12/17	P	S	0.04 P	>300 P	2.51 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24658	06/12/17	P	S	0.03 P	>300 P	2.44 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24661	06/12/17	P	S	0.02 P	>300 P	2.53 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24660	06/12/17	P	S	0.04 P	>300 P	2.53 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24657	06/12/17	P	S	0.02 P	>300 P	2.48 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24656	06/12/17	P	S	0.03 P	>300 P	2.51 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA26832	06/12/17	P	S	0.02 P	>300 P	2.44 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA26830	06/12/17	P	S	0.04 P	>300 P	2.43 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA26831	06/12/17	P	S	0.04 P	>300 P	2.50 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24662	06/12/17	P	S	0.03 P	>300 P	2.47 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24666	06/12/17	P	S	0.03 P	>300 P	2.45 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24667	06/12/17	P	S	0.02 P	>300 P	1.30 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24665	06/12/17	P	S	0.04 P	>300 P	2.49 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24664	06/12/17	P	S	0.04 P	>300 P	2.54 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24646	06/12/17	P	S	0.04 P	>300 P	2.45 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24668	06/12/17	P	S	0.04 P	>300 P	1.29 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA26835	06/12/17	P	S	0.04 P	>300 P	2.52 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE LINEAR	LA24663	06/12/17	P	S	0.02 P	>300 P	2.43 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE SQUARE	LA22771	07/12/17	P	S	0.02 P	>300 P	2.52 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE SQUARE	LA21347	07/12/17	P	S	0.03 P	>300 P	2.49 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE SQUARE	LA22865	07/12/17	P	S	0.02 P	>300 P	2.52 P	<0.10 P	S	S	S
THOMAS											
MOLEFAY 4 LITE SQUARE	LA21345	07/12/17	P	S	0.03 P	>300 P	2.61 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
THOMAS											
MOLEFAY 4 LITE SQUARE THOMAS	LA21099	07/12/17	P	S	0.02 P	>300 P	2.61 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21883	07/12/17	P	S	0.04 P	>300 P	2.60 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22864	07/12/17	P	S	0.02 P	>300 P	2.59 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21888	07/12/17	P	S	0.02 P	>300 P	2.57 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21348	07/12/17	P	S	0.03 P	>300 P	2.58 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22765	07/12/17	P	S	0.04 P	>300 P	2.59 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21886	07/12/17	P	S	0.04 P	>300 P	2.59 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21349	07/12/17	P	S	0.02 P	>300 P	2.59 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21887	07/12/17	P	S	0.03 P	>300 P	2.57 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34868	07/12/17	P	S	0.04 P	>300 P	2.54 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22767	07/12/17	P	S	0.04 P	>300 P	2.51 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22766	07/12/17	P	S	0.04 P	>300 P	2.54 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22224	07/12/17	P	S	0.04 P	>300 P	2.55 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22770	07/12/17	P	S	0.02 P	>300 P	2.60 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22769	07/12/17	P	S	0.02 P	>300 P	2.61 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA22768	07/12/17	P	S	0.03 P	>300 P	2.60 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34865	07/12/17	P	S	0.04 P	>300 P	2.57 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34864	07/12/17	P	S	0.02 P	>300 P	2.59 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34863	07/12/17	P	S	0.02 P	>300 P	2.55 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34340	07/12/17	P	S	0.02 P	>300 P	2.57 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34341	07/12/17	P	S	0.02 P	>300 P	2.57 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34866	07/12/17	P	S	0.03 P	>300 P	1.29 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21884	07/12/17	P	S	0.02 P	>300 P	2.59 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34867	07/12/17	P	S	0.02 P	>300 P	2.51 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA21885	07/12/17	P	S	0.03 P	>300 P	2.58 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34862	07/12/17	P	S	0.03 P	>300 P	2.58 P	<0.10 P	S	S	S
MOLEFAY 4 LITE SQUARE THOMAS	LA34861	07/12/17	P	S	0.02 P	>300 P	2.59 P	<0.10 P	S	S	S
MOLEFAY 8 LITE THOMAS	LA26969	03/01/18	P	S	0.03 P	>300 P	2.45 P	<0.10 P	S	S	S
MOLEFAY 8 LITE THOMAS	LA26970	03/01/18	P	S	0.03 P	>300 P	2.41 P	<0.10 P	S	S	S
MOLEFAY 8 LITE THOMAS	LA22241	03/01/18	P	S	0.03 P	>300 P	2.41 P	<0.10 P	S	S	S
MOLEFAY 8 LITE THOMAS	LA22239	03/01/18	P	S	0.03 P	>300 P	2.41 P	<0.10 P	S	S	S
MOLEFAY 8 LITE THOMAS	LA24365	03/01/18	P	S	0.04 P	>300 P	2.47 P	<0.10 P	S	S	S
MOLEFAY 8 LITE THOMAS	LA24364	03/01/18	P	S	0.03 P	>300 P	2.41 P	<0.10 P	S	S	S
MOLEFAY 8 LITE THOMAS	LA22240	03/01/18	P	S	0.03 P	>300 P	2.42 P	<0.10 P	S	S	S
MOLEFAY 8 LITE THOMAS	LA22238	03/01/18	P	S	0.03 P	>300 P	2.41 P	<0.10 P	S	S	S
MOTOROLA GP340 6 WAY CHARGER	LA37630	20/12/17	P	S	S	>300 P	S	S	S	S	S
MTP FIBRE BREAKOUT BOX - FOH	LA39672	23/01/18	P	S	0.09 P	S	<0.05 P	<0.10 P	S	S	S
MTP FIBRE BREAKOUT BOX - STAGE	LA33474	23/01/18	P	S	0.08 P	S	<0.05 P	<0.10 P	S	S	S
MTP FIBRE MULTICORE 150M	LA42636	08/12/17	P	S	S	S	S	S	S	S	S
MTP FIBRE MULTICORE 150M	LA39487	08/12/17	P	S	S	S	S	S	S	S	S
MTP FIBRE MULTICORE 150M	LA39488	05/02/18	S	S	S	S	S	S	S	S	S
MTP FIBRE MULTICORE 150M	LA39468	08/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
NEUTRIK IN-LINE POWERCON BARREL	LA26934	02/02/18	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA38796	02/02/18	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA38797	26/01/18	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA17752	02/02/18	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA38794	02/02/18	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA24734	02/02/18	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA24735	02/02/18	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA24733	02/02/18	S	S	S	S	S	S	S	S	S
NEUTRIK IN-LINE POWERCON BARREL	LA17754	02/02/18	S	S	S	S	S	S	S	S	S
OUTBOARD 12 WAY GAUZE CONTROLLER	LA20495	23/01/18	P	S	0.03 P	>300 P	S	S	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25140	20/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25138	20/12/17	P	S	0.08 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25135	20/12/17	P	S	0.07 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25141	20/12/17	P	S	0.09 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25146	20/12/17	P	S	0.07 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25144	20/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 BLACK BIRDIE 240V IEC	LA25142	20/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37080	20/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37079	20/12/17	P	S	0.08 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37078	20/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37085	20/12/17	P	S	0.09 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37082	20/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37081	20/12/17	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37077	20/12/17	P	S	0.07 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37073	20/12/17	P	S	0.08 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37072	20/12/17	P	S	0.08 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37071	20/12/17	P	S	0.08 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37076	20/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37075	20/12/17	P	S	0.08 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37074	20/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37087	20/12/17	P	S	0.09 P	>300 P	0.05 P	<0.10 P	S	S	S
PAR 16 SILVER BIRDIE 240V IEC	LA37089	20/12/17	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37033	07/12/17	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37028	07/12/17	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34974	07/12/17	P	S	0.04 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37030	07/12/17	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37036	07/12/17	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37035	07/12/17	P	S	0.03 P	>300 P	0.29 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA37032	07/12/17	P	S	0.03 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34969	07/12/17	P	S	0.06 P	>300 P	0.29 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34970	07/12/17	P	S	0.06 P	>300 P	0.27 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PARCAN											
PAR 56 SHORT NOSE BLACK PARCAN	LA37034	07/12/17	P	S	0.03 P	>300 P	0.29 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34968	07/12/17	P	S	0.07 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34972	07/12/17	P	S	0.07 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34973	07/12/17	P	S	0.06 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 56 SHORT NOSE BLACK PARCAN	LA34971	07/12/17	P	S	0.06 P	>300 P	0.28 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA17531	10/01/18	P	S	0.07 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA20636	10/01/18	P	S	0.09 P	>300 P	1.05 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA20638	09/01/18	P	S	0.09 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA20637	09/01/18	P	S	0.09 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA24302	09/01/18	P	S	0.09 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA15293	09/01/18	P	S	0.09 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA24300	10/01/18	P	S	0.09 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA17532	09/01/18	P	S	0.09 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA24301	09/01/18	P	S	0.09 P	>300 P	1.05 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA20635	09/01/18	P	S	0.09 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA24303	09/01/18	P	S	0.09 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 4 WAY BAR	LA15188	09/01/18	P	S	0.09 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA15295	10/01/18	P	S	0.09 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16008	10/01/18	P	S	0.09 P	>300 P	1.01 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16005	10/01/18	P	S	0.08 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16006	10/01/18	P	S	0.07 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA15296	10/01/18	P	S	0.09 P	>300 P	1.00 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16007	12/02/18	P	S	0.09 P	>300 P	1.06 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA17301	10/01/18	P	S	0.09 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16727	10/01/18	P	S	0.09 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 6 WAY BAR	LA16597	10/01/18	P	S	0.09 P	>300 P	1.01 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26488	07/12/17	P	S	0.05 P	>300 P	1.07 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26489	07/12/17	P	S	0.06 P	>300 P	1.10 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26487	07/12/17	P	S	0.09 P	>300 P	0.55 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26486	07/12/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26495	07/12/17	P	S	0.07 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26493	07/12/17	P	S	0.07 P	>300 P	1.09 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26492	07/12/17	P	S	0.05 P	>300 P	1.07 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26494	07/12/17	P	S	0.06 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26490	09/01/18	P	S	0.09 P	>300 P	1.19 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26491	07/12/17	P	S	0.06 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26484	09/01/18	P	S	0.07 P	>300 P	1.30 P	<0.10 P	S	S	S
PAR 64 BLACK FLOORCAN	LA26485	07/12/17	P	S	0.06 P	>300 P	0.53 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31643	09/01/18	P	S	0.04 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA21087	10/01/18	P	S	0.03 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31645	09/01/18	P	S	0.04 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31646	09/01/18	P	S	0.05 P	>300 P	1.02 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31648	09/01/18	P	S	0.04 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA21090	09/01/18	P	S	0.04 P	>300 P	1.01 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA21097	09/01/18	P	S	0.04 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA21530	09/01/18	P	S	0.06 P	>300 P	1.03 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31642	10/01/18	P	S	0.02 P	>300 P	1.04 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31641	10/01/18	P	S	0.02 P	>300 P	1.05 P	<0.10 P	S	S	S
PAR 64 INDIVIDUAL BLACK PARCAN	LA31650	09/01/18	P	S	0.04 P	>300 P	1.06 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21164	04/01/18	P	S	0.02 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21165	04/01/18	P	S	0.02 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21166	06/12/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21177	08/12/17	P	S	0.05 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21168	06/12/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PAR 64 SILVER FLOORCAN	LA21176	06/12/17	P	S	0.03 P	>300 P	0.50 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21175	04/01/18	P	S	0.02 P	>300 P	0.50 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21174	08/12/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21169	04/01/18	P	S	0.03 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21170	04/01/18	P	S	0.02 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA16792	08/12/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22860	08/12/17	P	S	0.03 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22861	08/12/17	P	S	0.03 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22857	06/12/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22858	04/01/18	P	S	0.02 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22859	08/12/17	P	S	0.04 P	>300 P	0.52 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA21178	08/12/17	P	S	0.05 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22262	04/01/18	P	S	0.02 P	>300 P	0.51 P	<0.10 P	S	S	S
PAR 64 SILVER FLOORCAN	LA22261	04/01/18	P	S	0.02 P	>300 P	0.50 P	<0.10 P	S	S	S
PINSPOT 4 WAY BAR C/W 16A IN AND OUT.	LA22854	04/01/18	P	S	0.08 P	>300 P	0.09 P	<0.10 P	S	S	S
PINSPOT 4 WAY BAR C/W 16A IN AND OUT.	LA22855	04/01/18	P	S	0.07 P	>300 P	0.09 P	<0.10 P	S	S	S
PINSPOT 5 WAY BAR C/W 16A IN AND OUT.	LA02993	04/01/18	P	S	0.04 P	>300 P	0.23 P	<0.10 P	S	S	S
PINSPOT 5 WAY BAR C/W 16A IN AND OUT.	LA02991	04/01/18	P	S	0.03 P	>300 P	0.29 P	<0.10 P	S	S	S
PINSPOT 5 WAY BAR C/W 16A IN AND OUT.	LA01787	04/01/18	P	S	0.04 P	>300 P	0.28 P	<0.10 P	S	S	S
PINSPOT 5 WAY BAR C/W 16A IN AND OUT.	LA01396	08/01/18	P	S	0.06 P	>300 P	0.30 P	<0.10 P	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30375	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA26341	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30378	30/01/18	S	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30386	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA26094	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA26092	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30382	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA35096	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON - 16A 1PH ADAPTOR 0.5M	LA30380	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA32904	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA32900	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA35102	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA35103	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA40320	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON (M) - IEC (F) ADAPTOR 0.5M	LA35132	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34855	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34935	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34939	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34940	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34936	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34938	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34858	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34857	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34860	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON 2 WAY SPLITTER	LA34859	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA42157	06/02/18	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38267	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38266	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA42207	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA42206	02/02/18	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38265	19/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRS 0.3M	LA38270	08/02/18	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38268	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRS 0.3M	LA38261	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40288	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40289	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40290	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40975	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40969	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40402	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40976	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40401	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40416	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40417	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40418	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40413	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40414	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40415	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40420	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40971	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40968	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40967	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40974	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40973	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40972	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40412	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40405	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40406	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40407	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40970	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40403	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40404	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40409	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40410	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40411	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - 16A 1PH ADAPTOR	LA40408	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40985	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40979	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40980	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) -	LA40984	22/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON (F) ADAPTOR POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40981	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40982	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40983	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42481	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42480	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42479	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42496	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42484	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42483	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42482	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42476	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42495	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42424	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42477	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42422	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42423	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42478	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42417	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42418	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42420	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42494	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42416	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42471	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42493	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42475	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42486	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42485	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42474	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42421	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42472	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42473	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42276	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42275	23/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42277	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42279	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42278	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) -	LA42274	22/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON (F) ADAPTOR POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42491	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42271	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42492	06/02/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42273	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42272	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42280	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42285	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42463	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42286	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42288	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42287	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42284	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42461	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42281	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42462	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42283	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42282	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42454	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42455	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42453	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42451	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42452	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42460	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42487	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42488	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42459	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42457	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42458	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42505	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42497	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42498	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42270	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42490	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42489	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42499	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42503	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) -	LA42504	22/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON (F) ADAPTOR POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42502	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42500	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42501	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42438	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42439	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42437	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42435	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42436	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42440	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42444	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42445	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42443	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42441	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42442	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42434	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42426	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42427	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42425	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40978	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA40977	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42428	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42432	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42433	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42431	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42429	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42430	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42464	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42411	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42465	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42467	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42466	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42410	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42406	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42289	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42407	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON (F) ADAPTOR	LA42409	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) -	LA42408	22/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42412	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42449	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42450	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42448	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42446	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42447	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42470	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42414	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42413	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42415	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42469	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA42468	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON (F) ADAPTOR											
POWERCON TRUE (M) -	LA40623	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40622	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40624	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40626	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40625	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40618	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40617	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40619	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40621	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40620	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40633	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40632	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40634	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40636	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40635	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40628	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40627	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40629	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40631	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40630	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40603	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40602	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40604	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40606	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) -	LA40605	22/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40598	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40597	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40599	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40601	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40600	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40613	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40612	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40614	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40616	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40615	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40608	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40607	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40609	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40611	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40610	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40663	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40662	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40664	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40666	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40665	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40658	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40657	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40659	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40661	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40660	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40673	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40672	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40674	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40676	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40675	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40668	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40667	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40669	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40671	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40670	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40643	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40642	22/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON ADAPTOR (F)											
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40644	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40646	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40645	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40638	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40637	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40639	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40641	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40640	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40653	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40652	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40654	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40656	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40655	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40648	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40647	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40649	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40651	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE (M) - POWERCON ADAPTOR (F)	LA40650	22/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34763	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34762	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34764	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34767	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34766	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34761	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA42176	30/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA42180	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34758	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34760	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34759	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34768	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34771	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34774	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34769	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE 2 WAY SPLITTER Y-CORD	LA34770	19/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40837	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35587	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35586	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA39087	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35590	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE TRS 10FT	LA32618	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35588	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35589	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32621	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35584	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32620	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32622	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32623	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35585	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35583	07/02/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32619	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32421	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32420	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35591	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA35592	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32419	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32416	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32415	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32418	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32417	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32625	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32627	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32617	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32624	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32628	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32631	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32632	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32629	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA32630	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40584	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40585	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40586	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40581	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40582	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40583	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40587	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40863	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40862	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40861	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40588	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40589	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40590	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40571	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40572	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40573	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40866	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40865	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40864	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40574	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40578	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40579	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40580	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40575	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40576	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40577	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40846	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40845	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40844	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40849	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40848	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40847	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40840	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40839	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40838	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40843	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40842	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40841	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40851	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40854	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE TRS 10FT	LA40858	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40855	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40856	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40857	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40853	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40859	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40860	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 10FT	LA40852	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36339	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36340	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36341	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36333	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36334	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36331	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36332	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36337	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36338	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36335	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36336	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36346	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36345	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36350	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36348	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36349	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36347	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36344	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36352	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36353	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36354	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36343	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36342	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36351	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40596	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40594	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36313	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36314	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40591	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36315	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40593	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA40592	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36307	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36308	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36305	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36306	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36311	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36312	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36309	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36310	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36316	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36324	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36325	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36323	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36321	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36322	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36329	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36330	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36328	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36326	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36327	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36319	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36318	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36317	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 20FT	LA36320	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40834	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40835	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40833	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40831	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40832	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40548	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE TRS 5FT	LA40549	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40550	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40836	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40552	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40551	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40830	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40547	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40829	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40828	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40826	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40827	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40825	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40821	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40820	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40822	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40824	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40823	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40553	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40567	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32399	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40566	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32400	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40565	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40570	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32402	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32401	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32403	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40569	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40568	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40564	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40557	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40558	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40556	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40554	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40555	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40559	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40562	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40563	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40561	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA33783	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40560	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40819	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40541	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40542	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40543	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35628	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35626	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35625	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40544	17/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40789	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40790	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40791	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40545	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40546	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40788	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35629	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32412	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32411	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32413	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32414	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA35630	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32410	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32406	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32405	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32404	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32409	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32408	26/01/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA32407	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40809	17/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERCON TRUE TRS 5FT	LA40810	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40811	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40806	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40807	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40808	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40812	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40816	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40817	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40818	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40813	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40814	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40815	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40795	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40796	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40797	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40792	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40793	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40794	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40798	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40802	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40803	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40805	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40799	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40800	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE TRS 5FT	LA40801	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39931	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39932	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39933	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39927	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39929	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39930	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39689	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39690	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39691	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39934	25/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39935	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39936	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39926	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39687	18/01/18	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39688	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39918	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39917	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39916	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39915	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39923	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39924	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39925	06/02/18	S	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5 COMBI CABLE 10FT	LA39919	14/12/17	P	S	S	S	S	S	S	S	S
POWERCON TRUE XLR5	LA39921	14/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39922	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39953	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39954	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39955	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39950	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39951	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39952	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39696	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39695	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39694	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39957	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39958	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39959	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39949	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39938	08/02/18	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39939	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39940	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39692	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39693	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39937	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39945	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39946	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39948	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39941	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39942	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA39943	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40914	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40912	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40916	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40915	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40909	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40908	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40911	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40910	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40520	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40515	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40516	14/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40512	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40513	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40471	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40519	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40518	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40472	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40907	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40888	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40889	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40896	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40887	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40894	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40895	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40892	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40893	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40897	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40903	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40902	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40906	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40904	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40899	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40898	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40901	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40900	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40488	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40487	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40490	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40489	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40484	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40483	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40486	17/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40485	08/02/18	S	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40491	17/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40497	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40496	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40500	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT											
POWERCON TRUE XLR5	LA40499	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40493	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40492	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40495	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40494	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40482	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40503	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40504	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40473	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40502	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40509	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40510	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40505	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40506	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40474	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40479	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40478	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40481	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40480	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40476	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40475	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40477	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40501	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 10FT POWERCON TRUE XLR5	LA40527	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40526	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40530	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40528	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40525	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40522	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40521	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40524	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40523	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40531	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40538	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40537	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40540	17/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40539	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT POWERCON TRUE XLR5	LA40536	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40533	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40532	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40535	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40534	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 20FT											
POWERCON TRUE XLR5	LA40435	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40434	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40437	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40436	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40430	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40429	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40433	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40432	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40445	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40443	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40447	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40446	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40440	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40439	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40442	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40441	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA35981	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40867	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA30644	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA35993	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40871	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40872	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40869	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40870	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40426	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40425	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40428	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40427	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40421	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA30647	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40423	17/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40422	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40467	14/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40466	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40469	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40468	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40463	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40462	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40465	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40464	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA33174	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA39677	17/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA33149	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA33169	08/02/18	S	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA39680	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA39681	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA39678	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA39679	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40453	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40452	17/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA39684	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA39685	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40449	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40448	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40451	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40450	17/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40459	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40458	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40461	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40460	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40455	17/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40454	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40457	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40456	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40881	22/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40886	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40879	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40880	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40885	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40882	14/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA30417	25/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40884	17/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40883	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40874	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40876	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40875	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40878	14/12/17	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON TRUE XLR5	LA40877	18/01/18	P	S	S	S	S	S	S	S	S
COMBI CABLE 5FT											
POWERCON XLR3 COMBI	LA30406	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30405	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30407	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30412	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30413	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30401	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30408	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30409	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30411	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30404	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30399	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30398	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30402	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30400	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30395	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30394	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30397	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30396	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30403	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR3 COMBI	LA30736	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30737	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30738	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30735	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30733	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30734	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30732	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30739	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30745	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30744	15/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 15FT											
POWERCON XLR3 COMBI	LA30747	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30746	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30741	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30740	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30743	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30742	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30731	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30728	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30729	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR3 COMBI	LA30730	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA42615	08/02/18	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA39081	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33857	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33862	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA42618	08/02/18	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA42812	06/02/18	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33858	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33860	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33856	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33861	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33038	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33859	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33032	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33845	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33844	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33847	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33846	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33036	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33033	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33031	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33035	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33034	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33854	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33853	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33037	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33855	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33852	18/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 10FT											
POWERCON XLR5 COMBI	LA33849	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33848	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33851	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33850	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33039	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33164	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33041	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33040	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33872	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33871	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33870	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33869	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33865	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30660	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30661	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33868	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33867	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33866	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30658	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33047	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33046	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33045	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33050	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33049	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33048	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33044	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30654	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30655	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30657	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33043	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33042	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30653	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33877	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33878	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33876	19/01/18	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33874	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33875	18/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 10FT											
POWERCON XLR5 COMBI	LA33882	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33883	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33881	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33879	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33880	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA30662	06/02/18	S	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33864	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33863	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33873	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 10FT											
POWERCON XLR5 COMBI	LA33191	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA42200	06/02/18	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33193	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33192	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33189	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA25282	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33190	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33194	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33195	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33179	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33178	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33184	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33183	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33182	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33181	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33185	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33187	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33188	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33177	08/02/18	S	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33176	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 15FT											
POWERCON XLR5 COMBI	LA33055	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33054	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33051	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33052	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33053	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33057	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33165	06/02/18	S	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33901	18/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 20FT											
POWERCON XLR5 COMBI	LA33899	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33058	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33283	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33900	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33895	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33896	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33893	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33894	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33898	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33904	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33903	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA38988	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33905	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33886	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33887	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33884	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33885	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33888	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33891	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33892	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33889	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33890	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25290	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25405	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25406	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25285	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25287	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25289	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25407	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA33902	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 20FT											
POWERCON XLR5 COMBI	LA25230	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 3FT											
POWERCON XLR5 COMBI	LA25229	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 3FT											
POWERCON XLR5 COMBI	LA35991	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35989	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35990	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35996	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35995	18/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 5FT											
POWERCON XLR5 COMBI	LA35997	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35992	14/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35994	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35983	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35984	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA26353	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35980	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35987	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35988	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35985	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35986	17/01/18	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA25249	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33030	14/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA25242	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA25236	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33006	19/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33780	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA38959	14/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA38960	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA38804	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA38803	18/01/18	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35998	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA35999	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA25247	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA25245	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA38802	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA38801	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40207	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40206	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40204	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40210	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40209	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40208	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30433	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30431	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30430	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40203	18/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 5FT											
POWERCON XLR5 COMBI	LA30435	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30434	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30646	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30645	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30643	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30652	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30650	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30649	09/02/18	S	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40213	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40212	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40211	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40216	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40215	18/01/18	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40214	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30429	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40197	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40196	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40195	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40200	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40199	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40198	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40189	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40188	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40187	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40194	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40193	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40190	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30424	17/01/18	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30423	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30422	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30428	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30427	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30425	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30415	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40202	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA40201	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30420	18/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
CABLE 5FT											
POWERCON XLR5 COMBI	LA30419	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA30416	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33146	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33147	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33148	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33145	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33142	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33143	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33144	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33150	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33175	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33173	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33170	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA24520	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33166	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33167	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33168	18/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERCON XLR5 COMBI	LA33141	15/12/17	P	S	S	S	S	S	S	S	S
CABLE 5FT											
POWERLOCK - 125A 3PH	LA30795	05/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 125A 3PH	LA22671	05/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 125A 3PH	LA26974	05/01/18	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 125A 3PH	LA30796	30/01/18	S	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 63A 3PH	LA22247	21/12/17	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 63A 3PH	LA22243	13/12/17	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 63A 3PH	LA22244	12/12/17	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 63A 3PH	LA22245	21/12/17	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 63A 3PH	LA21431	12/12/17	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 63A 3PH	LA42572	21/12/17	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 63A 3PH	LA22246	13/12/17	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK - 63A 3PH	LA31372	13/12/17	P	S	S	S	S	S	S	S	S
ADAPTOR 3M											
POWERLOCK LINK E 1.5M	LA38834	11/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38835	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33468	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA42853	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33465	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33467	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33466	11/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38833	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA33469	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA42698	11/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA42696	11/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38832	20/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
POWERLOCK LINK E 1.5M	LA38831	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK E 1.5M	LA38830	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33447	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33446	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33445	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33448	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38809	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38811	11/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38808	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA33449	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA38807	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA42653	11/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L1 1.5M	LA42837	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33450	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38813	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33451	16/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA42665	16/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA42659	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38812	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33452	16/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38817	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38815	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38816	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA38814	16/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33453	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L2 1.15M	LA33454	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38818	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38819	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38821	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38820	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA38822	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33455	15/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33458	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33459	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33456	15/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA42678	15/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA33457	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA42859	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK L3 1.5M	LA42688	16/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33462	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33460	16/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33461	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33463	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38826	16/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38825	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38827	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38828	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA42848	29/01/18	S	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA33464	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA42685	11/01/18	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38824	20/12/17	P	S	S	S	S	S	S	S	S
POWERLOCK LINK N 1.5M	LA38829	20/12/17	P	S	S	S	S	S	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38112	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38113	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38115	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38114	15/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38111	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38106	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38105	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38104	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38107	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COLOUR											
PROLIGHTS ARENACOB FULL COLOUR	LA38110	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38109	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38108	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38125	05/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38124	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38123	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.33 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38126	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38129	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38128	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38127	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.26 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38118	15/01/18	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38117	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.32 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38116	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38119	15/12/17	P	S	0.07 P	>300 P	<0.05 P	0.22 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38122	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38121	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38120	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38083	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38082	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38081	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38085	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.26 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38088	15/01/18	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38087	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38086	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38080	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38075	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38074	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38073	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.32 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38076	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38079	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38078	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38077	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38099	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38098	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38097	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38100	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA38103	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COLOUR											
PROLIGHTS ARENACOB FULL	LA38102	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38101	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38096	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38091	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38090	15/01/18	P	S	0.06 P	>300 P	<0.05 P	0.31 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38089	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38092	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38095	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38094	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38093	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41148	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41149	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41147	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.32 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41145	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.33 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41146	15/01/18	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41150	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41154	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41155	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.30 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41153	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41151	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.33 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41152	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.34 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38399	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38662	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38400	12/01/18	P	S	0.05 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38402	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38401	15/01/18	P	S	0.06 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41141	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41143	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41144	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41142	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38663	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38664	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.34 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41304	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38665	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.26 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41302	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA41303	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
COLOUR											
PROLIGHTS ARENACOB FULL	LA38130	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
COLOUR											
PROLIGHTS ARENACOB FULL COLOUR	LA38666	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41305	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41306	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41158	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41297	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41157	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41156	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41300	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41301	05/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41298	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.26 P	S	S	S
PROLIGHTS ARENACOB FULL COLOUR	LA41299	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38063	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38064	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38061	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38062	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.33 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38068	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38069	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38070	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38065	15/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38066	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38067	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.33 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38258	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38254	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38253	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38255	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38256	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38257	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38249	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38259	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38260	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38252	15/01/18	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38251	15/01/18	P	S	0.05 P	>300 P	<0.05 P	0.26 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38250	12/01/18	P	S	0.04 P	>300 P	<0.05 P	0.33 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38072	15/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ARENACOB HALO	LA38071	05/01/18	P	S	0.04 P	>300 P	<0.05 P	0.28 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE	LA41315	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE	LA41314	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.31 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE	LA41313	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE	LA41318	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE	LA41317	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS ECLIPSEHDTU LED PROFILE	LA41316	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38336	11/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38177	11/01/18	P	S	0.02 P	>300 P	0.07 P	0.96 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38176	04/01/18	P	S	0.04 P	>300 P	0.09 P	0.78 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38181	11/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38178	11/01/18	P	S	0.03 P	>300 P	0.07 P	0.89 P	S	S	S
PROLIGHTS LUMIPIX16H HIGH-POWER LED BATTEN	LA38179	11/01/18	P	S	0.03 P	>300 P	0.07 P	0.91 P	S	S	S
PROLIGHTS LUMIPIX16H	LA38180	04/01/18	P	S	0.03 P	>300 P	0.09 P	0.77 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
HIGH-POWER LED BATTEN PROLIGHTS LUMIPIX16H	LA38175	11/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
HIGH-POWER LED BATTEN PROLIGHTS LUMIPIX16H	LA38183	11/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
HIGH-POWER LED BATTEN PROLIGHTS LUMIPIX16H	LA38182	11/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
HIGH-POWER LED BATTEN PROLIGHTS LUMIPIX16H	LA38059	11/01/18	P	S	0.03 P	>300 P	0.07 P	0.87 P	S	S	S
HIGH-POWER LED BATTEN PROLIGHTS LUMIPIX16H	LA38174	11/01/18	P	S	0.03 P	>300 P	0.07 P	0.94 P	S	S	S
HIGH-POWER LED BATTEN PROLIGHTS LUMIPIX16H	LA38173	11/01/18	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
HIGH-POWER LED BATTEN PROLIGHTS LUMIPIX16H	LA38058	11/01/18	P	S	0.03 P	>300 P	0.07 P	0.96 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37647	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37646	20/12/17	P	S	0.07 P	>300 P	0.05 P	0.13 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37648	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38504	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37645	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37640	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37639	20/12/17	P	S	0.05 P	>300 P	0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37638	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37641	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37644	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37643	20/12/17	P	S	0.07 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37642	21/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37760	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37761	20/12/17	P	S	0.06 P	>300 P	0.06 P	0.14 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37762	20/12/17	P	S	0.06 P	>300 P	0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37757	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37758	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37759	21/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37765	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37764	20/12/17	P	S	0.07 P	>300 P	0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37763	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38503	21/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38502	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38501	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38495	21/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38496	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38497	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37671	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38493	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38494	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.12 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37754	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37755	20/12/17	P	S	0.05 P	>300 P	0.06 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA37756	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38498	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38499	20/12/17	P	S	0.07 P	>300 P	<0.05 P	0.12 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS SMARTBATIP	LA38500	20/12/17	P	S	0.07 P	>300 P	0.05 P	0.13 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38695	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38694	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38697	22/12/17	P	S	0.02 P	>300 P	<0.05 P	0.16 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38696	20/12/17	P	S	0.06 P	>300 P	<0.05 P	0.17 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38691	08/12/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38690	21/12/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38693	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38692	15/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38700	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38710	15/12/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38707	20/12/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38713	02/01/18	P	S	0.04 P	>300 P	0.05 P	0.15 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38712	02/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38703	21/12/17	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38702	21/12/17	P	S	0.07 P	>300 P	<0.05 P	0.15 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38706	22/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38704	22/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38675	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38673	21/12/17	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38677	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38676	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38669	20/12/17	P	S	0.09 P	>300 P	<0.05 P	0.16 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38668	22/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38672	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.29 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38671	20/12/17	P	S	0.09 P	>300 P	<0.05 P	0.16 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38680	15/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38687	22/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38686	15/12/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38689	21/12/17	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38688	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
BATTERY LED PROJECTOR PROLIGHTS STUDIOCOBFC FULL COLOUR	LA38683	15/12/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38681	21/12/17	P	S	0.06 P	>300 P	<0.05 P	0.16 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38685	02/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38684	21/12/17	P	S	0.03 P	>300 P	<0.05 P	0.28 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38741	22/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38740	20/12/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38743	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38742	21/12/17	P	S	0.03 P	>300 P	<0.05 P	<0.10 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38736	15/12/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38735	22/12/17	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38739	21/12/17	P	S	0.04 P	>300 P	<0.05 P	0.16 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38738	21/12/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38744	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38752	15/12/17	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38750	15/12/17	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA41526	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38756	21/12/17	P	S	0.05 P	>300 P	<0.05 P	0.17 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38746	22/12/17	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38745	20/12/17	P	S	0.08 P	>300 P	<0.05 P	0.17 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38749	02/01/18	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38747	15/12/17	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38719	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38718	20/12/17	P	S	0.08 P	>300 P	<0.05 P	0.16 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38721	21/12/17	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38720	21/12/17	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38715	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38714	15/12/17	P	S	0.03 P	>300 P	<0.05 P	0.13 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38717	02/01/18	P	S	0.03 P	>300 P	<0.05 P	0.14 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38716	20/12/17	P	S	0.08 P	>300 P	<0.05 P	0.16 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38722	21/12/17	P	S	0.03 P	>300 P	<0.05 P	0.29 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38730	21/12/17	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38729	21/12/17	P	S	0.04 P	>300 P	<0.05 P	0.14 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38734	15/12/17	P	S	0.04 P	>300 P	<0.05 P	0.17 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38731	02/01/18	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38725	21/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38723	21/12/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38728	21/12/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
FULL COLOUR PROLIGHTS STUDIOCOBFC	LA38727	15/12/17	P	S	0.04 P	>300 P	<0.05 P	0.13 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FULL COLOUR PROLIGHTS STUDIOCOBUV LED UV	LA38200	12/01/18	P	S	0.02 P	182.40 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38201	06/02/18	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38198	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38199	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38202	08/12/17	P	S	0.05 P	>300 P	0.10 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38205	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38206	08/12/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38203	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38204	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38197	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.13 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38190	08/12/17	P	S	0.04 P	>300 P	0.10 P	0.16 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38191	08/12/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38188	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38189	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38192	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38195	08/12/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38196	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38193	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38194	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38207	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.16 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38220	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.16 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38221	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38218	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38219	08/12/17	P	S	0.06 P	>300 P	0.10 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38222	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38225	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38226	12/01/18	P	S	0.02 P	269.70 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38223	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38224	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.14 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38217	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38210	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38211	08/12/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38208	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38209	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38212	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV LED UV	LA38215	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
PROLIGHTS STUDIOCOBUV	LA38216	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
LED UV											
PROLIGHTS STUDIOCOBUV	LA38213	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38214	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38187	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38027	08/12/17	P	S	0.04 P	>300 P	0.10 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38019	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38026	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38030	12/01/18	P	S	0.02 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38029	12/01/18	P	S	0.03 P	>300 P	<0.05 P	0.16 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38028	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.16 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38022	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38021	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38020	12/01/18	P	S	0.02 P	>300 P	<0.05 P	0.17 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38025	08/12/17	P	S	0.04 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38024	08/12/17	P	S	0.06 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38023	08/12/17	P	S	0.07 P	>300 P	<0.05 P	0.16 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38186	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS STUDIOCOBUV	LA38185	08/12/17	P	S	0.05 P	>300 P	<0.05 P	0.15 P	S	S	S
LED UV											
PROLIGHTS WIFIBOX WIFI/DMX	LA37649	20/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
INTERFACE											
PROLIGHTS WIFIBOX WIFI/DMX	LA37826	20/12/17	P	S	S	>300 P	S	S	<0.10 P	S	S
INTERFACE											
PROPLEX DMX OPTO	LA34304	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34305	24/01/18	P	S	0.08 P	S	<0.05 P	0.15 P	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34885	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34326	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34302	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34301	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34303	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34300	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34329	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34328	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34934	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA26968	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34327	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34887	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34886	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34888	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA37468	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
ISOLATOR											
PROPLEX DMX OPTO	LA34884	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ISOLATOR											
PROPLEX DMX OPTO ISOLATOR	LA34805	24/01/18	P	S	0.07 P	S <0.05 P	0.17 P	P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34806	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34803	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34804	24/01/18	P	S	0.07 P	S <0.05 P	0.16 P	P	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34808	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34883	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
PROPLEX DMX OPTO ISOLATOR	LA34807	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38518	05/01/18	P	S	0.03 P	>300 P <0.05 P	0.25 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41312	12/01/18	P	S	0.03 P	S <0.05 P	0.22 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38306	16/01/18	P	S	0.01 P	S <0.05 P	0.18 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38519	16/01/18	P	S	0.02 P	S <0.05 P	0.24 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38302	16/01/18	P	S	0.03 P	>300 P <0.05 P	0.17 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41309	05/01/18	P	S	0.04 P	>300 P <0.05 P	0.25 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41311	12/01/18	P	S	0.06 P	S <0.05 P	0.22 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38516	16/01/18	P	S	0.02 P	S <0.05 P	0.22 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41308	12/01/18	P	S	0.04 P	S <0.05 P	0.23 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38305	16/01/18	P	S	0.05 P	S <0.05 P	0.17 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38301	16/01/18	P	S	0.03 P	>300 P <0.05 P	0.18 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41307	12/01/18	P	S	0.06 P	S <0.05 P	0.22 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38303	16/01/18	P	S	0.05 P	S <0.05 P	0.18 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38294	05/01/18	P	S	0.04 P	>300 P <0.05 P	0.17 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA41310	05/01/18	P	S	0.06 P	>300 P <0.05 P	0.25 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38295	16/01/18	P	S	S	>300 P S	S	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38517	17/01/18	P	S	0.03 P	>300 P <0.05 P	0.26 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38031	12/01/18	P	S	0.04 P	S <0.05 P	0.16 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38032	12/01/18	P	S	0.02 P	S <0.05 P	0.16 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38299	17/01/18	P	S	0.02 P	>300 P <0.05 P	0.26 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38300	16/01/18	P	S	0.04 P	>300 P <0.05 P	0.17 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38304	16/01/18	P	S	0.03 P	S <0.05 P	0.17 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38296	17/01/18	P	S	0.02 P	>300 P <0.05 P	0.19 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38297	17/01/18	P	S	0.04 P	>300 P <0.05 P	0.18 P	P	S	S	S
PROPLEX RDM DMX OPTO ISOLATOR	LA38298	16/01/18	P	S	0.02 P	S <0.05 P	0.17 P	P	S	S	S
PROPLEX SCENE SWITCH 8	LA38369	12/12/17	P	S	0.06 P	>300 P S	S	P	S	S	S
PROPLEX SCENE SWITCH 8	LA38368	12/12/17	P	S	0.08 P	>300 P S	S	P	S	S	S
PROPLEX SCENE SWITCH 8	LA38371	12/12/17	P	S	0.07 P	>300 P S	S	P	S	S	S
PROPLEX SCENE SWITCH 8	LA38370	12/12/17	P	S	0.08 P	>300 P S	S	P	S	S	S
PROPLEX SCENE SWITCH 8	LA41187	12/12/17	P	S	0.06 P	>300 P S	S	P	S	S	S
PROPLEX SCENE SWITCH 8	LA41186	12/12/17	P	S	0.07 P	>300 P S	S	P	S	S	S
PULSAR UNI PAK 10A DIMMER	LA22933	13/12/17	P	S	0.08 P	>300 P <0.05 P	<0.10 P	P	S	S	S
PULSAR UNI PAK 10A DIMMER	LA22937	13/12/17	P	S	0.09 P	>300 P <0.05 P	<0.10 P	P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
QUAD FIBRE MULTICORE 150M	LA38877	08/12/17	P	S	S	S	S	S	S	S	S
QUAD FIBRE MULTICORE 150M	LA38942	08/12/17	P	S	S	S	S	S	S	S	S
QUAD FIBRE MULTICORE 150M	LA36056	08/12/17	P	S	S	S	S	S	S	S	S
QUAD FIBRE MULTICORE 150M	LA42637	02/02/18	S	S	S	S	S	S	S	S	S
QUAD FIBRE MULTICORE 150M	LA39486	08/12/17	P	S	S	S	S	S	S	S	S
REEL FX DF50 CRACKER	LA34248	17/01/18	P	S	0.04 P	>300 P	0.42 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA17198	17/01/18	P	S	0.04 P	>300 P	0.48 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA31431	17/01/18	P	S	0.05 P	>300 P	0.50 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA31432	17/01/18	P	S	0.04 P	>300 P	0.45 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA21836	06/02/18	P	S	0.05 P	>300 P	0.40 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA21837	07/02/18	P	S	0.04 P	13.06 P	0.41 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA17199	05/02/18	P	S	0.05 P	>300 P	0.49 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA21835	17/01/18	P	S	0.06 P	>300 P	0.39 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA22772	17/01/18	P	S	0.05 P	68.64 P	0.45 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA34869	17/01/18	P	S	0.04 P	>300 P	0.44 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA24941	17/01/18	P	S	0.05 P	>300 P	0.42 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA25756	17/01/18	P	S	0.04 P	>300 P	0.42 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA25755	17/01/18	P	S	0.07 P	>300 P	0.41 P	<0.10 P	S	S	S
REEL FX DF50 CRACKER	LA25006	17/01/18	P	S	0.05 P	>300 P	0.39 P	<0.10 P	S	S	S
RJ FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA41458	08/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
RJ FLO 1800 MSR FOLLOW SPOT 13/24 DEG	LA41459	08/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
ROBE PATT 2013	LA41036	09/01/18	P	S	0.08 P	>300 P	0.78 P	<0.10 P	S	S	S
ROBE PATT 2013	LA41035	09/01/18	P	S	0.08 P	>300 P	0.76 P	<0.10 P	S	S	S
ROBE PATT 2013	LA41038	09/01/18	P	S	0.08 P	286.40 P	0.77 P	<0.10 P	S	S	S
ROBE PATT 2013	LA41037	09/01/18	P	S	0.07 P	>300 P	0.79 P	<0.10 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41495	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41494	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41492	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41499	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41496	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.25 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41497	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41498	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41481	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.21 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41482	08/01/18	P	S	0.04 P	>300 P	<0.05 P	0.21 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41483	08/01/18	P	S	0.04 P	>300 P	<0.05 P	0.22 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41478	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.21 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41479	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.21 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41480	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.21 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41484	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.21 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41489	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41490	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.21 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41491	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41485	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.24 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41486	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41488	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41509	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
ROBERT JULIAT DALIS 862 LED FOOT LIGHT	LA41510	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
ROBERT JULIAT DALIS 862 LED	LA41507	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41508		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41513		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41515		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41511		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41512		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41502		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41503		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41500		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41501		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.22 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41504		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41505		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.23 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT DALIS 862 LED LA41506		08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.24 P	S	S	S
FOOT LIGHT											
ROBERT JULIAT FLO 1800 MSR LA34741		05/01/18	P	S	0.08 P	37.20 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT 13/24 DEG											
ROBERT JULIAT FLO 1800 MSR LA37962		05/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT 13/24 DEG											
ROBERT JULIAT FLO 1800 MSR LA37934		05/01/18	P	S	0.08 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT 13/24 DEG											
ROBERT JULIAT FLO 1800 MSR LA34743		15/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT 13/24 DEG											
ROBERT JULIAT FLO 1800 MSR LA37395		05/01/18	P	S	0.09 P	111.60 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT 13/24 DEG											
ROBERT JULIAT FLO 1800 MSR LA38046		15/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT 13/24 DEG											
ROBERT JULIAT FLO 1800 MSR LA34740		15/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT 13/24 DEG											
ROBERT JULIAT FLO 1800 MSR LA37973		15/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT 13/24 DEG											
ROBERT JULIAT FLO 1800 MSR LA34745		15/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA37457		05/01/18	P	S	0.08 P	113.80 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA37396		10/01/18	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA34744		15/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA37974		05/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA37961		05/01/18	P	S	0.06 P	32.90 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA38045		15/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA34747		15/01/18	P	S	0.06 P	>300 P	S	S	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA41460		08/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA37162		10/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA37960		05/01/18	P	S	0.06 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROBERT JULIAT FLO 1800 MSR LA41461		08/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
FOLLOW SPOT BALLAST											
ROCKSWITCH 8 PRO DMX /	LA37553	17/01/18	P	S	0.04 P	S	<0.05 P	0.49 P	S	S	S
ETHERNET SWITCH											
ROCKSWITCH 8 PRO DMX /	LA37389	16/01/18	P	S	0.06 P	S	<0.05 P	0.48 P	S	S	S
ETHERNET SWITCH											
ROCKSWITCH 8 PRO DMX /	LA37390	12/12/17	P	S	0.09 P	>300 P	S	S	S	S	S
ETHERNET SWITCH											
ROCKSWITCH 8 PRO DMX /	LA38359	17/01/18	P	S	0.04 P	S	<0.05 P	0.48 P	S	S	S
ETHERNET SWITCH											
ROCKSWITCH 8 PRO DMX /	LA38358	17/01/18	P	S	0.04 P	S	<0.05 P	0.48 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
ETHERNET SWITCH											
ROCKSWITCH 8 PRO DMX / ETHERNET SWITCH	LA37401	17/01/18	P	S	0.04 P	S	<0.05 P	0.49 P	S	S	S
SGM X5 WHITE LED STROBE	LA34251	21/12/17	P	S	0.05 P	>300 P	<0.05 P	0.30 P	S	S	S
SGM X5 WHITE LED STROBE	LA34662	21/12/17	P	S	0.04 P	>300 P	<0.05 P	0.30 P	S	S	S
SGM X5 WHITE LED STROBE	LA34663	19/12/17	P	S	0.08 P	>300 P	<0.05 P	0.31 P	S	S	S
SGM X5 WHITE LED STROBE	LA34226	19/12/17	P	S	0.08 P	>300 P	<0.05 P	0.31 P	S	S	S
SGM X5 WHITE LED STROBE	LA34223	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.25 P	S	S	S
SGM X5 WHITE LED STROBE	LA34252	19/12/17	P	S	0.06 P	>300 P	<0.05 P	0.32 P	S	S	S
SGM X5 WHITE LED STROBE	LA34270	19/12/17	P	S	0.07 P	>300 P	<0.05 P	0.31 P	S	S	S
SGM X5 WHITE LED STROBE	LA34272	19/12/17	P	S	0.06 P	>300 P	<0.05 P	0.31 P	S	S	S
SGM X5 WHITE LED STROBE	LA34267	21/12/17	P	S	0.08 P	>300 P	<0.05 P	0.31 P	S	S	S
SGM X5 WHITE LED STROBE	LA34268	21/12/17	P	S	0.05 P	>300 P	<0.05 P	0.30 P	S	S	S
SGM X5 WHITE LED STROBE	LA34284	19/12/17	P	S	0.08 P	>300 P	<0.05 P	0.31 P	S	S	S
SGM X5 WHITE LED STROBE	LA34261	21/12/17	P	S	0.05 P	>300 P	<0.05 P	0.29 P	S	S	S
SGM X5 WHITE LED STROBE	LA34260	19/12/17	P	S	0.05 P	>300 P	<0.05 P	0.31 P	S	S	S
SGM X5 WHITE LED STROBE	LA34264	21/12/17	P	S	0.05 P	>300 P	<0.05 P	0.29 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26202	04/01/18	P	S	0.07 P	>300 P	<0.05 P	0.37 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34668	15/12/17	P	S	0.08 P	>300 P	<0.05 P	0.31 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26203	15/12/17	P	S	0.05 P	>300 P	<0.05 P	0.27 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26199	04/01/18	P	S	0.05 P	>300 P	<0.05 P	0.38 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26198	04/01/18	P	S	0.03 P	>300 P	<0.05 P	0.37 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26200	04/01/18	P	S	0.05 P	>300 P	<0.05 P	0.39 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26294	08/01/18	P	S	0.04 P	>300 P	<0.05 P	0.39 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34666	15/12/17	P	S	0.08 P	>300 P	<0.05 P	0.29 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34546	04/01/18	P	S	0.04 P	>300 P	<0.05 P	0.38 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA31515	04/01/18	P	S	0.06 P	>300 P	<0.05 P	0.33 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26295	04/01/18	P	S	0.07 P	179.30 P	<0.05 P	0.33 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26297	04/01/18	P	S	0.04 P	>300 P	<0.05 P	0.34 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34667	04/01/18	P	S	0.04 P	>300 P	<0.05 P	0.36 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26197	04/01/18	P	S	0.08 P	>300 P	<0.05 P	0.38 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34684	04/01/18	P	S	0.04 P	>300 P	<0.05 P	0.36 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34685	04/01/18	P	S	0.05 P	>300 P	<0.05 P	0.37 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34680	04/01/18	P	S	0.05 P	>300 P	<0.05 P	0.36 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34682	04/01/18	P	S	0.05 P	>300 P	<0.05 P	0.35 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34687	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.40 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34671	04/01/18	P	S	0.05 P	>300 P	<0.05 P	0.36 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34670	04/01/18	P	S	0.06 P	>300 P	<0.05 P	0.35 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34688	04/01/18	P	S	0.06 P	>300 P	<0.05 P	0.36 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34689	15/12/17	P	S	0.09 P	>300 P	<0.05 P	0.29 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA24323	04/01/18	P	S	0.06 P	>300 P	<0.05 P	0.32 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34673	04/01/18	P	S	0.05 P	>300 P	<0.05 P	0.36 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34674	04/01/18	P	S	0.09 P	>300 P	<0.05 P	0.37 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34675	04/01/18	P	S	0.06 P	>300 P	<0.05 P	0.36 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34672	04/01/18	P	S	0.06 P	>300 P	<0.05 P	0.36 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SHOWTEC SUNSTRIP ACTIVE DMX	LA34678	08/01/18	P	S	0.03 P	>300 P	<0.05 P	0.41 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34679	04/01/18	P	S	0.04 P	>300 P	<0.05 P	0.35 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA24319	04/01/18	P	S	0.07 P	>300 P	<0.05 P	0.35 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34677	08/01/18	P	S	0.09 P	>300 P	<0.05 P	0.42 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA34669	15/12/17	P	S	0.09 P	>300 P	<0.05 P	0.29 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA24316	08/01/18	P	S	0.05 P	>300 P	<0.05 P	0.40 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26192	15/12/17	P	S	0.04 P	>300 P	<0.05 P	0.27 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26193	04/01/18	P	S	0.06 P	>300 P	<0.05 P	0.36 P	S	S	S
SHOWTEC SUNSTRIP ACTIVE DMX	LA26194	08/01/18	P	S	0.06 P	13.92 P	<0.05 P	0.47 P	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15596	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15588	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15595	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15592	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA42098	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17484	26/01/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15599	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15598	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15586	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17483	08/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA42097	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15587	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17642	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17486	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17485	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17643	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA17487	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15630	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA35127	07/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15625	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - 16A 1PH ADAPTOR	LA15597	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - IEC EURO ADAPTOR	LA26059	02/02/18	S	S	S	S	S	S	S	S	S
SHUKO - IEC EURO ADAPTOR	LA24491	07/02/18	S	S	S	S	S	S	S	S	S
SHUKO - POWERCON ADAPTOR	LA35120	02/02/18	S	S	S	S	S	S	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31628	19/12/17	P	S	0.12 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31636	19/12/17	P	S	0.12 P	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31626	19/12/17	P	S	0.11 P	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31629	19/12/17	P	S	0.12 P	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31627	19/12/17	P	S	0.12 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31634	19/12/17	P	S	0.12 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34380	19/12/17	P	S	0.12 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31015	19/12/17	P	S	0.11 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34372	19/12/17	P	S	0.13 P	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31017	19/12/17	P	S	0.12 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31014	19/12/17	P	S	0.12 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31006	19/12/17	P	S	0.12 P	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31007	19/12/17	P	S	0.12 P	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31012	19/12/17	P	S	0.13 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31011	19/12/17	P	S	0.12 P	>300 P	<0.05 P	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
LAMP											
SILVER EXHIBITION CLAMP ON LAMP	LA34368	19/12/17	P	S	0.14 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31625	19/12/17	P	S	0.14 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31624	19/12/17	P	S	0.12 P	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31638	19/12/17	P	S	0.13 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31639	19/12/17	P	S	0.13 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31623	19/12/17	P	S	0.13 P	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31633	19/12/17	P	S	0.11 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA34366	19/12/17	P	S	0.14 P	>300 P	0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31621	19/12/17	P	S	0.11 P	>300 P	<0.05 P	<0.10 P	S	S	S
SILVER EXHIBITION CLAMP ON LAMP	LA31630	19/12/17	P	S	0.11 P	>300 P	<0.05 P	<0.10 P	S	S	S
SNOW / CONFETTI SUPERSTAR MACHINE (FAN STYLE)	LA15149	14/12/17	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
SNOW / CONFETTI SUPERSTAR MACHINE (FAN STYLE)	LA15148	14/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
SNOW / CONFETTI SUPERSTAR MACHINE (FAN STYLE)	LA17425	14/12/17	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN IN	LA35144	02/02/18	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN IN	LA25640	25/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN IN	LA21136	09/02/18	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN IN	LA25917	02/02/18	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN IN	LA21137	09/02/18	S	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA43086	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA43093	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30161	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30160	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30163	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30162	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30629	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30632	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30631	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30630	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30633	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30782	25/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA35087	25/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30634	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA30781	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA22676	09/01/18	P	S	S	S	S	S	S	S	S
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA42962	07/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCA - 3 WAY 415V/110V MOTOR FAN OUT	LA22675	09/01/18	P	S	S	S	S	S	S	S	S
SOCA- 3 WAY 415V/110V MOTOR FAN OUT 60FT	LA20274	25/01/18	P	S	S	S	S	S	S	S	S
SOCA- 3 WAY 415V/110V MOTOR FAN OUT 60FT	LA20275	25/01/18	P	S	S	S	S	S	S	S	S
SOCA- 3 WAY 415V/110V MOTOR FAN OUT 60FT	LA20272	30/01/18	S	S	S	S	S	S	S	S	S
SOCA- 3 WAY 415V/110V MOTOR FAN OUT 60FT	LA20273	25/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20531	08/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20529	08/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20528	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20532	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20535	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20536	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20534	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20526	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20527	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20525	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20524	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20521	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20522	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - 2 X 16A 240V / 1 X 16A 110V	LA20523	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15690	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15691	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15697	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15693	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15692	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15696	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15695	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15694	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15685	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15688	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15687	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX - SOCAPEX (1/2345/6)	LA15686	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 3 WAY 415V/110V MOTOR FAN IN	LA32869	02/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 3 WAY 415V/110V MOTOR FAN IN	LA32870	06/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 3 WAY 415V/110V MOTOR FAN IN	LA32871	25/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA20187	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA22324	19/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA20190	19/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA20189	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA22323	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21945	08/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21944	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA22322	25/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA22321	19/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA42129	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32275	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA17463	19/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA17462	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32276	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32279	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32280	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32277	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA32278	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21128	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21130	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA40287	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA16889	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21131	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA17466	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA17465	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA21133	19/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (F) - 6 X 16A 1PH FAN IN	LA17467	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32841	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32842	25/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32844	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32839	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32843	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32583	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32589	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32590	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32584	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32838	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32848	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32847	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32588	25/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32849	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32846	25/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32845	25/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32840	25/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32586	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 3 WAY 415V/110V MOTOR FAN OUT	LA32587	09/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01843	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32691	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22911	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01841	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32692	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35549	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32694	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32693	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35550	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01979	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01844	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35551	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35552	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32690	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35108	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17124	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24963	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01748	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17274	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01660	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24966	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24964	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24965	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35092	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32687	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32689	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32688	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32686	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35099	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24962	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32685	08/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24961	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21774	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21776	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32274	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21772	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21779	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21780	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21777	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21778	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35537	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35538	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA36232	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA36231	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35541	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35542	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35539	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35540	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32269	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32267	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32272	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32271	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24959	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35091	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32266	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32265	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21783	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35543	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21781	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21782	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35546	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32273	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35544	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35545	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43095	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01416	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32521	26/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21947	08/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32522	26/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32520	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24974	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32517	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32577	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22652	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21946	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21932	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21933	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24973	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35146	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21934	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43089	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32576	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21935	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA21936	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22649	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32519	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22647	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22648	26/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35556	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35553	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22650	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35555	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35554	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22646	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32579	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32581	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22651	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32578	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32582	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22644	06/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22645	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32518	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22643	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35909	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA25116	04/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35911	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35910	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA22977	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35905	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35904	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24975	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35908	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35912	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA15638	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43092	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24967	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01659	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43091	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24968	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35913	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43090	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA01612	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35894	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43087	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35896	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35895	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35131	06/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24970	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA04516	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA43088	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24969	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32575	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA34568	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA34565	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35903	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35902	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35901	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35899	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA35898	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32573	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA32574	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40314	04/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40315	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40304	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17815	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40316	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26917	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26916	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40317	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40318	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26927	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40284	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA42218	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17819	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40283	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17818	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40295	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40298	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA42216	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17817	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26914	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26878	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30534	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30533	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26879	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30535	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26874	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26871	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26876	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26875	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA33313	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26886	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30527	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17811	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26913	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30528	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30531	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30532	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30529	08/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA30530	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40170	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40171	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40168	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40169	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40172	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40177	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40178	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40173	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40176	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40167	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40159	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40160	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40157	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40158	26/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40161	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40165	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40166	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40162	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40164	17/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40180	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17878	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17827	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17895	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17879	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17826	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17821	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17820	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17825	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA17824	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20356	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40183	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40185	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40181	17/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40182	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA40186	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20359	04/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20358	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20439	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA20361	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26870	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA42108	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24958	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA26869	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24955	08/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X 16A 1PH FAN OUT	LA24956	04/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42269	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42263	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA40163	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42267	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42265	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA40179	08/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA40175	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42230	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42248	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA40174	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42261	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42262	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42220	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA42260	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P/CON TRUE FAN OUT	LA32270	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40684	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40683	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40682	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40687	08/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40686	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40685	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40678	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40677	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42228	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40681	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40680	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40679	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40695	23/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40694	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40693	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40697	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40696	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42259	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42244	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40689	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40688	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40692	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40691	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40690	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42224	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42257	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42245	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42222	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42223	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42256	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42250	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42251	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42252	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42246	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42247	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42253	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42255	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40988	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40990	07/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40992	07/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42243	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40987	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42227	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40991	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42258	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42254	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42226	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42221	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42225	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40698	23/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42229	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40726	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40725	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42233	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42232	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42231	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40721	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40720	08/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40996	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40724	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40723	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40722	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42238	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42237	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42236	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42242	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42241	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42239	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40995	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42235	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42234	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40993	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42240	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40994	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40719	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42264	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42266	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40704	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40707	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40706	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40705	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40701	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40700	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40699	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40703	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA42268	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40702	30/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40716	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40715	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40714	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40718	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40989	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40717	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40711	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40709	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40710	22/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40708	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40713	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX (M) - 6 X P' CON TRUE STAG F/OUT	LA40712	07/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX (M) IP67 - 6 X 16A 1PH FAN OUT	LA42619	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA20110	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA34557	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA30195	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32308	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36149	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32073	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA31994	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36151	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36177	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36216	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA17148	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA30761	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA43068	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36080	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36079	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32361	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36076	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA36078	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA22848	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA30852	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA32038	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 10M	LA26076	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30946	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA36084	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA34709	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA32793	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA21904	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA21785	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA32792	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30308	10/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30854	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA21788	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA30783	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 15M	LA43050	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA31997	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA17624	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA24291	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30890	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30865	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36111	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30889	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA32036	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA22759	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30894	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30862	03/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 1.5MM CABLE 2.5M	LA30891	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA32033	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20546	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36171	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA32035	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36170	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20545	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20540	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA34547	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA20544	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36060	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36061	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA31351	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30932	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36063	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21145	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21142	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21144	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30931	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21302	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36155	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA36169	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA30933	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 2.5M	LA21301	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA24712	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA31053	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA36185	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA36086	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA31612	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA36025	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 20M	LA22879	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 30M	LA32064	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 30M	LA36101	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 40M	LA36230	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 40M	LA01995	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA22758	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20553	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30190	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30942	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30941	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA26605	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA34696	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30948	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30944	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30193	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36141	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30888	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA01276	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA17272	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36143	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30851	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30855	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20562	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36148	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36173	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA21900	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36131	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA17282	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA22063	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36145	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20556	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36142	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20427	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20429	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30850	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA21540	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30197	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30194	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20554	03/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 1.5MM CABLE 5M	LA30305	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20555	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36071	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36070	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36068	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36072	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA36073	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA30765	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 1.5MM CABLE 5M	LA20054	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32359	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32541	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32542	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32040	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32540	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32497	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32498	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32499	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32231	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32229	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32228	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32232	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32535	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32534	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32533	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32500	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43073	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32227	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32226	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32225	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32538	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32537	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32536	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32496	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32495	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32539	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32493	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32492	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32491	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32233	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32304	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32494	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36198	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36182	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA22523	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA22522	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21924	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21923	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36181	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36180	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43063	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32757	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21716	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32758	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32754	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36215	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32756	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32755	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36179	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36020	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32645	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21714	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32644	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32648	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36034	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32646	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32647	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21920	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21919	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21922	02/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 10M	LA21921	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21710	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21713	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21709	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21802	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43069	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30470	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43071	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43070	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43065	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43064	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43067	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43066	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30466	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30467	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30462	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30465	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25584	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA43072	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30468	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25583	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25585	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32791	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36082	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA36083	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32876	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA21717	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32874	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32875	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA30857	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25589	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25588	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25586	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25590	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32925	05/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA32926	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 10M	LA25592	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32764	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32877	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32862	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32878	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32924	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32923	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32861	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32857	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32856	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32858	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32860	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32859	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32550	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32551	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33025	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33026	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33027	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33019	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33018	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32552	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33020	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32547	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32545	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33021	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33023	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32544	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32549	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33024	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32543	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32548	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33017	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43096	30/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 15M	LA43097	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32603	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32604	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43098	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32762	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32763	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32759	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32760	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33014	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33013	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33016	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33015	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33012	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33009	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33008	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33011	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA33010	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32249	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32301	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30947	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32246	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32247	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32248	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32041	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32006	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36022	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36184	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32074	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32055	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30945	08/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32237	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32235	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30486	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32238	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32239	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32240	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32242	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32243	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32244	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30485	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA30484	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32241	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22429	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43057	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22433	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22436	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43054	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43055	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43056	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22437	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43060	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43061	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43062	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA22440	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43058	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43059	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43045	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43044	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36001	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43047	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA32007	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43046	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43051	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43052	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43053	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA36021	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43048	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 15M	LA43049	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA30930	03/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 2.5M	LA30935	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA30936	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36200	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA32886	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA32872	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36066	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36039	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA36065	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 2.5M	LA43084	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30972	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30971	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA31654	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30978	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36097	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36099	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36098	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30969	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36026	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30965	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36024	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30963	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36023	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36032	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30967	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30968	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32768	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32767	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32789	15/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32769	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36088	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36090	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32766	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32765	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36091	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30977	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30976	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36095	08/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36094	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36093	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36092	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30975	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30973	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32989	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32988	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21915	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32990	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32993	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32992	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32991	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30452	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30453	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30454	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21724	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21912	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21891	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA21890	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32994	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22635	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33007	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33005	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22639	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22642	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22641	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA22640	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32999	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32996	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32995	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33000	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33004	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 20M	LA33003	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA33002	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36193	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36191	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36189	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36219	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32863	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36222	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36221	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30959	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30960	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30961	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30958	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA36187	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30955	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30956	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32864	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32932	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32931	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32922	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30460	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30455	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30457	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA30459	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32880	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32879	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32865	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32881	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32884	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32883	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32882	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32220	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32219	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32222	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32221	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32218	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32554	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32216	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32217	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32555	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32561	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32559	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32357	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32340	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32224	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32223	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32556	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32558	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32557	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32215	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32208	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32207	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32211	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32209	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32075	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32043	20/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32206	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32205	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32212	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32213	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 20M	LA32214	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30449	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32939	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32941	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32938	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36106	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36105	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36103	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36104	19/12/17	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 30M	LA32944	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30450	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32942	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32943	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32934	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30790	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30789	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30788	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36227	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30856	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30791	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36107	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA43022	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32933	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30786	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32062	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32885	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32973	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32972	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32971	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32976	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32975	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32974	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32969	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32964	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32963	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32961	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32968	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32967	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32965	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32977	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22656	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22653	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32987	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA24312	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA24977	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA22658	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32986	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32980	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32979	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32978	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32984	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32982	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32981	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32960	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21739	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21735	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21734	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21798	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21797	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21796	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21733	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30446	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30447	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30448	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA21731	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30444	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30445	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32945	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32955	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32954	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32953	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32959	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32958	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32957	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32952	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32948	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32947	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32946	18/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 30M	LA32951	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32950	30/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32949	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30984	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30985	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36027	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30983	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36002	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36003	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA36004	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32653	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32651	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32649	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA32654	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30992	18/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30991	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30987	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30982	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA31583	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30981	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 30M	LA30980	19/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 40M	LA36108	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 40M	LA38490	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32004	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA30993	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32005	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32002	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA30994	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32001	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 50M	LA32003	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32748	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36015	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30480	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36016	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32749	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36018	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43079	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43082	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43083	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36037	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43081	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32873	07/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32747	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43080	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30479	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32639	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32638	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32637	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21700	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21701	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21706	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25476	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25473	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25472	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21929	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32362	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA25479	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA21640	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43077	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43075	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43074	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30476	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30472	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA43078	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32642	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32641	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32640	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32305	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36014	01/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
SOCAPEX 2.5MM CABLE 5M	LA36013	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30951	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30950	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30949	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36144	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32072	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32071	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32852	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32853	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32854	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32037	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32850	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32851	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36202	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36203	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36204	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36196	06/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36197	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36201	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36175	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30953	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30952	18/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36205	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36206	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36176	02/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32530	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32529	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30938	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30940	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30939	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32528	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32752	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32751	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32524	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32526	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA32525	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA30943	03/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX 2.5MM CABLE 5M	LA36110	01/02/18	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40749	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40755	22/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40750	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40756	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40747	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40754	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40748	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40752	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 10M	LA40751	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40774	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40773	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40943	23/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40945	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40946	31/01/18	S	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40944	21/12/17	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE 15M	LA40758	24/01/18	P	S	S	S	S	S	S	S	S
SOCAPEX IP67 2.5MM CABLE	LA40941	31/01/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
15M											
SOCAPEX IP67 2.5MM CABLE	LA40942	21/12/17	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40939	21/12/17	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40938	24/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40937	24/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40775	21/12/17	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40940	24/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40757	21/12/17	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40776	24/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40772	24/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40761	24/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40767	31/01/18	S	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40766	31/01/18	S	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40770	22/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40769	31/01/18	S	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40759	24/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40765	31/01/18	S	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40771	23/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40763	24/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40764	31/01/18	S	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40762	24/01/18	P	S	S	S	S	S	S	S	S
15M											
SOCAPEX IP67 2.5MM CABLE	LA40777	22/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40953	22/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40954	22/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40779	22/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40947	24/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40948	24/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40786	19/12/17	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40785	22/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40951	24/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40952	22/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40949	24/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40950	24/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40783	24/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40782	24/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40781	20/12/17	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40784	24/01/18	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40956	22/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
20M											
SOCAPEX IP67 2.5MM CABLE	LA40955	20/12/17	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA40780	20/12/17	P	S	S	S	S	S	S	S	S
20M											
SOCAPEX IP67 2.5MM CABLE	LA43030	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40957	24/01/18	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43085	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43027	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43026	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43029	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43028	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40963	19/12/17	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40962	24/01/18	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40964	22/01/18	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40966	24/01/18	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40965	24/01/18	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40961	22/01/18	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43032	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43031	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40958	22/01/18	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40960	24/01/18	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40959	24/01/18	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43025	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43017	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43018	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43019	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43001	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43015	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43016	19/12/17	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43035	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43036	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43037	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43033	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43020	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43034	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43002	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43011	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43010	19/12/17	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43009	01/02/18	S	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
30M											
SOCAPEX IP67 2.5MM CABLE	LA43014	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43013	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43012	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43005	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43004	19/12/17	P	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43003	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43008	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43007	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43006	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43040	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43039	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43041	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43042	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43043	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43021	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43038	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43024	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA43023	01/02/18	S	S	S	S	S	S	S	S	S
30M											
SOCAPEX IP67 2.5MM CABLE	LA40745	03/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40746	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40736	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40737	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40735	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40733	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40734	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40728	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40727	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40738	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40729	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40732	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40731	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40730	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40742	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40743	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40744	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40740	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX IP67 2.5MM CABLE	LA40739	24/01/18	P	S	S	S	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
5M											
SOCAPEX IP67 2.5MM CABLE	LA40741	24/01/18	P	S	S	S	S	S	S	S	S
5M											
SOCAPEX SPLITTER RUBBER	LA25181	09/02/18	S	S	S	S	S	S	S	S	S
BOX RB											
SOCAPEX SPLITTER RUBBER	LA37069	09/02/18	S	S	S	S	S	S	S	S	S
BOX RB											
SOCAPEX SPLITTER RUBBER	LA37275	09/02/18	S	S	S	S	S	S	S	S	S
BOX RB											
SOCAPEX SPLITTER RUBBER	LA38784	09/02/18	S	S	S	S	S	S	S	S	S
BOX RB											
SOCAPEX SPLITTER RUBBER	LA16633	09/02/18	S	S	S	S	S	S	S	S	S
BOX RB											
SOCAPEX SPLITTER RUBBER	LA37805	09/02/18	S	S	S	S	S	S	S	S	S
BOX RB											
SOLARIS FLARE RGBW LED	LA37979	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.94 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37980	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.93 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37977	19/12/17	P	S	0.05 P	>300 P	0.05 P	<0.10 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37978	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.94 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37981	11/01/18	P	S	0.03 P	>300 P	0.06 P	0.95 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37984	11/01/18	P	S	0.03 P	>300 P	0.06 P	0.97 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37985	18/12/17	P	S	0.03 P	>300 P	0.06 P	0.89 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37982	11/01/18	P	S	0.06 P	>300 P	0.06 P	0.94 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37983	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.92 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37548	19/12/17	P	S	0.05 P	111.90 P	0.06 P	0.90 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37549	18/12/17	P	S	0.04 P	>300 P	0.05 P	0.93 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37546	19/12/17	P	S	0.03 P	>300 P	0.06 P	0.91 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37547	19/12/17	P	S	0.05 P	>300 P	0.06 P	<0.10 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37944	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.91 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37947	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.93 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37975	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.92 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37945	19/12/17	P	S	0.03 P	>300 P	0.06 P	<0.10 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA37946	11/01/18	P	S	0.04 P	>300 P	0.06 P	0.93 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38420	18/12/17	P	S	0.05 P	>300 P	0.05 P	0.93 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38786	19/12/17	P	S	0.04 P	>300 P	0.06 P	0.89 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38787	11/01/18	P	S	0.06 P	>300 P	0.06 P	0.96 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38430	11/01/18	P	S	0.03 P	>300 P	0.06 P	0.95 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38785	11/01/18	P	S	0.04 P	>300 P	0.06 P	0.90 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38788	19/12/17	P	S	0.04 P	>300 P	0.05 P	<0.10 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38791	11/01/18	P	S	0.04 P	>300 P	0.06 P	0.97 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38792	18/12/17	P	S	0.03 P	>300 P	0.06 P	0.90 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38789	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.88 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38790	18/12/17	P	S	0.03 P	>300 P	0.06 P	0.92 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38423	19/12/17	P	S	0.04 P	>300 P	0.06 P	0.89 P	S	S	S
STROBE											
SOLARIS FLARE RGBW LED	LA38424	18/12/17	P	S	0.03 P	>300 P	0.06 P	0.92 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
STROBE											
SOLARIS FLARE RGBW LED STROBE	LA38421	11/01/18	P	S	0.05 P	>300 P	0.06 P	0.92 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38422	11/01/18	P	S	0.05 P	>300 P	0.06 P	0.92 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38425	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.92 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38428	19/12/17	P	S	0.04 P	>300 P	0.06 P	0.88 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38429	05/01/18	P	S	0.11 P	>300 P	0.05 P	0.87 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38426	05/01/18	P	S	0.07 P	>300 P	0.05 P	0.89 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA38427	11/01/18	P	S	0.04 P	>300 P	0.05 P	0.92 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34854	18/12/17	P	S	0.04 P	>300 P	0.05 P	0.89 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41185	11/01/18	P	S	0.04 P	44.88 P	0.05 P	0.98 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34852	18/12/17	P	S	0.05 P	121.90 P	0.06 P	0.89 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34853	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.86 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41182	18/12/17	P	S	0.08 P	>300 P	0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41180	19/12/17	P	S	0.05 P	>300 P	0.05 P	0.89 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41184	11/01/18	P	S	0.07 P	>300 P	0.06 P	0.91 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41183	18/12/17	P	S	0.05 P	>300 P	<0.05 P	0.83 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34846	18/12/17	P	S	0.07 P	272.80 P	0.05 P	0.89 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34847	11/01/18	P	S	0.06 P	>300 P	0.06 P	0.94 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34844	11/01/18	P	S	0.06 P	84.68 P	0.06 P	0.93 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34845	18/12/17	P	S	0.07 P	>300 P	0.06 P	0.89 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34850	18/12/17	P	S	0.03 P	>300 P	0.06 P	0.91 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34851	19/12/17	P	S	0.05 P	>300 P	0.06 P	<0.10 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34848	18/12/17	P	S	0.06 P	>300 P	0.05 P	0.91 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA34849	18/12/17	P	S	0.06 P	>300 P	0.05 P	0.91 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41179	08/01/18	P	S	0.09 P	>300 P	0.05 P	0.88 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37467	19/12/17	P	S	0.06 P	92.26 P	0.06 P	<0.10 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37541	18/12/17	P	S	0.06 P	>300 P	0.05 P	0.79 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37442	19/12/17	P	S	0.04 P	>300 P	0.06 P	0.91 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37443	18/12/17	P	S	0.06 P	>300 P	0.05 P	0.92 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37544	11/01/18	P	S	0.05 P	>300 P	0.05 P	0.93 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37545	11/01/18	P	S	0.05 P	>300 P	0.06 P	0.97 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37542	11/01/18	P	S	0.03 P	>300 P	0.06 P	0.99 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37543	18/12/17	P	S	0.04 P	>300 P	0.06 P	0.88 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA37441	18/12/17	P	S	0.06 P	>300 P	0.06 P	0.89 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41175	11/01/18	P	S	0.03 P	>300 P	0.06 P	0.99 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41176	18/12/17	P	S	0.05 P	>300 P	0.05 P	0.85 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41177	11/01/18	P	S	0.07 P	269.30 P	0.06 P	0.95 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41174	18/12/17	P	S	0.05 P	249.10 P	0.06 P	0.88 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
STROBE											
SOLARIS FLARE RGBW LED STROBE	LA37440	18/12/17	P	S	0.05 P	>300 P	0.06 P	0.92 P	S	S	S
SOLARIS FLARE RGBW LED STROBE	LA41178	18/12/17	P	S	0.07 P	>300 P	0.05 P	0.77 P	S	S	S
SOLARIS T-LIGHT 85K WATT STROBE (SILVER)	LA34385	04/01/18	P	S	0.03 P	>300 P	0.08 P	<0.10 P	S	S	S
SOLARIS T-LIGHT 85K WATT STROBE (SILVER)	LA34384	04/01/18	P	S	0.03 P	>300 P	0.07 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01624	03/01/18	P	S	0.04 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01625	03/01/18	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01622	03/01/18	P	S	0.03 P	>300 P	0.81 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01623	03/01/18	P	S	0.03 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01628	03/01/18	P	S	0.03 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA34062	03/01/18	P	S	0.04 P	>300 P	0.81 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01626	03/01/18	P	S	0.04 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01627	03/01/18	P	S	0.04 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01614	03/01/18	P	S	0.05 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01615	03/01/18	P	S	0.05 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01613	03/01/18	P	S	0.03 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA31489	03/01/18	P	S	0.05 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA31488	03/01/18	P	S	0.04 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01616	03/01/18	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01620	03/01/18	P	S	0.04 P	>300 P	0.81 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01621	03/01/18	P	S	0.02 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01619	03/01/18	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01617	03/01/18	P	S	0.05 P	>300 P	0.82 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01618	03/01/18	P	S	0.02 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01971	03/01/18	P	S	0.04 P	>300 P	0.83 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16789	03/01/18	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16788	03/01/18	P	S	0.04 P	>300 P	0.81 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16791	03/01/18	P	S	0.03 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16790	03/01/18	P	S	0.03 P	63.87 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16787	03/01/18	P	S	0.06 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA04204	03/01/18	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA04203	03/01/18	P	S	0.08 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA16786	03/01/18	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA04206	03/01/18	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01974	03/01/18	P	S	0.02 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01973	03/01/18	P	S	0.05 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PARNEL	LA01972	03/01/18	P	S	0.04 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA15104	21/12/17	P	S	0.04 P	>300 P	0.80 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16142	02/01/18	P	S	0.05 P	>300 P	<0.05 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16566	02/01/18	P	S	0.05 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16146	03/01/18	P	S	0.04 P	>300 P	0.81 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16140	03/01/18	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA20840	02/01/18	P	S	0.06 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA20841	02/01/18	P	S	0.04 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA31484	02/01/18	P	S	0.08 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16567	02/01/18	P	S	0.04 P	>300 P	0.76 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA20848	21/12/17	P	S	0.08 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA20847	02/01/18	P	S	0.07 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA31487	02/01/18	P	S	0.05 P	220.70 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA31485	03/01/18	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24032	02/01/18	P	S	0.03 P	273.20 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24034	02/01/18	P	S	0.05 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24028	21/12/17	P	S	0.05 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24029	03/01/18	P	S	0.06 P	>300 P	0.78 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16139	02/01/18	P	S	0.09 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA25051	21/12/17	P	S	0.09 P	>300 P	0.79 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24465	02/01/18	P	S	0.06 P	>300 P	0.62 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA24464	21/12/17	P	S	0.06 P	>300 P	0.81 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA25114	02/01/18	P	S	0.06 P	10.13 P	0.76 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA01935	02/01/18	P	S	0.09 P	>300 P	<0.05 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA25619	02/01/18	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA25618	02/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16009	02/01/18	P	S	0.07 P	>300 P	0.77 P	<0.10 P	S	S	S
SOURCE 4 PROFILE BACK END	LA16014	02/01/18	P	S	0.07 P	>300 P	0.77 P	<0.10 P	S	S	S
STRAND 100 PLUS SERIES 12/24 PSU	LA34354	22/01/18	P	S	S	>300 P	S	S	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
STRAND BAMBINO 2000W FRESNEL	LA21630	09/01/18	P	S	0.07 P	>300 P	1.97 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21629	09/01/18	P	S	0.06 P	>300 P	2.01 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21632	09/01/18	P	S	0.09 P	>300 P	1.99 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21631	09/01/18	P	S	0.07 P	>300 P	2.01 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21624	09/01/18	P	S	0.07 P	>300 P	<0.05 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21198	09/01/18	P	S	0.07 P	>300 P	1.98 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21192	09/01/18	P	S	0.07 P	>300 P	2.31 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21625	09/01/18	P	S	0.06 P	>300 P	1.99 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21628	09/01/18	P	S	0.06 P	>300 P	1.97 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21627	09/01/18	P	S	0.06 P	>300 P	1.99 P	<0.10 P	S	S	S
STRAND BAMBINO 2000W FRESNEL	LA21626	09/01/18	P	S	0.08 P	>300 P	1.99 P	<0.10 P	S	S	S
SUPER-NOVA 2K MOVING	LA34081	15/01/18	P	S	0.05 P	>300 P	0.05 P	0.45 P	S	S	S
SUPER-NOVA 2K MOVING	LA34082	15/01/18	P	S	0.08 P	>300 P	0.05 P	0.49 P	S	S	S
SUPER-NOVA 2K MOVING	LA34080	15/01/18	P	S	0.08 P	>300 P	0.05 P	0.45 P	S	S	S
SUPER-NOVA 2K MOVING	LA34078	15/01/18	P	S	0.06 P	>300 P	0.05 P	0.46 P	S	S	S
SUPER-NOVA 2K MOVING	LA37156	15/01/18	P	S	0.07 P	>300 P	0.05 P	0.47 P	S	S	S
SUPER-NOVA 2K MOVING	LA34750	15/01/18	P	S	0.06 P	>300 P	0.05 P	0.47 P	S	S	S
SUPER-NOVA 2K MOVING	LA34077	15/01/18	P	S	0.05 P	>300 P	0.05 P	0.45 P	S	S	S
SUPER-NOVA 2K MOVING	LA34079	15/01/18	P	S	0.05 P	>300 P	0.05 P	0.45 P	S	S	S
TFT MONITOR 17``	LA25037	23/01/18	P	S	0.08 P	S	<0.05 P	<0.10 P	S	S	S
TFT MONITOR 17``	LA26028	23/01/18	P	S	0.06 P	S	<0.05 P	<0.10 P	S	S	S
TFT MONITOR 17``	LA25044	23/01/18	P	S	0.06 P	S	<0.05 P	<0.10 P	S	S	S
TFT MONITOR 17``	LA24823	24/01/18	P	S	0.06 P	S	<0.05 P	0.51 P	S	S	S
TFT MONITOR 17``	LA25033	23/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
TFT MONITOR 17``	LA25034	23/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
TFT MONITOR 24``	LA31160	25/01/18	P	S	0.06 P	S	0.05 P	0.51 P	S	S	S
TFT MONITOR 24``	LA31159	25/01/18	P	S	0.06 P	S	0.05 P	0.46 P	S	S	S
TFT MONITOR 24``	LA31162	18/01/18	P	S	0.09 P	S	0.05 P	0.48 P	S	S	S
TFT MONITOR 24``	LA34178	23/01/18	P	S	0.05 P	S	<0.05 P	<0.10 P	S	S	S
TFT MONITOR 24``	LA41537	23/01/18	P	S	0.06 P	S	<0.05 P	<0.10 P	S	S	S
TFT MONITOR 24``	LA34179	23/01/18	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
TFT MONITOR 24``	LA31157	24/01/18	P	S	0.07 P	S	0.05 P	0.43 P	S	S	S
TFT MONITOR 24``	LA37392	23/01/18	P	S	0.04 P	S	<0.05 P	<0.10 P	S	S	S
TFT MONITOR 24``	LA25365	24/01/18	P	S	0.07 P	S	<0.05 P	0.42 P	S	S	S
TFT MONITOR 24``	LA37391	23/01/18	P	S	0.07 P	S	<0.05 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24043	04/01/18	P	S	0.03 P	>300 P	1.00 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24042	04/01/18	P	S	0.02 P	>300 P	1.01 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24045	04/01/18	P	S	0.02 P	>300 P	1.01 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24044	04/01/18	P	S	0.02 P	202.90 P	1.02 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24035	04/01/18	P	S	0.02 P	>300 P	0.99 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24037	04/01/18	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24038	04/01/18	P	S	0.02 P	>300 P	1.00 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24036	04/01/18	P	S	0.02 P	>300 P	0.99 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24041	04/01/18	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24039	04/01/18	P	S	0.02 P	>300 P	1.03 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24048	04/01/18	P	S	0.02 P	>300 P	1.00 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24047	04/01/18	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24040	04/01/18	P	S	0.02 P	>300 P	<0.05 P	<0.10 P	S	S	S
THOMAS 1000W CYC UNIT	LA24046	04/01/18	P	S	0.02 P	>300 P	1.00 P	<0.10 P	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA26023	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA25962	12/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA24529	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
TMB DATA LYNX DMX SWITCHING/SAVING	LA25961	12/12/17	P	S	0.07 P	>300 P	S	S	S	S	S
TV ONE C2 SCAN CONVERTER PSU	LA40270	12/01/18	P	S	S	S	S	<0.10 P	S	S	S
TV ONE C2 SCAN CONVERTER	LA40271	12/01/18	P	S	S	S	S	<0.10 P	S	S	S

Appliance Description	Appliance Id	Test Date	Vis	Pol	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Touch Leak mA	Sub Leak mA	Flash mA
PSU											
TWIN HEAD EMERGENCY SPOT LIGHTS	LA31670	08/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
TWIN HEAD EMERGENCY SPOT LIGHTS	LA31668	08/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
TWIN HEAD EMERGENCY SPOT LIGHTS	LA31672	08/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
TWIN HEAD EMERGENCY SPOT LIGHTS	LA31671	08/12/17	P	S	0.04 P	>300 P	<0.05 P	<0.10 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31907	14/12/17	P	S	0.03 P	>300 P	0.13 P	0.93 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31906	14/12/17	P	S	0.03 P	>300 P	0.13 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31905	14/12/17	P	S	0.04 P	>300 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA34949	14/12/17	P	S	0.04 P	>300 P	0.13 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31909	14/12/17	P	S	0.02 P	>300 P	0.13 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31908	14/12/17	P	S	0.03 P	>300 P	0.13 P	0.89 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31904	14/12/17	P	S	0.04 P	>300 P	0.05 P	0.88 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31865	14/12/17	P	S	0.04 P	>300 P	0.13 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31864	15/12/17	P	S	0.03 P	>300 P	0.13 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31866	14/12/17	P	S	0.04 P	>300 P	0.13 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31868	14/12/17	P	S	0.04 P	>300 P	0.13 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31867	14/12/17	P	S	0.03 P	>300 P	0.13 P	0.88 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31863	14/12/17	P	S	0.03 P	>300 P	0.13 P	0.92 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31461	14/12/17	P	S	0.03 P	>300 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31460	14/12/17	P	S	0.03 P	>300 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31462	14/12/17	P	S	0.04 P	>300 P	0.13 P	0.91 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31464	15/12/17	P	S	0.03 P	>300 P	<0.05 P	0.27 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31463	14/12/17	P	S	0.03 P	>300 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31869	14/12/17	P	S	0.03 P	>300 P	0.13 P	0.89 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31902	14/12/17	P	S	0.04 P	>300 P	0.13 P	0.93 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31870	15/12/17	P	S	0.03 P	>300 P	0.13 P	0.90 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31903	15/12/17	P	S	0.02 P	>300 P	<0.05 P	0.30 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31871	14/12/17	P	S	0.04 P	>300 P	0.13 P	0.95 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31872	15/12/17	P	S	0.02 P	>300 P	0.13 P	0.91 P	S	S	S
VARI*LITE VL3500 WASH FX	LA31901	14/12/17	P	S	0.02 P	>300 P	0.13 P	0.89 P	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22940	20/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA31663	20/12/17	P	S	0.05 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22943	20/12/17	P	S	0.05 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22944	20/12/17	P	S	0.04 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22945	20/12/17	P	S	0.06 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA31664	20/12/17	P	S	0.03 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22941	20/12/17	P	S	0.05 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX R-512 RECEIVER	LA22942	20/12/17	P	S	0.03 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX S-1 TRANSMITTER	LA37332	12/12/17	P	S	0.08 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX S-1 TRANSMITTER	LA22939	20/12/17	P	S	0.04 P	>300 P	S	S	S	S	S
WIRELESS SOLUTIONS W-DMX S-1 TRANSMITTER	LA22938	20/12/17	P	S	0.04 P	>300 P	S	S	S	S	S
WYBRON IRIS 2K DOWSER FOR WILDFIRE UV LAMP	LA31509	08/01/18	P	S	0.06 P	>300 P	<0.05 P	0.89 P	S	S	S

Total Appliances: 8,004
Total Appliances For Report: 8,004